

1 Q. Further to the response to PUB-NLH-217, page 8-9 which states that standby
2 generation would be available in 10 to 20 minutes, information filed by Hydro in
3 response to GT-NP-NLH-007 in the Application for Approval of a Capital Project to
4 Supply and Install 100 MW of Combustion Turbine Generation states that the start
5 time for the new 100 MW gas turbine at Holyrood is 40 minutes to full load. What
6 impact does this have on the reliability associated with the Labrador Island Link?

7

8

9 A. The start-up time for the new combustion turbine will have minimal impact on the
10 reliability associated with the Labrador-Island Link. As stated in Hydro's response to
11 GT-NP-NLH-007¹ in the Board proceeding *Supply & Install of 100MW Combustion*
12 *Turbine Generator*, the 40 minutes to full load start-up time reflects a normal "from
13 cold" start. PUB-NLH-278 Attachment 1 also indicates that procedures will be
14 developed to minimize the unit start up time. During periods of heightened alert
15 due to weather conditions or reduced operating reserves, the unit will be placed in
16 a state of readiness to further reduce the time required to supply customers. It is
17 during these times of heightened alert that a failure of the Labrador-Island Link
18 would have the greatest reliability impact and the timely availability of the
19 combustion turbine is most important.

¹ Attached as PUB-NLH-278 Attachment 1.

100 MW Combustion Turbine Generation - Holyrood

1 Q. In the event of a sudden and unexpected loss of generation or transmission assets
2 on the Island Interconnected System, how long does Hydro expect it would take to
3 start the 100 MW combustion turbine and supply 100 MW of load?
4

5
6 A. The new 120 MW combustion turbine is being designed and constructed to
7 complement existing generating capacity to provide reliable service to customers. It
8 will be placed in dispatch order with other available generating capacity including
9 existing gas turbines to meet service reliability requirements and minimize
10 operating costs. Procedures will be developed, implemented, tested and drilled
11 with staff to provide the minimum start-up and loading time under different
12 operating scenarios.
13

14 During periods of heightened alert during severe weather conditions or reduced
15 operating reserves, the unit will be placed in a state of readiness including, as the
16 situation dictates, being placed on-line to be ready to quickly increase output as
17 required to supply customers.
18

19 Under the stated scenario of the question, where a heightened level of readiness is
20 not in place, the start-up and loading time for the unit has been estimated for the
21 following scenarios:
22

23 Scenario 1 - Emergency Service Duty: Start-up power is provided from the Island
24 Grid.

25 Estimated time: 40 minutes

100 MW Combustion Turbine Generation - Holyrood

1 It is estimated it will take 20 minutes to bring the main generator unit to its
2 minimum load. It will then take an additional 20 minutes to load the unit to 100
3 MW.

4
5 Scenario 2 – Blackstart Service: Start-up power is provided from the unit’s blackstart
6 facilities.

7 Estimated time: 55 minutes

8

9 The plant is equipped with a diesel generating unit and a small combustion turbine
10 to provide blackstart capability for the main generator. It is estimated it will take 15
11 minutes to bring the main generating unit to the “Ready to Start” status using this
12 equipment. It will take an additional 20 minutes to bring the main generator up to
13 speed and support the blackstarting load requirement of the Holyrood Thermal
14 Generating Station load. It will take an additional 20 minutes to bring the unit to a
15 100 MW output level. The actual rate of picking up customer load under a
16 blackstart scenario will be established through procedures developed between
17 Hydro’s Energy Control Centre and Newfoundland Power’s control centre.