

1 Q. **Asset Management**

2 Provide, in tabular form, the numbers of distribution substation transformers on
3 Hydro's system by age groups (0-10, 11-20, 21-30, 31-40 and greater than 40 years).
4 Provide estimates of actual ages are not known.

5

6

7 A. There are 47 distribution substation transformers on the Island Interconnected
8 System. The table below summarizes the age groups of those transformers.

9

Age Groups (Years)	Numbers of Transformer
0-10	4
11-20	3
21-30	7
31-40	11
> 40	22