

1 Q. Further to the response to PUB-NLH-244, will the dc cable be HV tested before the
2 rock dumping operation and again afterward?

3

4

5 A. The dc cables will be tested both prior to and after rock placement.