

1 Q. Further to PUB-NLH-481, what mitigation measures, other than curtailment of the  
2 Maritime Link, will be considered to avoid curtailment?

3

4

5 A. As noted in Hydro's response to PUB-NLH-476, curtailment of the Maritime Link  
6 (ML) for issues associated with the Labrador - Island HVdc Link (LIL) is acceptable.  
7 As a result, curtailment of the ML is a primary component in maintaining Island  
8 Interconnected System stability.

9

10 With respect to mitigation measures to avoid load shedding when the LIL is  
11 operating in monopolar mode, please refer to Hydro's response to PUB-NLH-482.