

1 Q. Further to the response to PUB-NLH-468, please explain the potential reduction in
2 power delivery capability when operating in monopolar operation with a single
3 electrode conductor in Labrador during high load periods on the Interconnected
4 Island System. In the response include the amount of load shedding that would be
5 required during worst case conditions.
6
7

8 A. Periods of high load on the Island Interconnected System will occur during the
9 winter months when the ambient temperatures are at their lowest and residential
10 heating requirements are at their greatest. With respect to Hydro's response to
11 PUB-NLH-468 Table 2, the Labrador-Island HVdc Link (LIL) has a calculated
12 continuous power delivery of 416.3 MW at Soldiers Pond for an ambient
13 temperature of 0 °C with one electrode conductor in service between Muskrat Falls
14 and L'Anse au Diable.
15

16 As noted in Hydro's response to PUB-NLH-217, the LIL deliveries between Emera
17 and Hydro will be shared on a pro rata basis during continuous monopolar mode of
18 operation. To this end the Nova Scotia block is 78.3 MW and the Island (Hydro)
19 portion is 338 MW. Recall from PUB-NLH-217 the Island entitlement under normal
20 bipole mode of operation equals a maximum of 673 MW under maximum (900
21 MW) LIL loading. With the LIL entering monopolar mode, Hydro would initiate start
22 of all standby generation having a total capacity of 276.2 MW. The combined
23 capacity for standby generation and available capacity from LIL in monopolar mode
24 with one electrode conductor out of service in Labrador equals 614.2 MW (338 MW
25 + 276.2 MW). Consequently, load shed due to the LIL operating in monopolar mode
26 with one electrode conductor in service in Labrador could equal 58.8 MW (673 MW
27 – 614.2 MW).