

1 Q. Reference PUB-NLH-265: It is stated that the present UFLS has df/dt settings at
2 0.5Hz/s, 0.6Hz/s and 0.7Hz/s. What will be the range of df/dt when the LIL is in
3 service providing minimum or maximum power to the IIS?

4

5

6 A. Hydro has not defined the range of df/dt relaying to be employed when the LIL is in
7 service at this point in time. For further details concerning the revised Under
8 Frequency Load Shedding (UFLS) scheme please refer to responses PUB-NLH-535,
9 PUB-NLH-536 and UB-NLH-537.