

1 Q. Reference PUB-NLH-265: Has Hydro made any progress towards determining an
2 appropriate protection scheme for post LIL? If so, please explain the general
3 principles of the proposed new scheme. If not, when will it be completed?
4
5

6 A. The study outlining the Under Frequency Load Shedding (UFLS) scheme for post
7 Labrador – island HVdc Link (LIL) implementation has not been completed. The
8 analysis is expected to be complete at the end of 2016. The high level guiding
9 principles for the study are summarized as follows:

- 10 • The existing UFLS for the isolated Island Interconnected System permits
11 UFLS operation for a single contingency loss of on Island generation;
- 12 • The post LIL UFLS will prevent load loss (i.e. no operation of UFLS) for the
13 following single contingency events:
 - 14 ○ Temporary loss of one pole of the LIL bipole (temporary block and
15 restart of a pole);
 - 16 ○ Permanent loss of one pole of the LIL bipole (2 p.u. current operation
17 on healthy pole for ten minutes with continuous operation of the
18 monopole at 1.5 p.u. current);
 - 19 ○ Temporary loss of the LIL bipole (temporary bipole block and
20 restart);
 - 21 ○ Curtailment of Maritime Link exports is acceptable for LIL pole and
22 bipole contingencies;
 - 23 ○ Single generation contingencies on the Island Interconnected System
24 including:
 - 25 ■ Bay d’Espoir Unit 7 - 154 MW (Largest single generator)

- 1 the LIL to ensure that the Island Interconnected System frequency does not
2 fall below 59 Hz for loss of the 154 MW;
- 3 • The study will consider the appropriate NERC standards and NPCC
4 directories with respect to an appropriate level of spinning reserve for on
5 island generator contingencies;
 - 6 ○ Notionally the concept of spinning and non-spinning reserves
7 (synchronized or non-synchronized) and ten minute and 30 minute
8 reserves will be considered given the HVdc links to the North
9 American grid
 - 10 ○ The applicability of having spinning reserve for the first generation
11 loss and one half the capacity for the second contingency loss will be
12 explored (i.e. 154 MW plus 75 MW or 229 MW).