

1 Q. Reference PUB-NLH-279: Please state whether or not Hydro expects to provide
 2 sufficient generation capacity within the IIS so that the peak demand could be met
 3 at all times in the absence of the LIL but with support from ML. If the answer is no,
 4 please provide an estimate of the additional cost that the provision of this level of
 5 generation would incur and estimate the extra annual cost that would have to be
 6 recovered from the average domestic consumer. In the response state what would
 7 the maximum power and energy delivered via the ML be and how often statistically
 8 would import via the ML be required.

9
 10
 11 A. Hydro has not yet completed its review of the generation capacity planning criteria
 12 to be applied following the interconnections via the ML and LIL which will lead to
 13 the identification of new generation capacity additions. In the absence of the LIL the
 14 existing generation plus support from the MIL would be sufficient to meet demand
 15 until 2024 (see Table 2). In order to continue to meet the peak demand under these
 16 conditions, additions as noted in Table 1 and Table 2 would be required. Additions
 17 are required due to both increases in the load forecast and to asset retirements
 18 such as the Stephenville CT in 2025 and the Hardwoods CT in 2028.

19
 20 Generation Additions

21

Year	Addition
2024	1 x 100 MW CT
2027	1 x 100 MW CT
2030	1 x 50 MW CT
2033	1 x 50 MW CT

22
 23
 24
 25
 26

Table 1

Island Interconnected System Supply Issues and Power Outages

1 The Net Present Value of these additions is \$391.8 million. Other alternatives, such
 2 as interruptible contracts or customer curtailable load, could also be considered at
 3 the time as alternatives to additional generation. It is also possible that by the time
 4 additional capacity were required the existing system constraints in the Maritime
 5 provinces could be alleviated allowing for the import of up to an additional 200 MW
 6 over the Maritime Link.
 7

Generation Additions in the Absence of LIL														
	Island Interconnected Peak Demand (MW)	NL Hydro (MW)	NL Hydro Thermal ⁴ (MW)	Customer ⁵ Generation (MW)	NUG ^{3,6} Purchases (MW)	Labrador Island Link (MW)	Maritime Island Link ² (MW)	Continuous Capacity at Winter Peak (MW)	Reserve (MW)	Reserve Margin (%)	Additions Total (MW)	Reserve with Additions (MW)	Additions - CTs	
	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(%)	(MW)	(MW)	50 MW	100 MW
2020	1736	954	738.2	217	89	0	300	2,298	562	32.4%	0	562		
2021	1744	954	738.2	217	89	0	300	2,298	555	31.8%	0	555		
2022	1755	954	238.2	217	89	0	300	1,798	44	2.5%	0	44		
2023	1764	954	238.2	217	81	0	300	1,790	26	1.5%	0	26		
2024	1777	954	238.2	217	81	0	300	1,790	13	0.7%	100	113		1
2025	1793	954	238.2	217	81	0	300	1,790	-3	-0.2%	100	97		
2026	1813	954	188.2	217	81	0	300	1,740	-73	-4.0%	100	27		
2027	1831	954	188.2	217	81	0	300	1,740	-91	-5.0%	200	109		1
2028	1853	954	188.2	217	81	0	300	1,740	-112	-6.1%	200	88		
2029	1873	954	138.2	217	81	0	300	1,690	-183	-9.8%	200	17		
2030	1885	954	138.2	217	81	0	300	1,690	-195	-10.4%	250	55	1	
2031	1905	954	138.2	217	81	0	300	1,690	-214	-11.3%	250	36		
2032	1922	954	138.2	217	81	0	300	1,690	-232	-12.1%	250	18		
2033	1938	954	138.2	217	81	0	300	1,690	-248	-12.8%	300	52	1	
2034	1956	954	138.2	217	81	0	300	1,690	-266	-13.6%	300	34		
2035	1972	954	138.2	217	81	0	300	1,690	-282	-14.3%	300	18		
	1. There are currently no demand management initiatives, other than the potential use of interruptible contracts, forecast during this period.													
	2. Assumes capacity is available through market or other contractual means to enable full use of the available transmission capacity.													
	3. Assumes that CBPP Co-Generation NUG contract is not renewed in 2023.													
	4. Assumes that Holyrood shuts down in 2021, Stephenville GT shuts down in 2025 and Hardwoods GT shuts down in 2028													
	5. Assumes capacity at winter peak of 117.9 MW for NP and 99.1 MW for Deer Lake Power.													
	6. Assumes capacity at winter peak of 18 MW for Star Lake, 8 MW for Corner Brook Co-gen and 63 MW for Nalcor Grand Falls and Bishop's Falls. Rattle Brook, Nalcor Buchans, St. Lawrence Wind and Fermeuse Wind are assumed to have 0 MW capacity at winter peak.													

Table 2

1 The extra annual cost that would have to be recovered from the average domestic¹
 2 consumer is shown in Figure 1.




Figure 1

3
 4 Based on demand and unavailable generation at any given time, up to 300 MW (the
 5 capacity of the ML) could be required from the ML. The maximum energy required
 6 would depend on the requirements of the IIS. Table 3 gives the average annual
 7 energy expected over the ML during an emergency situation.

8
 9 It is difficult to determine statistically how often imports would be required via the
 10 ML, but the results of Table 3 would indicate that on average full load over the ML
 11 would be required less than an hour or two per year.

¹ Domestic in this instance is interpreted as residential customers.

Year	Total MIL Energy
	GWH
2020	0.2
2021	0.2
2022	0.2
2023	0.2
2024	0.2
2025	0.2
2026	0.2
2027	0.2
2028	0.2
2029	0.3
2030	0.4
2031	0.4
2032	0.4
2033	0.5
2034	0.6
2035	0.6

Table 3