

1 Q. When Hydro performs generation planning studies using Strategist, is the LIL  
2 modelled as a generator and ML as a curtailable load?

3

4

5 A. Currently, when Hydro performs generation planning studies using Strategist, both  
6 the LIL and the MIL are modelled as generators. Currently, the Emera block is  
7 netted out incoming on the LIL and outgoing on the MIL.