

**Island Interconnected System Supply Issues and Power Outages**

1 Q. Please provide the maximum power that can be delivered to Soldiers Pond during  
 2 monopolar operation with metallic return.

3  
 4

5 A. Based upon the converter manufacturer’s main scheme parameters used for design  
 6 the following nominal ratings of the Labrador – Island HVdc Link are being used  
 7 within the analysis:  
 8

Nominal Ratings of Labrador – Island HVdc Link				
Mode of Operation	Parameter	Pole 1	Pole 2	Total
Bipolar	kV	350	350	
	Current	1286	1286	
	Sending MW	450	450	900
	losses MW	33.1	33.1	66.2
	Receiving MW	418.1	418.1	833.8
Monopolar 2 pu Ground Return (ten minute)	kV	350	-	
	Current	2572	-	
	Sending MW	900	-	900
	losses MW	212.7	-	212.7
	Receiving MW	687.3	-	687.3
Monopolar 1.5 pu Ground Return (continuous)	kV	350	-	
	Current	1929	-	
	Sending MW	675	-	675
	losses MW	119.7	-	119.7
	Receiving MW	555.3	-	555.3
Monopolar Metallic Return	kV	350	-	
	Current	1286	-	
	Sending MW	450	-	450
	losses MW	64	-	64
	Receiving MW	386.8	-	386
Notes				
Does not include Station Service Loads				
In Metallic Return there will be a single cable in the path with a continuous current limit of 1286 A.				