

1 Q. Reference PUB-NLH-504: What would be the cost of an additional 50MW GT?

2

3

4 A. An indicative estimate of cost to add a 50MW GT, assuming installation at Holyrood
5 and transmission and terminal station work to connect it to the system, would be in
6 the order of \$125 million (2017\$).