

1 Q. Please explain why the Holyrood de-rates extend to emergency situations.

2

3

4 A. The Holyrood de-rates extend to emergency power system situations as well as
5 normal operation to minimize the risk and consequence of forced outages and
6 further de-ratings due to possible tube failures. The consequence of a boiler tube
7 failure may be a loss of generation from Holyrood. In an emergency power
8 situation, maintaining generation from Holyrood could be critical.