

1 Q. Please provide Hydro's estimate of UFOP for Hardwoods and Stephenville gas
2 turbines used in the Energy Supply Risk Assessment Report for the period 2016 -
3 2021.

4

5

6 A. Hydro used its sensitivity estimate of UFOP = 20% for both Hardwoods and
7 Stephenville gas turbines for the period 2016-2021.