

1 Q. Further to PUB-NLH-617, please describe the actions that the Island Interconnected
2 system operator has to take in order to re-instate the loads which have been shed
3 including how long would these actions take and whether the re-instatement of the
4 loads would wait until all generation has been brought on line, or would loads be
5 connected gradually, as generation becomes available.

6

7

8 A. The re-instatement of load would be in stages as generation becomes available.
9 Local generation would be started as specified in Hydro's response to PUB-NLH-617
10 until capacity from the Labrador Island Link is restored. In the event of a sustained
11 outage to the Labrador Island Link bipole, processes for importing capacity over the
12 Maritime Link, which are yet to be developed, would be initiated.