

Q. Reference: Energy Supply Risk Assessment Update, November 30, 2016, page 26, Table 2 and Appendix A, page 5. Please provide the definition and equation for UFOP, and provide a spreadsheet with the underlying data used by Hydro to calculate UFOP for Hardwoods and Stephenville for the past five years.

A. The following outlines the definition and equations used to calculate the Utilization Forced Outage Probability (UFOP) values in Hydro's Energy Supply Risk Assessment. UFOP is defined as the probability that a generating unit will not be available when required. The equation used to calculate UFOP is:

UFOP Calculation Equation

The following equations are used for calculating UFOP.

$$UFOP = \frac{f(FO + FEMO + FEPO)}{f(FO + FEMO + FEPO) + O + O(SD) + O(FD)}$$

Where f = Demand Factor

$$f = \left(\frac{1}{r} + \frac{1}{T} \right) / \left(\frac{1}{D} + \frac{1}{r} + \frac{1}{T} \right)$$

Where r = Average Forced Outage Time

$$r = \frac{FO + FEMO + FEPO}{No. of Forced Outages}$$

D = Average In-Service Time per Occasion of Demand

$$D = \frac{O + O(FD) + O(SD)}{SR * Total Attempted Starts}$$

SR = the Starting Reliability. It gives the ratio of successful starts to start attempts.

$$SR = \frac{Total Attempted Start - Total Start Failures}{Total Attempted Starts}$$

Total Attempted Starts – Total start failures plus the number of transitions to operating from a non operating state plus the number of transitions into a synchronous condenser mode from a non operating state.

T = Average Reserve Shutdown Time between Periods of Need

$$T = \frac{ABNO + ABNO(FD) + ABNO(SD)}{Total Attempted Starts}$$

Other defintions:

O means the Generating Unit is synchronized with the system and is capable of operating at MCR under normal operating procedures.

$O (FD)$ means the Generating Unit is synchronized with the system but not capable of carrying its MCR due to a Forced Derating being in effect.

$O (SD)$ means the Generating Unit is synchronized with the system but not capable of carrying its MCR due to a Scheduled Derating being in effect.

FO means the Generating Unit is on a Forced Outage (see Clause 3.1 and Section 6.0). Should another reason cause an extended Forced Outage, it should be reported as a separate Forced Outage with a start time equal to the finish time of the prior Forced Outage.

FEMO means the Generating Unit has an outage resulting from a condition discovered during a Maintenance Outage which has forced the extension of the Maintenance Outage.

FEPO means the Generating Unit has an outage resulting from a condition discovered during a Planned Outage which has forced the extension of the Planned Outage

Please refer to PUB-NLH-636, Attachments 1 to 6 – Underlying Data, for the spreadsheets used to calculate the UFOP for each year from 2011 to 2015 and the 2011 to 2015 average for Hardwoods and Stephenville.

The following table summarizes the UFOP for Hardwoods and Stephenville for each year from 2011 to 2015 and the 2011 to 2015 averages.

UFOP

| Year | HWD/SVL | SVL | HWD |
|----------------------------|---------|--------|-------|
| 2011 | 10.27 | 15.20 | 6.30 |
| 2012 | 56.58 | 100.00 | 16.65 |
| 2013 | 34.03 | 50.00 | 14.42 |
| 2014 | 16.73 | 13.73 | 19.42 |
| 2015 | 12.72 | 15.59 | 5.63 |
| NLH Average (2011-2015) | 28.08 | 39.52 | 16.54 |

| Unit | Start_Date | Finish_Date | State Code | Outage Code | Synch/Condense | State | Operating? | Synch Cond | Prev Stat Already | Prev Stat Already | S.C.? | Trans to SC? | Starting Failure? |
|------|------------------|------------------|---|--|----------------|-------|------------|------------|----------------------|----------------------|-------|--------------|-------------------|
| HWDT | 12:01 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:16 | 12:25 | 21 (2)-FO-2 : Forced Outage - Immediately Deferrable | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:26 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/01/05 7:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:45 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:47 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/01/10 9:34 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:42 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:43 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:26 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/01/27 8:17 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:16 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/01/31 7:35 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:02 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/01/31 | 2011/02/01 | | (49950) Fuel Management Controls and Instrumentation | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 11:43 | 15:03 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:02 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:44 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:12 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:20 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:39 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:20 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/02/22 7:49 | 2011/02/22 16:05 | 25-PO : Planned Outage | (64210) Supervisory Control & Data Acquisition (SCADA) | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:05 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/02/23 7:33 | 16:34 | 24-MO : Maintenance Outage | (49900) Controls and Instrumentation | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:34 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:38 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/02/25 9:08 | 13:16 | 25-PO : Planned Outage | (49900) Controls and Instrumentation | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:16 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/03/01 8:21 | 2011/03/01 9:03 | 25-PO : Planned Outage | (49900) Controls and Instrumentation | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/03/01 9:03 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:43 | 12:56 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:56 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/03/07 9:23 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 15:39 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/03/08 8:23 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 15:43 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/03/23 7:54 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/03/23 9:49 | 13:17 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:17 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/04/14 8:55 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/04/14 9:39 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:30 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:05 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:51 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:25 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 19:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/04/27 8:34 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:50 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/05/09 9:13 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 23:05 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:38 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:12 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/05/24 9:19 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 19:47 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/05/25 12:12 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 12:19 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:17 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:42 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:35 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:44 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:46 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:58 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:02 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:13 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:25 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:14 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:17 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:25 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:30 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/06/22 1:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/06/22 1:40 | 2011/06/22 2:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/06/22 2:59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |

| | | | | | | | | | | | | |
|------|-------------------|--|----------------|----------------------------|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 2011/06/22 6:35 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:23 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:32 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/08/22 5:58 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| HWDT | 22:59 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:36 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:41 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:18 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:55 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:01 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:33 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:09 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/09/21 19:03 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 12:28 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:02 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 22:28 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/09/29 7:35 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 22:43 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/05 7:38 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:12 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:07 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:08 | 10:17 21 (1)-FO-1 : Forced Outage - Sudden | | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:17 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:20 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:31 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:10 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:01 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:15 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:58 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:59 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 22:33 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/21 9:11 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:41 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/22 7:53 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:28 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/25 8:19 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/25 9:38 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:41 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:17 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:15 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 19:06 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/27 7:35 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:00 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:35 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/10/28 7:50 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 21:50 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/29 9:14 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:54 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/30 8:53 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 21:48 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/31 7:13 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 22:01 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/11/03 0:30 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/11/10 3:18 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/11/10 7 7:30 | 17:08 24-MO : Maintenance Outage | | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:08 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/11/14 7:30 | 16:24 25-PO : Planned Outage | | (49100) Combustion Turbine | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:10 | 13:49 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:43 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:49 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:49 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:24 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:49 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:01 | 14:17 21 (1)-FO-1 : Forced Outage - Sudden | | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:17 | 12-0 (FD) : Operating under Forced Derated | | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:32 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:28 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:42 | 15-ABNO (FD) : Available but not operating - | Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |

| Unit | Start_Date | Finish_Date | State Code | Outage Code | Synch/Condense | State | Operating? | Synch Cond? | Prev Stat Already | Prev Stat S.C.? | Trans to SC? | Starting Failure? |
|------|-----------------|---|---|--|----------------|-------|------------|-------------|----------------------|--------------------|--------------|-------------------|
| SVLT | 17:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:11 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 23:59 | 23:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49820) Generator Stator | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2011/01/20 9:51 | 11:12 | 21 (1)-FO-1 : Forced Outage - Sudden | (49253) Intercoolers | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:13 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:30 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:02 | 15:16 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:16 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:40 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:41 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2011/02/15 7:05 | 14:49 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:49 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2011/02/17 8:12 | 15:15 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:15 | | 14-ABNO : Available but not operating | (49100) Combustion Turbine | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 13:49 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:38 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2011/03/07 | 2011/03/07 | 21 (1)-FO-1 : Forced Outage - Sudden | (49311) Internal Cooling and Seal Air System and Seals | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:46 | 17:46 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 19:00 | 20:07 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2011/03/15 9:18 | 14:14 | 24-MO : Maintenance Outage | (49800) Generator | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:14 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/03/16 8:23 | 2011/03/16 | 24-MO : Maintenance Outage | (49980) Auxiliaries Controls and Instrumentation | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:21 | 16:21 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/03/18 9:48 | 14:39 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:46 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2011/03/23 7:05 | 11:20 | 24-MO : Maintenance Outage | (49280) Battery and Charger System | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/03/24 6:50 | 15:28 | 24-MO : Maintenance Outage | (49280) Battery and Charger System | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:28 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 11:49 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:49 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:19 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 14:53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2011/04/20 8:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:11 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:34 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:09 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:08 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:02 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:19 | 16:57 | 25-PO : Planned Outage | (49321) External Cooling Air System | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:57 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/06/14 9:27 | 12:00 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2011/06/14 9:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2011/06/16 8:59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:58 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 10:01 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:14 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:11 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 14:20 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:51 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/07/27 7:47 | 16:41 | 25-PO : Planned Outage | (49293) Exhaust Stack and Silencer | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:41 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/07/29 9:27 | 12:00 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:13 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2011/08/15 9:29 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:29 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 14:21 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:09 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2011/08/26 8:32 | 11:03 | 24-MO : Maintenance Outage | (49325) Building Fire Protection | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 1 | 0 |
| SVLT | 11:03 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/09/09 7:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:51 | 15:18 | 25-PO : Planned Outage | (49321) External Cooling Air System | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/09/14 5:56 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2011/09/14 8:49 | 18:48 | 25-PO : Planned Outage | (5200) Transmission Limitations | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:48 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 19:14 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/09/15 5:37 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2011/09/15 6:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/09/15 7:10 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:06 | 18:55 | 25-PO : Planned Outage | (5200) Transmission Limitations | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 19:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/09/19 7:32 | 19:39 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49890) Electrical Distribution System | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 19:39 | | 25-PO : Planned Outage | (49100) Combustion Turbine | TRUE | 25 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/09/20 7:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2011/09/20 9:55 | 16:21 | 25-PO : Planned Outage | (49890) Electrical Distribution System | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2011/09/22 8:22 | 14:38 | 25-PO : Planned Outage | (49325) Building Fire Protection | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:38 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |

PUB-NLH-636, Attachment 1
Page 4 of 6, Isl Int System Power Outages (Phase Two)

| | | | | | |
|------|-----------------|------------|---|--|-------|
| SVLT | 2011/10/04 | 2011/10/04 | | (49980) Auxiliaries Controls and Instrumentation | |
| SVLT | 10:25 | 10:53 | 21 (1)-FO-1 : Forced Outage - Sudden | | FALSE |
| SVLT | 10:53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 11:33 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 14:17 | 15:04 | 24-MO - Maintenance Outage | (49100) Combustion Turbine | FALSE |
| SVLT | 15:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 13:22 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 13:50 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 14:37 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 11:13 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 11:59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 13:17 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 14:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 17:43 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 18:06 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2011/12/20 7:26 | 17:45 | 21 (1)-FO-1 : Forced Outage - Sudden | (49890) Electrical Distribution System | FALSE |
| SVLT | 17:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 14:49 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 15:41 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 17:46 | 23:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49820) Generator Stator | FALSE |

| | | | | | | |
|----|-------|-------|-------|-------|---|---|
| 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |

2011 Gas Turbine UFOP Calculations - External Causes Included

Hardwoods GT - 2011 Statistics

| State | Y-T-D | |
|--------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0 | |
| 12 | 38.38 | 4.76 |
| 13 | 0 | 0 |
| 14 | 0 | |
| 15 | 8076.52 | 17.99 |
| 16 | 0 | 0 |
| 21 | 28.22 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 18.65 | |
| 25 | 598.23 | |
| 30 | 0 | |
| TOTAL | 8760.0 | 22.8 |
| Number of Forced Outages | | 5 |
| Number of Unit Starts | | 32 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 38.38 |
| State 14+15+16 | 8076.52 |
| State 21+22+23 | 28.22 |
| Number of FO | 5 |
| Number of Starts | 32 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 39 |
| Attempted Starts | 72 |
| r | 5.644 |
| D | 0.5405634 |
| T | 112.16638 |
| Demand Factor | 0.0914013 |
| UFOP | 6.30% |

NLH HWD/SVL Units - External Causes Included

| | |
|--------------------|------------|
| State 11+12+13 | 45.80 |
| State 14+15+16 | 12,953.18 |
| State 21+22+23 | 217.34 |
| Number of FO | 12.00 |
| Number of Starts | 52 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 63 |
| Attempted Starts | 116 |
| r | 18.1116667 |
| D | 0.39826087 |
| T | 111.661912 |
| Demand Factor | 0.02491903 |
| UFOP | 10.57% |

2011 Gas Turbine UFOP Calculations - External Causes Included

Stephenville GT - 2011 Statistics

| State | Y-T-D | |
|--------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0.00 | |
| 12 | 13.03 | 7.42 |
| 13 | 0.00 | 0 |
| 14 | 94.57 | |
| 15 | 8329.93 | 4782.09 |
| 16 | 0.00 | 0 |
| 21 | 189.12 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 37.43 | |
| 25 | 95.92 | |
| 30 | 0.00 | |
| TOTAL | 8760.00 | 4789.51 |
| Number of Forced Outages | | 7 |
| Number of Unit Starts | | 20 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 7.42 |
| State 14+15+16 | 4876.66 |
| State 21+22+23 | 189.12 |
| Number of FO | 7 |
| Number of Starts | 20 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 24 |
| Attempted Starts | 44 |
| r | 27.017143 |
| D | 0.1686364 |
| T | 110.83318 |
| Demand Factor | 0.0077036 |
| UFOP | 16.41% |

2011 Gas Turbine UFOP Calculations - External Causes Excluded

Hardwoods GT - 2011 Statistics

| State | Y-T-D | |
|--------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | | 0 |
| 12 | 38.38 | 4.76 |
| 13 | 0 | 0 |
| 14 | 0 | |
| 15 | 8076.52 | 17.99 |
| 16 | 0 | 0 |
| 21 | 28.22 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 18.65 | |
| 25 | 598.23 | |
| 30 | 0 | |
| TOTAL | 8760.00 | 22.75 |
| Number of Forced Outages | | 5 |
| Number of Unit Starts | | 32 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 38.38 |
| State 14+15+16 | 8076.52 |
| State 21+22+23 | 28.22 |
| Number of FO | 5 |
| Number of Starts | 32 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 39 |
| Attempted Starts | 72 |
| r | 5.644 |
| D | 0.5405634 |
| T | 112.16638 |
| Demand Factor | 0.0914013 |
| UFOP | 6.30% |

NLH HWD/SVL Units - External Causes Excluded

| | |
|--------------------|-----------|
| State 11+12+13 | 51.41 |
| State 14+15+16 | 16,501.02 |
| State 21+22+23 | 217.34 |
| Number of FO | 12.00 |
| Number of Starts | 52 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 63 |
| Attempted Starts | 116 |
| r | 18.111667 |
| D | 0.4470435 |
| T | 142.24632 |
| Demand Factor | 0.0270721 |
| UFOP | 10.27% |

2011 Gas Turbine UFOP Calculations - External Causes Excluded

Stephenville GT - 2011 Statistics

| State | Y-T-D | |
|--------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0.00 | |
| 12 | 13.03 | 7.42 |
| 13 | 0.00 | 0 |
| 14 | 94.57 | |
| 15 | 8329.93 | 4782.09 |
| 16 | 0.00 | 0 |
| 21 | 189.12 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 37.43 | |
| 25 | 65.40 | |
| 30 | 0.00 | |
| TOTAL | 8729.48 | 4789.51 |
| Number of Forced Outages | | 7 |
| Number of Unit Starts | | 20 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 13.03 |
| State 14+15+16 | 8424.50 |
| State 21+22+23 | 189.12 |
| Number of FO | 7 |
| Number of Starts | 20 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 24 |
| Attempted Starts | 44 |
| r | 27.017143 |
| D | 0.2961364 |
| T | 191.46591 |
| Demand Factor | 0.0123532 |
| UFOP | 15.20% |

[illegible]

| | | | | | | | | | | | |
|------|-----------------|---|------------------------------------|------|----|-------|------|-------|-------|---|---|
| HWDT | 16:24 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:44 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:57 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:14 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:07 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:22 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:39 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:18 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:19 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 12:24 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:27 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:30 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:05 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:14 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/01/11 8:42 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:22 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:48 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:26 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 14:57 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:23 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:30 | 21 (1)-FO-1 : Forced Outage - Sudden | (49210) Compressor | TRUE | 21 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:39 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:34 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:55 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | TRUE | 21 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:39 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 15:05 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:11 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:49 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 21:17 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | TRUE | 21 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/06/05 3:18 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/06/05 3:32 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/06/05 3:37 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/06/05 4:07 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/06/05 4:10 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/06/05 7:11 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 14:24 | 16-47 PD - Planned Outage | (49243) Clutch | TRUE | 25 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| HWDT | 16:47 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:54 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:06 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 23:01 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:07 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 21:24 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/06/29 9:00 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/06/29 9:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/06/29 9:47 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:04 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:03 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:41 | 21 (1)-FO-1 : Forced Outage - Sudden | (49811) Generator Bearings | TRUE | 21 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:50 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:28 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:24 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 14:08 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 21:48 | 21 (1)-FO-1 : Forced Outage - Sudden | (49325) Building Fire Protection | TRUE | 21 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 12:51 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 12:09 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:44 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 21:45 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:31 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 14:56 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/08/30 9:43 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 21:06 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:29 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:29 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:49 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 12:41 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/09/1 9:45 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:46 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/09/1 18:54 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:18 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:04 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | TRUE | 21 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 12:58 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:57 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 26:29 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:47 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:39 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:56 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:08 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:17 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 19:10 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:11 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:31 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/10/31 8:46 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/10/31 9:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/10/31 9:48 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:03 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:14 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:25 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:01 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 15:17 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

PUB-NLH-636, Attachment 2
Page 3 of 6, Isl Int System Power Outages (Phase Two)

| | | | | | |
|------|-----------------|-------|---|----------------------------|------|
| HWDT | 12:27 | 13:35 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | TRUE |
| HWDT | 13:35 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 15:06 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 15:54 | 17:22 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | TRUE |
| HWDT | 17:22 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 2012/11/27 6:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 17:54 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 21:49 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 23:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 14:35 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 15:49 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| HWDT | 16:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |

| | | | | | | |
|----|-------|------|-------|-------|---|---|
| 21 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 21 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 12 | TRUE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |

| Unit | Start_Date | Finish_Date | State Code | Outage Code | SynchCondense |
|------|-----------------|-------------|--------------------------------------|--------------------------|---------------|
| SVLT | 2012/01/01 0:01 | 23:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49820) Generator Stator | FALSE |

| State | Operating? | Synch Cond? | Prev Stat Operating? | Prev Stat Already S.C.? | Trans to SC? | Starting Failure? | |
|-------|------------|-------------|-------------------------|-------------------------------|--------------|--------------------------------------|--|
| 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| | | | | | 0 | Number of transitions to S.C. | 0 |
| | | | | | 0 | Number of starting failures | 0 |
| | | | | | 0 | | |
| | | | | | 0 | | |
| | | | | | 0 | Starting Failure Code | 21 (4)-FO-4 : Forced Outage - Starting Failure |
| | | | | | 0 | | |

2012 Gas Turbine UFOP Calculations - External Causes Included

Hardwoods GT - 2012 Statistics

| State | Y-T-D | |
|--------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0 | |
| 12 | 103.3 | 19.22 |
| 13 | 0 | 0 |
| 14 | 0 | |
| 15 | 8155.93 | 1198.13 |
| 16 | 0 | 0 |
| 21 | 473.55 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 0 | |
| 25 | 51.22 | |
| 30 | 0 | |
| TOTAL | 8784.0 | 1217.4 |
| Number of Forced Outages | | 13 |
| Number of Unit Starts | | 70 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 19.22 |
| State 14+15+16 | 1198.13 |
| State 21+22+23 | 473.55 |
| Number of FO | 13 |
| Number of Starts | 70 |
| No. of Start Fail. | 2 |
| No. trans. to SC | 100 |
| Attempted Starts | 172 |
| r | 36.426923 |
| D | 0.1130588 |
| T | 6.9645575 |
| Demand Factor | 0.0189703 |
| UFOP | 31.85% |

NLH HWD/SVL Units - External Causes Included

| | |
|--------------------|------------|
| State 11+12+13 | 19.22 |
| State 14+15+16 | 1,198.13 |
| State 21+22+23 | 9,257.55 |
| Number of FO | 14.00 |
| Number of Starts | 70 |
| No. of Start Fail. | 2 |
| No. trans. to SC | 100 |
| Attempted Starts | 172 |
| r | 661.253571 |
| D | 0.11305882 |
| T | 6.96455746 |
| Demand Factor | 0.01613967 |
| UFOP | 88.60% |

2012 Gas Turbine UFOP Calculations - External Causes Included

Stephenville GT - 2012 Statistics

| State | Y-T-D | |
|--------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0.00 | |
| 12 | 0.00 | 0 |
| 13 | 0.00 | 0 |
| 14 | 0.00 | |
| 15 | 0.00 | 0 |
| 16 | 0.00 | 0 |
| 21 | 8784.00 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 0.00 | |
| 25 | 0.00 | |
| 30 | 0.00 | |
| TOTAL | 8784.00 | 0.00 |
| Number of Forced Outages | | 1 |
| Number of Unit Starts | | 0 |

Calculations

| | |
|--------------------|---------|
| State 11+12+13 | 0 |
| State 14+15+16 | 0 |
| State 21+22+23 | 8784 |
| Number of FO | 1 |
| Number of Starts | 0 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 0 |
| Attempted Starts | 0 |
| r | 8784 |
| D | #DIV/0! |
| T | #DIV/0! |
| Demand Factor | #DIV/0! |
| UFOP | #DIV/0! |

2012 Gas Turbine UFOP Calculations - External Causes Excluded

Hardwoods GT - 2012 Statistics

| State | Y-T-D | |
|---------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0 | |
| 12 | 103.3 | 19.22 |
| 13 | 0 | 0 |
| 14 | 0 | |
| 15 | 8155.93 | 1198.13 |
| 16 | 0 | 0 |
| 21 | 473.55 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 0 | |
| 25 | 51.22 | |
| 30 | 0 | |
| TOTAL | 8784.00 | 1217.35 |
| Number of Forced Outages: | | 13 |
| Number of Unit Starts | | 70 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 103.3 |
| State 14+15+16 | 8155.93 |
| State 21+22+23 | 473.55 |
| Number of FO | 13 |
| Number of Starts | 70 |
| No. of Start Fail. | 2 |
| No. trans. to SC | 17 |
| Attempted Starts | 89 |
| r | 36.426923 |
| D | 1.1873563 |
| T | 91.612981 |
| Demand Factor | 0.0435712 |
| UFOP | 16.65% |

NLH HWD/SVL Units - External Causes Excluded

| | |
|--------------------|-----------|
| State 11+12+13 | 103.30 |
| State 14+15+16 | 8,155.93 |
| State 21+22+23 | 9,257.55 |
| Number of FO | 14.00 |
| Number of Starts | 70 |
| No. of Start Fail. | 2 |
| No. trans. to SC | 17 |
| Attempted Starts | 89 |
| r | 661.25357 |
| D | 1.1873563 |
| T | 91.612981 |
| Demand Factor | 0.0145416 |
| UFOP | 56.58% |

2012 Gas Turbine UFOP Calculations - External Causes Excluded

Stephenville GT - 2012 Statistics

| State | Y-T-D | |
|---------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0.00 | |
| 12 | 0.00 | 0 |
| 13 | 0.00 | 0 |
| 14 | 0.00 | |
| 15 | 0.00 | 0 |
| 16 | 0.00 | 0 |
| 21 | 8784.00 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 0.00 | |
| 25 | 0.00 | |
| 30 | 0.00 | |
| TOTAL | 8784.00 | 0.00 |
| Number of Forced Outages: | | 1 |
| Number of Unit Starts | | 0 |

Calculations

| | |
|--------------------|---------|
| State 11+12+13 | 0 |
| State 14+15+16 | 0 |
| State 21+22+23 | 8784 |
| Number of FO | 1 |
| Number of Starts | 0 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 0 |
| Attempted Starts | 0 |
| r | 8784 |
| D | #DIV/0! |
| T | #DIV/0! |
| Demand Factor | #DIV/0! |
| UFOP | #DIV/0! |

PUB-NLH-636, Attachment 3
Page 1 of 4, Isl Int System Power Outages (Phase Two)

| Unit | Start Date | Finish Date | State Code | Outage Code | SynchCondense |
|------|------------------|-----------------|---|--------------------------------------|---------------|
| SVLT | 2013/01/01 0:01 | 10:00 | 21 (1)-FO-1 : Forced Outage - Sudden | (49820) Generator Sator | FALSE |
| SVLT | 10:00 | 16:54 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 16:54 | 10:00 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE |
| SVLT | 10:00 | 12:18 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 12:18 | 2013/06/01 8:51 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE |
| SVLT | 2013/06/01 8:51 | | 11-O : Operating | | FALSE |
| SVLT | 11:33 | 12:09 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE |
| SVLT | 12:09 | | 11-O : Operating | | FALSE |
| SVLT | 14:40 | | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 14:41 | 15:49 | 24-MO : Maintenance Outage | (49313) Supercharging Fan | FALSE |
| SVLT | 15:49 | | 11-O : Operating | | FALSE |
| SVLT | 16:02 | 12:00 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 12:01 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 13:36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 13:37 | 11:32 | 24-MO : Maintenance Outage | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 11:32 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 14:02 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 14:03 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 12:00 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 12:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 15:32 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 17:19 | 14:28 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 14:28 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 13:18 | 15:55 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE |
| SVLT | 15:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 10:11 | | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 15:43 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2013/07/19 7:11 | 2013/07/20 2:57 | 25-PO : Planned Outage | (99999) Other | FALSE |
| SVLT | 2013/07/20 2:57 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2013/07/25 9:25 | 14:45 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE |
| SVLT | 14:45 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 14:41 | 15:41 | 24-MO : Maintenance Outage | (49317) Lubrication System | FALSE |
| SVLT | 15:41 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 13:21 | | 11-O : Operating | | FALSE |
| SVLT | 15:01 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 10:07 | | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 10:42 | | 11-O : Operating | | FALSE |
| SVLT | 11:38 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 12:37 | | 11-O : Operating | | FALSE |
| SVLT | 13:00 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2013/10/24 9:36 | | 11-O : Operating | | FALSE |
| SVLT | 11:01 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 12:57 | 21:23 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE |
| SVLT | 21:23 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2013/11/14 9:15 | | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 10:24 | | 11-O : Operating | | FALSE |
| SVLT | 2013/11/14 12:10 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 13:52 | 20:21 | 25-PO : Planned Outage | (49812) Generator Lubrication System | FALSE |
| SVLT | 20:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 11:30 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 12:20 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 16:44 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 22:35 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 22:20 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 21:29 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 13:47 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |

| State | Operating? | Synch Cond' | Prev Stat Already | Prev Stat Operating? | S.C.? | Trans to SC? | Starting Failure? |
|-------|------------|-------------|----------------------|-------------------------|-------|--------------|-------------------|
| 21 | FALSE | FALSE | TRUE | FALSE | TRUE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 24 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 24 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 24 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| 25 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| 25 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |

PUB-NLH-636, Attachment 3
Page 2 of 4, Isl Int System Power Outages (Phase Two)

| Unit | Start Date | Finish Date | State Code | Outage Code | SynchCondense |
|------|------------------|------------------|--|------------------------------------|---------------|
| HWDT | 17:33 | | 11-O : Operating | | FALSE |
| HWDT | 18:25 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 2013/01/11 7:12 | | 11-O : Operating | | FALSE |
| HWDT | 11:32 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 2013/01/16 0:44 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 14:27 | | 11-O : Operating | | FALSE |
| HWDT | 15:17 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 16:35 | | 11-O : Operating | | FALSE |
| HWDT | 21:04 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 2013/01/17 9:08 | | 11-O : Operating | | FALSE |
| HWDT | 14:26 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 16:10 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 16:36 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 11:50 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 12:54 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 13:44 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 21:31 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 21:47 | | 11-O : Operating | | FALSE |
| HWDT | 22:04 | 22:33 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | TRUE |
| HWDT | 22:33 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 22:47 | | 11-O : Operating | | FALSE |
| HWDT | 15:49 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 17:13 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 18:05 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 2013/01/23 7:26 | | 11-O : Operating | | FALSE |
| HWDT | 2013/01/23 7:32 | 2013/01/23 9:21 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE |
| HWDT | 2013/01/23 9:21 | | 11-O : Operating | | FALSE |
| HWDT | 2013/01/23 9:48 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 16:24 | | 11-O : Operating | | FALSE |
| HWDT | 16:49 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 14:26 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 21:16 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 11:09 | 12:24 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49100) Combustion Turbine | FALSE |
| HWDT | 12:24 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 20:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 2013/04/17 9:11 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 10:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 11:24 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 2013/05/17 6:26 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 2013/05/18 9:05 | 2013/05/25 16:14 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE |
| HWDT | 16:14 | | 11-O : Operating | | FALSE |
| HWDT | 18:01 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 14:37 | | 11-O : Operating | | FALSE |
| HWDT | 15:58 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 2013/07/04 9:01 | 10:48 | 24-MO : Maintenance Outage | (5200) Transmission Limitations | FALSE |
| HWDT | 10:48 | | 14-ABNO : Available but not operating | (49100) Combustion Turbine | FALSE |
| HWDT | 2013/09/13 14:45 | | 11-O : Operating | | FALSE |
| HWDT | 16:07 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 16:19 | | 11-O : Operating | | FALSE |
| HWDT | 17:39 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 17:40 | | 11-O : Operating | | FALSE |
| HWDT | 18:47 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 14:12 | | 11-O : Operating | | FALSE |
| HWDT | 15:36 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 15:52 | | 11-O : Operating | | FALSE |
| HWDT | 17:09 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 17:39 | | 11-O : Operating | | FALSE |
| HWDT | 19:14 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 13:34 | | 11-O : Operating | | FALSE |
| HWDT | 14:53 | | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 2013/10/04 0:00 | 12:34 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE |
| HWDT | 12:34 | | 11-O : Operating | | FALSE |
| HWDT | 12:49 | 13:30 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE |
| HWDT | 13:30 | | 11-O : Operating | | FALSE |
| HWDT | 15:04 | 2013/12/19 8:32 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE |
| HWDT | 2013/12/19 8:32 | | 11-O : Operating | | FALSE |
| HWDT | 15:41 | | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 15:42 | 23:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE |

| State | Operating? | Synch Cond? | Prev Stat Already | Prev Stat Operating? | S.C.? | Trans to SC? Starting Failure? |
|-------|------------|-------------|----------------------|-------------------------|-------|--------------------------------|
| 11 | TRUE | FALSE | TRUE | TRUE | FALSE | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 21 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 16 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 24 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 |
| 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 |

2013 Gas Turbine UFOP Calculations - External Causes Included

Hardwoods GT - 2013 Statistics

| State | Y-T-D | |
|--------------------------|---------|-------------|
| Code | Hours | Adj . Hours |
| 11 | 55.6 | |
| 12 | 25.38 | 8.19 |
| 13 | 0 | 0 |
| 14 | 3949.92 | |
| 15 | 2397.6 | 479.52 |
| 16 | 175.15 | 87.58 |
| 21 | 299.85 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 1856.5 | |
| 25 | 0 | |
| 30 | 0 | |
| TOTAL | 8760.0 | 575.3 |
| Number of Forced Outages | | 4 |
| Number of Unit Starts | | 28 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 80.98 |
| State 14+15+16 | 6522.67 |
| State 21+22+23 | 299.85 |
| Number of FO | 4 |
| Number of Starts | 28 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 3 |
| Attempted Starts | 32 |
| r | 74.9625 |
| D | 2.6122581 |
| T | 203.7518 |
| Demand Factor | 0.0454994 |
| UFOP | 14.42% |

NLH HWD/SVL Units - External Causes Included

| | |
|--------------------|------------|
| State 11+12+13 | 146.61 |
| State 14+15+16 | 10,956.97 |
| State 21+22+23 | 3,962.63 |
| Number of FO | 9.00 |
| Number of Starts | 45 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 12 |
| Attempted Starts | 58 |
| r | 440.292222 |
| D | 2.57210526 |
| T | 188.868929 |
| Demand Factor | 0.01908881 |
| UFOP | 34.03% |

2013 Gas Turbine UFOP Calculations - External Causes Included

Stephenville GT - 2013 Statistics

| State | Y-T-D | |
|--------------------------|---------|-------------|
| Code | Hours | Adj . Hours |
| 11 | 11.60 | |
| 12 | 54.03 | 26.6 |
| 13 | 0.00 | 0 |
| 14 | 3443.00 | |
| 15 | 991.30 | 488.04 |
| 16 | 0.00 | 0 |
| 21 | 3662.78 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 283.03 | |
| 25 | 314.25 | |
| 30 | 0.00 | |
| TOTAL | 8759.99 | 514.64 |
| Number of Forced Outages | | 5 |
| Number of Unit Starts | | 17 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 65.63 |
| State 14+15+16 | 4434.30 |
| State 21+22+23 | 3662.78 |
| Number of FO | 5 |
| Number of Starts | 17 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 9 |
| Attempted Starts | 26 |
| r | 732.556 |
| D | 2.5242308 |
| T | 170.55 |
| Demand Factor | 0.0179194 |
| UFOP | 50.00% |

2013 Gas Turbine UFOP Calculations - External Causes Excluded

Hardwoods GT - 2013 Statistics

| State | Y-T-D | |
|-----------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 55.6 | |
| 12 | 25.38 | 8.19 |
| 13 | 0 | 0 |
| 14 | 3949.92 | |
| 15 | 2397.6 | 479.52 |
| 16 | 175.15 | 87.58 |
| 21 | 299.85 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 1830.72 | |
| 25 | 0 | |
| 30 | 0 | |
| TOTAL | 8734.22 | 575.29 |
| Number of Forced Outages: 4 | | |
| Number of Unit Starts 28 | | |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 80.98 |
| State 14+15+16 | 6522.67 |
| State 21+22+23 | 299.85 |
| Number of FO | 4 |
| Number of Starts | 28 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 3 |
| Attempted Starts | 32 |
| r | 74.9625 |
| D | 2.6122581 |
| T | 203.7518 |
| Demand Factor | 0.0454994 |
| UFOP | 14.42% |

NLH HWD/SVL Units - External Causes Excluded

| | |
|--------------------|-----------|
| State 11+12+13 | 146.61 |
| State 14+15+16 | 10,956.97 |
| State 21+22+23 | 3,962.63 |
| Number of FO | 9.00 |
| Number of Starts | 45 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 12 |
| Attempted Starts | 58 |
| r | 440.29222 |
| D | 2.5721053 |
| T | 188.86893 |
| Demand Factor | 0.0190888 |
| UFOP | 34.03% |

2013 Gas Turbine UFOP Calculations - External Causes Excluded

Stephenville GT - 2013 Statistics

| State | Y-T-D | |
|-----------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 11.60 | |
| 12 | 54.03 | 26.6 |
| 13 | 0.00 | 0 |
| 14 | 3443.00 | |
| 15 | 991.30 | 488.04 |
| 16 | 0.00 | 0 |
| 21 | 3662.78 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 283.03 | |
| 25 | 294.48 | |
| 30 | 0.00 | |
| TOTAL | 8740.22 | 514.64 |
| Number of Forced Outages: 5 | | |
| Number of Unit Starts 17 | | |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 65.63 |
| State 14+15+16 | 4434.30 |
| State 21+22+23 | 3662.78 |
| Number of FO | 5 |
| Number of Starts | 17 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 9 |
| Attempted Starts | 26 |
| r | 732.556 |
| D | 2.5242308 |
| T | 170.55 |
| Demand Factor | 0.0179194 |
| UFOP | 50.00% |

| Unit | Start_Date | Finish_Date | State Code | Outage Code | SynchCondense | State | Operating? | Synch Cond' | Prev Stat Already | Prev Stat S.C.? | Trans to SC? | Starting Failure? |
|------|-----------------|-----------------|---|--|---------------|-------|------------|-------------|----------------------|--------------------|--------------|-------------------|
| HWDT | 2014/01/01 0:01 | 19:39 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:39 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/01/09 9:36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49810) Generator Rotor | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:09 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/01/11 9:04 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:17 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:04 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:35 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:59 | 21:52 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 21:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/01/12 9:38 | 13:47 | 24-MO : Maintenance Outage | (49980) Auxiliaries Controls and Instrumentation | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:00 | 18:58 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:48 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:07 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:15 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:21 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 22:31 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/01/22 8:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:25 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:26 | 13:57 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:57 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:01 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:12 | 15:06 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:06 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:09 | | 14-ABNO : Available but not operating | | TRUE | 14 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:19 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:20 | 15:52 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:52 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:55 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:01 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:02 | 16:50 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/01/23 7:03 | 2014/01/23 8:55 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/01/23 8:55 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:33 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:23 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:06 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:40 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:04 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:10 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/02/04 6:35 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/04 7:08 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:20 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:24 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:54 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:51 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:08 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:46 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/02/07 9:17 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:35 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 14:28 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:53 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 12:11 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/10 4:05 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/13 8:36 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:33 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:27 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:47 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:20 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:54 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:55 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/02/18 2:35 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:17 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:54 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:51 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/03/01 9:39 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:50 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:44 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:32 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:39 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:10 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/03/04 5:21 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |

| | | | | | | | | | | | | |
|------|-----------------|-----------------|---|--|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 10:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:30 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:05 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:36 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/05 9:02 | 13:00 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 22:48 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/03/06 4:45 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:14 | 2014/03/07 8:10 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:42 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/03/10 4:39 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/10 9:47 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/03/11 6:37 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:12 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/03/18 7:15 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/18 9:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:07 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:17 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/03/19 5:34 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/19 9:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:22 | 10:43 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | TRUE | 21 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:43 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:18 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:50 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:31 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:19 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:49 | | 11-O : Operating | | FALSE | 11 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:01 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/04/09 7:06 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:51 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:32 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:07 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 20:50 | 21:52 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 15:28 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:58 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 21:30 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 21:34 | 23:14 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/05/07 7:41 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/05/07 9:55 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/05/07 9:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:30 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/05/08 7:41 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/05/08 9:55 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/05/12 5:53 | | 11-O : Operating | | FALSE | 11 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/05/12 7:48 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/05/12 8:33 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| HWDT | 2014/06/01 6:46 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:14 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:15 | 13:18 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49270) Starting System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 12:53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:46 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:01 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:02 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:33 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:10 | 2014/06/21 8:24 | 25-PO : Planned Outage | (49312) Heat Shields | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/06/21 8:24 | 11:00 | 25-PO : Planned Outage | (49312) Heat Shields | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:00 | 18:45 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49312) Heat Shields | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:45 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:17 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:05 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:45 | 19:16 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49312) Heat Shields | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:16 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:07 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:33 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:52 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:26 | | 11-O : Operating | | FALSE | 11 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:04 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:59 | 19:10 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:32 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/07/05 7:52 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:09 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:28 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:37 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:34 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:13 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/07/25 3:47 | 11:54 | 21 (1)-FO-1 : Forced Outage - Sudden | (49890) Electrical Distribution System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:54 | | 11-O : Operating | | FALSE | 11 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:39 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:53 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:42 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:58 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:03 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/09/26 6:58 | 15:53 | 24-MO : Maintenance Outage | (49314) Fuel Supply System to Unit | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:53 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |

| | | | | | | | | | | | | |
|------|-----------------|-----------------|---|------------------------------------|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 15:08 | 15:27 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/10/02 7:41 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/10/02 8:57 | | 14-ABNO : Available but not operating | | TRUE | 14 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:24 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:24 | 2014/10/18 7:16 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49270) Starting System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 2014/10/18 7:16 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:42 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:19 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 12:53 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:22 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:24 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:45 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:28 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/11/17 7:29 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/11/17 8:11 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:07 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:54 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:09 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:06 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:45 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:22 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:59 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:25 | 10:52 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 10:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:41 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 23:57 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/12/09 4:42 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/12/09 8:57 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:09 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:11 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:09 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:11 | 15:10 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:03 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:31 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:48 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:16 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:26 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:12 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:10 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/12/31 6:19 | 2014/12/31 7:10 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49270) Starting System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 2014/12/31 7:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:36 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

| Unit | Start_Date | Finish_Date | State Code | Outage Code | Synch | Condense | State | Operating? | Synch Cond? | Prev Stat Already | Prev Stat S.C.? | Trans to SC? | Starting Failure? |
|------|-----------------|-----------------|---|--|-------|----------|-------|------------|-------------|----------------------|--------------------|--------------|-------------------|
| SVLT | 21-32 | 21-33 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | TRUE | 0 | 0 |
| SVLT | 21-33 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/01/04 2:14 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| | | | | (5203) Transmission equipment beyond the transmission line | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/04 9:05 | 2014/01/04 9:57 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/04 9:57 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14-10 | 14-28 | 21 (1)-FO-1 : Forced Outage - Sudden | (49810) Generator Rotor | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 14-28 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| | 2014/01/04 | 2014/01/04 | | (5203) Transmission equipment beyond the transmission line | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 15-33 | 15-36 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 15-56 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 19:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/05 0:03 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| | 2014/01/05 | | | (5203) Transmission equipment beyond the transmission line | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 21-27 | 21-48 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 21-48 | 22:06 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 22:06 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 22:10 | 23:14 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 23:14 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 23-43 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/07 9:26 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/07 9:33 | 11:29 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 11-29 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12-35 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/08 8:25 | 13:19 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:19 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/11 8:53 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:18 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:56 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:21 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:05 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 12-26 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:23 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:16 | | 11-O : Operating | (49100) Combustion Turbine | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 19:14 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 10-42 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13-37 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/02/04 8:46 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10-59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 11-23 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11-57 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 17-12 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 22:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/02/07 6:14 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10-00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 12-21 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13-25 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/02/10 4:15 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16-19 | 17-04 | 21 (2)-FO-2 : Forced Outage - Immediately Deferable | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| | 2014/02/10 | | | | | | | | | | | | |
| SVLT | 17-04 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21-36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/02/16 6:39 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/02/11 9:45 | 11:53 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 11-53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/02/13 9:37 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 20-04 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21-05 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/02/18 6:05 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/02/18 9:28 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 10-25 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14-45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 17-50 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 19-55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 10-20 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11-46 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 15-55 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17-06 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 10-00 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15-37 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 15-01 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16-15 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 10-00 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11-15 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/04 6:00 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/04 9:26 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 11-57 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12-39 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 15-27 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 22-59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/05 5:32 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 23-43 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/06 6:27 | 2014/03/06 6:54 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/06 6:54 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/06 9:17 | 2014/03/06 9:56 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/06 9:56 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10-23 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |

| | | | | | | | | | | | | |
|------|------------------|------------------|--|--|-------|----|-------|-------|-------|-------|---|---|
| SVLT | 15:33 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:45 | 16:18 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 16:18 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/07 5:51 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/07 9:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/03/10 5:54 | 10:09 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:09 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/03/11 7:10 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:09 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/03/19 5:37 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/03/19 9:07 | 15:36 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/03/25 9:24 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:06 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 16:26 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:56 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 20:55 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:06 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 21:17 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:19 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:44 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:33 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 14:39 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:30 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 16:56 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:33 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/05/07 8:23 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/05/07 9:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/05/16 10:53 | 2014/05/16 14:44 | 21 (1)-FO-1 : Forced Outage - Sudden | (49311) Internal Cooling and Seal Air System and Seals | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:44 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/05/28 8:58 | 13:50 | 25-PO : Planned Outage | (49325) Building Fire Protection | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:50 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/06/06 9:52 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/06/06 14:00 | 2014/06/09 11:00 | 21 (1)-FO-1 : Forced Outage - Sudden | (49980) Auxiliaries Controls and Instrumentation | TRUE | 21 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 11:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:30 | | 12-O (FD) : Operating under Forced Derated | (49293) Exhaust Stack and Silencer | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:48 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/06/11 8:47 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:44 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:48 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:38 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:55 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:13 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/08/06 9:20 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/08/06 9:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/08/12 9:08 | 18:14 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:14 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 13:12 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:30 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/09/18 8:09 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:15 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:00 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/02 11:18 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/10/04 8:26 | 10:00 | 25-PO : Planned Outage | (49100) Combustion Turbine | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:00 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/21 11:24 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:25 | | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:38 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/22 12:41 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:42 | 14:53 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:54 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/22 21:12 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 21:13 | | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/23 8:12 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/23 15:46 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:51 | 15:23 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:23 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 15:24 | 18:04 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:04 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:51 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 18:52 | 10:00 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:00 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:25 | 2014/11/20 9:21 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:48 | 20:30 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:01 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |

PUB-NLH-636, Attachment 4
Page 6 of 8, Isl Int System Power Outages (Phase Two)

| | | | | |
|------|-----------------|---|------------------------------------|-------|
| SVLT | 11:14 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 11:44 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 14:12 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 15:19 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 17:55 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 17:56 | 17:00 24-MO : Maintenance Outage | (99999) Other | FALSE |
| SVLT | 17:00 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 20:00 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2014/11/30 6:41 | 14:56 24-MO : Maintenance Outage | (49100) Combustion Turbine | TRUE |
| SVLT | 14:56 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 17:06 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 17:10 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 17:40 | 19:34 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 19:34 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 2014/12/09 4:13 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 2014/12/09 8:56 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 17:48 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 18:53 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 16:40 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 16:58 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 12:58 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 14:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 10:27 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 11:52 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 10:07 | 13:36 24-MO : Maintenance Outage | (49243) Clutch | FALSE |
| SVLT | 13:36 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 13:41 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |
| SVLT | 2014/12/31 9:36 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 11:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 17:05 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE |
| SVLT | 19:16 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE |

| | | | | | | |
|----|-------|-------|-------|-------|---|---|
| 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 24 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

2014 Gas Turbine UFOP Calculations - External Causes Included

Hardwoods GT - 2014 Statistics

| State | Y-T-D | |
|--------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 212.68 | |
| 12 | 142.07 | 67.6 |
| 13 | 0 | 0 |
| 14 | 4951.22 | |
| 15 | 1196.38 | 418.77 |
| 16 | 0 | 0 |
| 21 | 2220.88 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 14.93 | |
| 25 | 21.83 | |
| 30 | 0 | |
| TOTAL | 8760.0 | 486.4 |
| Number of Forced Outages | | 17 |
| Number of Unit Starts | | 88 |

| Calculations | |
|--------------------|-----------|
| State 11+12+13 | 280.28 |
| State 14+15+16 | 5369.99 |
| State 21+22+23 | 2220.88 |
| Number of FO | 17 |
| Number of Starts | 88 |
| No. of Start Fail. | 4 |
| No. trans. to SC | 18 |
| Attempted Starts | 110 |
| r | 130.64 |
| D | 2.6441509 |
| T | 48.818091 |
| Demand Factor | 0.0692508 |
| UFOP | 35.43% |

NLH HWD/SVL Units - External Causes Included

| | |
|--------------------|------------|
| State 11+12+13 | 449.40 |
| State 14+15+16 | 7,429.42 |
| State 21+22+23 | 2,530.75 |
| Number of FO | 35.00 |
| Number of Starts | 170 |
| No. of Start Fail. | 4 |
| No. trans. to SC | 30 |
| Attempted Starts | 204 |
| r | 72.3071429 |
| D | 2.247 |
| T | 36.42 |
| Demand Factor | 0.08489837 |
| UFOP | 32.35% |

2014 Gas Turbine UFOP Calculations - External Causes Included

Stephenville GT - 2014 Statistics

| State | Y-T-D | |
|--------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0.97 | |
| 12 | 362.20 | 156.88 |
| 13 | 17.62 | 11.27 |
| 14 | 0.00 | |
| 15 | 6617.15 | 2030.46 |
| 16 | 45.27 | 28.97 |
| 21 | 309.87 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 772.43 | |
| 25 | 634.50 | |
| 30 | 0.00 | |
| TOTAL | 8760.01 | 2227.58 |
| Number of Forced Outages | | 18 |
| Number of Unit Starts | | 82 |

| Calculations | |
|--------------------|-----------|
| State 11+12+13 | 169.12 |
| State 14+15+16 | 2059.43 |
| State 21+22+23 | 309.87 |
| Number of FO | 18 |
| Number of Starts | 82 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 12 |
| Attempted Starts | 94 |
| r | 17.215 |
| D | 1.7991489 |
| T | 21.90883 |
| Demand Factor | 0.1572776 |
| UFOP | 22.37% |

2014 Gas Turbine UFOP Calculations - External Causes Excluded

Hardwoods GT - 2014 Statistics

| State | Y-T-D | |
|---------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 212.68 | |
| 12 | 142.07 | 67.6 |
| 13 | 0 | 0 |
| 14 | 4951.22 | |
| 15 | 1196.38 | 418.77 |
| 16 | 0 | 0 |
| 21 | 724.77 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 14.93 | |
| 25 | 21.83 | |
| 30 | 0 | |
| TOTAL | 7263.88 | 486.37 |
| Number of Forced Outages: | | 16 |
| Number of Unit Starts | | 88 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 354.75 |
| State 14+15+16 | 6147.6 |
| State 21+22+23 | 724.77 |
| Number of FO | 16 |
| Number of Starts | 88 |
| No. of Start Fail. | 4 |
| No. trans. to SC | 18 |
| Attempted Starts | 110 |
| r | 45.298125 |
| D | 3.3466981 |
| T | 55.887273 |
| Demand Factor | 0.1179827 |
| UFOP | 19.42% |

NLH HWD/SVL Units - External Causes Excluded

| | |
|--------------------|-----------|
| State 11+12+13 | 735.54 |
| State 14+15+16 | 12,810.02 |
| State 21+22+23 | 1,009.04 |
| Number of FO | 31.00 |
| Number of Starts | 170 |
| No. of Start Fail. | 4 |
| No. trans. to SC | 30 |
| Attempted Starts | 204 |
| r | 32.549677 |
| D | 3.6777 |
| T | 62.79 |
| Demand Factor | 0.1464334 |
| UFOP | 16.73% |

2014 Gas Turbine UFOP Calculations - External Causes Excluded

Stephenville GT - 2014 Statistics

| State | Y-T-D | |
|---------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 0.97 | |
| 12 | 362.20 | 156.88 |
| 13 | 17.62 | 11.27 |
| 14 | 0.00 | |
| 15 | 6617.15 | 2030.46 |
| 16 | 45.27 | 28.97 |
| 21 | 284.27 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 267.32 | |
| 25 | 414.43 | |
| 30 | 0.00 | |
| TOTAL | 8009.23 | 2227.58 |
| Number of Forced Outages: | | 15 |
| Number of Unit Starts | | 82 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 380.79 |
| State 14+15+16 | 6662.42 |
| State 21+22+23 | 284.27 |
| Number of FO | 15 |
| Number of Starts | 82 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 12 |
| Attempted Starts | 94 |
| r | 18.951333 |
| D | 4.0509574 |
| T | 70.876809 |
| Demand Factor | 0.2131627 |
| UFOP | 13.73% |

PUB-NLH-636, Attachment 5

Page 1 of 9, Isl Int System Power Outages (Phase Two)

| Unit | Start Date | Finish Date | State Code | Outage Code | Sync/Condenser |
|------|------------------|-----------------|---|--|----------------|
| SVLT | 12:35 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 21:23 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2015/01/06 5:56 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 11:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 16:05 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 20:56 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 16:05 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 16:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 15:44 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 18:49 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2015/01/09 6:05 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 11:22 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2015/01/12 9:34 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 10:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 15:43 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 19:22 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2015/01/14 6:58 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 2015/01/14 9:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 15:57 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 16:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 11:27 | 15:41 | 24-MO : Maintenance Outage | (49243) Clutch | FALSE |
| SVLT | 15:41 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 10:52 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 15:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2015/01/22 9:53 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 12:47 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2015/01/23 11:41 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 12:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 15:26 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 19:10 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 16:21 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 17:44 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE |
| SVLT | 2015/01/21 17:08 | | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 16:59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE |
| SVLT | 10:04 | | 11-O : Operating | | FALSE |
| SVLT | 10:05 | 10:21 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE |
| SVLT | 10:21 | | 11-O : Operating | | FALSE |
| SVLT | 17:54 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/02/09 8:41 | | 11-O : Operating | | FALSE |
| SVLT | 12:31 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 16:07 | | 11-O : Operating | | FALSE |
| SVLT | 21:43 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/02/10 6:58 | | 11-O : Operating | | FALSE |
| SVLT | 12:46 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/02/11 8:47 | | 11-O : Operating | | FALSE |
| SVLT | 16:24 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 12:05 | | 11-O : Operating | | FALSE |
| SVLT | 14:28 | | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 11:24 | | 11-O : Operating | | FALSE |
| SVLT | 17:04 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/02/20 8:55 | 16:20 | 25-PO : Planned Outage | (49243) Clutch | FALSE |
| SVLT | 16:20 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 16:07 | | 11-O : Operating | | FALSE |
| SVLT | 20:12 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/02/25 6:49 | | 11-O : Operating | | FALSE |
| SVLT | 12:55 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/02/26 6:05 | | 11-O : Operating | | FALSE |
| SVLT | 2015/02/28 9:15 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 16:59 | | 11-O : Operating | | FALSE |
| SVLT | 20:09 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/03/01 6:07 | | 11-O : Operating | | FALSE |
| SVLT | 2015/03/01 9:24 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 18:40 | | 11-O : Operating | | FALSE |
| SVLT | 21:28 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/03/02 5:58 | | 11-O : Operating | | FALSE |
| SVLT | 10:35 | | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 18:45 | | 11-O : Operating | | FALSE |
| SVLT | 21:41 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/03/04 6:11 | | 11-O : Operating | | FALSE |
| SVLT | 2015/03/04 7:15 | 2015/03/04 7:40 | 21 (1)-FO-1 : Forced Outage - Sudden | (5209) Transmission equipment beyond the transmission line | FALSE |
| SVLT | 2015/03/04 7:40 | | 11-O : Operating | | FALSE |
| SVLT | 13:41 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 17:05 | | 11-O : Operating | | FALSE |
| SVLT | 17:59 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 20:16 | | 11-O : Operating | | FALSE |
| SVLT | 20:51 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/03/05 | 2015/03/06 | | (49850) Synchronous Condenser Equipment | FALSE |
| SVLT | 20:14 | 21:31 | 21 (1)-FO-1 : Forced Outage - Sudden | | FALSE |
| SVLT | 21:31 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/03/06 4:45 | | 11-O : Operating | | FALSE |
| SVLT | 2015/03/06 8:08 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/03/06 8:52 | | 11-O : Operating | | FALSE |
| SVLT | 10:09 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/03/07 4:03 | | 11-O : Operating | | FALSE |
| SVLT | 2015/03/07 8:08 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/03/12 6:00 | | 11-O : Operating | | FALSE |

PUB-NLH-636, Attachment 5
Page 2 of 9, Isl Int System Power Outages (Phase Two)

| | | | | | | | | | | | | |
|------|------------------|------------------|--|--|-------|----|-------|-------|-------|-------|---|---|
| SVLT | 2015/03/12 8:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:09 | 12:29 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:29 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 10:55 | 10:34 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:34 | 15:28 | 21 (1)-FO-1 : Forced Outage - Sudden | (49811) Generator Bearings | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:28 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:10 | 2015/05/28 9:41 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/05/28 9:41 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/05/28 9:59 | 2015/05/29 7:50 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/05/29 7:50 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/05/29 8:50 | 17:36 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:36 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 11:15 | 15:35 | 24-MO : Maintenance Outage | (49800) Generator | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:35 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 10:05 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:35 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/06/17 7:20 | 2015/06/17 16:50 | 25-PO : Planned Outage | (5201) Powerhouse substation (non-Generating Unit Equipment) | FALSE | 25 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 16:50 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49800) Generator | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 17:33 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:54 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 19:56 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/06/23 9:31 | 17:00 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | TRUE | 24 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 17:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 10:27 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/07/20 10:28 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/07/20 22:15 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | TRUE | 16 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2015/07/21 9:51 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/07/21 18:25 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | TRUE | 16 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2015/07/22 7:19 | 2015/07/22 17:23 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:23 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2015/07/28 8:58 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/07/28 9:55 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:18 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:19 | 11:28 | 21 (1)-FO-1 : Forced Outage - Sudden | (49811) Generator Bearings | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:42 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:28 | | 12-O (FD) : Operating under Forced Derated | (49811) Generator Bearings | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:25 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49811) Generator Bearings | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/08/12 8:42 | 20:07 | 24-MO : Maintenance Outage | (49325) Building Fire Protection | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:07 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:08 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:12 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:54 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/08/31 9:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:12 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:42 | 16:43 | 25-PO : Planned Outage | (49890) Electrical Distribution System | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:43 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:58 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:29 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:50 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:40 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:15 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 18:35 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:39 | 11:08 | 24-MO : Maintenance Outage | (49900) Controls and Instrumentation | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:08 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:45 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:39 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:50 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 17:01 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:10 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:22 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:29 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:31 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 23:11 | 17:30 | 21 (1)-FO-1 : Forced Outage - Sudden | (49900) Controls and Instrumentation | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:30 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:40 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/11/17 7:40 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:49 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 19:25 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/11/19 7:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:48 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/11/20 7:39 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:13 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/11/21 8:13 | 14:47 | 24-MO : Maintenance Outage | (49321) External Cooling Air System | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:47 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 10:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |

PUB-NLH-636, Attachment 5
Page 3 of 9, Isl Int System Power Outages (Phase Two)

| | | | | | |
|------|-------|-------|---------------------------------------|-------------------|-------|
| SVLT | 14:40 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 10:42 | 12:04 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE |
| SVLT | 12:04 | | 11-O : Operating | | FALSE |
| SVLT | 12:57 | | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 16:22 | | 11-O : Operating | | FALSE |
| SVLT | 17:39 | | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 18:08 | | 11-O : Operating | | FALSE |
| SVLT | 18:24 | | 14-ABNO : Available but not operating | | TRUE |

| | | | | | | |
|----|-------|-------|-------|-------|---|---|
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

[illegible]

[illegible]

PUB-NLH-636, Attachment 5
Page 6 of 9, Isl Int System Power Outages (Phase Two)

| | | | | | | | | | | | | |
|------|------------------|------------------|--|--|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 16:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:06 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:08 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 20:00 | 11:00 | 21 (1)-FO-1 : Forced Outage - Sudden | (49294) Exhaust Hood/Doors | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/10/23 7:52 | 2015/10/23 18:27 | 25-PO : Planned Outage | (5201) Powerhouse substation (non-Generating Unit Equipment) | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2015/11/01 17:36 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/01 18:24 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:29 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/02 10:58 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:47 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/03 11:07 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:32 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49243) Clutch | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:07 | | 12-O (FD) : Operating under Forced Derated | (49243) Clutch | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 23:01 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49243) Clutch | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:27 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/04 13:38 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:12 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/04 18:23 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:00 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/05 18:50 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/11 7:26 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/11 12:01 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:50 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/17 18:26 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:00 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/18 21:57 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/19 8:54 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/19 10:24 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/20 7:23 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/20 9:54 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:29 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/20 17:39 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:23 | 17:31 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:31 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/23 17:36 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/24 5:00 | 15:00 | 24-MO : Maintenance Outage | (49800) Generator | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/24 10:30 | 14:45 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:29 | | 24-MO : Maintenance Outage | (49319) Cooling Water System | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:44 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:44 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:57 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:04 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:23 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:04 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/12/01 7:28 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/12/01 8:18 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/12/02 11:35 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:18 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:30 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:15 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/12/03 9:15 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:39 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:16 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 12:07 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:11 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:55 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:39 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/12/10 7:13 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/12/10 8:21 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:35 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:20 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:35 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:39 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:12 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:05 | | 14-ABNO : Available but not operating | | TRUE | 14 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:15 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

PUB-NLH-636, Attachment 5
Page 7 of 9, Isl Int System Power Outages (Phase Two)

| | | | |
|------|-----------------|---------------------------------------|-------|
| HWDT | 10:40 | 11-O : Operating | FALSE |
| HWDT | 14:49 | 14-ABNO : Available but not operating | TRUE |
| HWDT | 2015/12/29 8:17 | 11-O : Operating | FALSE |
| HWDT | 21:15 | 14-ABNO : Available but not operating | TRUE |
| HWDT | 16:35 | 11-O : Operating | FALSE |
| HWDT | 20:55 | 14-ABNO : Available but not operating | TRUE |
| HWDT | 2015/12/31 6:48 | 11-O : Operating | FALSE |
| HWDT | 11:58 | 14-ABNO : Available but not operating | TRUE |
| HWDT | 18:07 | 11-O : Operating | FALSE |
| HWDT | 20:45 | 14-ABNO : Available but not operating | TRUE |

| | | | | | | |
|----|-------|-------|-------|-------|---|---|
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

2015 Gas Turbine UFOP Calculations - External Causes Included

Hardwoods GT - Statistics

| State Code | Y-T-D Hours | Adj. Hours |
|--------------------------|-------------|------------|
| 11 | 240.65 | |
| 12 | 129.05 | 58.06 |
| 13 | 40.52 | 13.7 |
| 14 | 1970.4 | 0 |
| 15 | 4155.57 | 1491.4 |
| 16 | 545.2 | 144.98 |
| 21 | 51.5 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 67.37 | |
| 25 | 1559.75 | |
| 30 | 0 | |
| TOTAL | 8760.0 | 1708.1 |
| Number of Forced Outages | | 11 |
| Number of Unit Starts | | 107 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 312.41 |
| State 14+15+16 | 3606.78 |
| State 21+22+23 | 51.5 |
| Number of FO | 11 |
| Number of Starts | 107 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 4 |
| Attempted Starts | 112 |
| r | 4.6818182 |
| D | 2.8145045 |
| T | 32.203393 |
| Demand Factor | 0.4077773 |
| UFOP | 6.30% |

NLH HWD/SVL Units - External Causes Included

| | |
|--------------------|------------|
| State 11+12+13 | 504.21 |
| State 14+15+16 | 8,432.54 |
| State 21+22+23 | 703.77 |
| Number of FO | 19.00 |
| Number of Starts | 177 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 19 |
| Attempted Starts | 197 |
| r | 37.0405263 |
| D | 2.5725 |
| T | 42.80 |
| Demand Factor | 0.11469122 |
| UFOP | 13.80% |

2015 Gas Turbine UFOP Calculations - External Causes Included

Stephenville GT - Statistics

| State Code | Y-T-D Hours | Adj. Hours |
|--------------------------|-------------|------------|
| 11 | 147.67 | |
| 12 | 88.45 | 44.13 |
| 13 | 0.00 | 0 |
| 14 | 3978.45 | |
| 15 | 1605.02 | 819.85 |
| 16 | 54.92 | 27.46 |
| 21 | 652.27 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 578.30 | |
| 25 | 1654.93 | |
| 30 | 0.00 | |
| TOTAL | 8760.01 | 891.44 |
| Number of Forced Outages | | 8 |
| Number of Unit Starts | | 70 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 191.8 |
| State 14+15+16 | 4825.76 |
| State 21+22+23 | 652.27 |
| Number of FO | 8 |
| Number of Starts | 70 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 15 |
| Attempted Starts | 85 |
| r | 81.53375 |
| D | 2.2564706 |
| T | 56.773647 |
| Demand Factor | 0.0631619 |
| UFOP | 17.68% |

2015 Gas Turbine UFOP Calculations - External Causes Excluded

Hardwoods GT - Statistics

| State | Y-T-D | |
|---------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 240.65 | |
| 12 | 129.05 | 58.06 |
| 13 | 40.52 | 13.7 |
| 14 | 1970.4 | 0 |
| 15 | 4155.57 | 1491.4 |
| 16 | 545.2 | 144.98 |
| 21 | 51.5 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 65.12 | |
| 25 | 1452.93 | |
| 30 | 0 | |
| TOTAL | 8650.94 | 1708.14 |
| Number of Forced Outages: | | 11 |
| Number of Unit Starts | | 107 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 410.22 |
| State 14+15+16 | 3606.78 |
| State 21+22+23 | 51.5 |
| Number of FO | 11 |
| Number of Starts | 107 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 4 |
| Attempted Starts | 112 |
| r | 4.6818182 |
| D | 3.6956757 |
| T | 32.203393 |
| Demand Factor | 0.4748252 |
| UFOP | 5.63% |

NLH HWD/SVL Units - External Causes Excluded

| | |
|--------------------|-----------|
| State 11+12+13 | 646.34 |
| State 14+15+16 | 9,245.17 |
| State 21+22+23 | 703.35 |
| Number of FO | 18.00 |
| Number of Starts | 177 |
| No. of Start Fail. | 1 |
| No. trans. to SC | 19 |
| Attempted Starts | 197 |
| r | 39.075 |
| D | 3.2976531 |
| T | 46.93 |
| Demand Factor | 0.1339447 |
| UFOP | 12.72% |

Calculations - External Causes Excluded

Stephenville GT - Statistics

| State | Y-T-D | |
|---------------------------|---------|------------|
| Code | Hours | Adj. Hours |
| 11 | 147.67 | |
| 12 | 88.45 | 44.13 |
| 13 | 0.00 | 0 |
| 14 | 3978.45 | |
| 15 | 1605.02 | 819.85 |
| 16 | 54.92 | 27.46 |
| 21 | 651.85 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 530.17 | |
| 25 | 1645.43 | |
| 30 | 0.00 | |
| TOTAL | 8701.96 | 891.44 |
| Number of Forced Outages: | | 7 |
| Number of Unit Starts | | 70 |

Calculations

| | |
|--------------------|-----------|
| State 11+12+13 | 236.12 |
| State 14+15+16 | 5638.39 |
| State 21+22+23 | 651.85 |
| Number of FO | 7 |
| Number of Starts | 70 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 15 |
| Attempted Starts | 85 |
| r | 93.121429 |
| D | 2.7778824 |
| T | 66.334 |
| Demand Factor | 0.06691 |
| UFOP | 15.59% |

| Unit | Start_Date | Finish_Date | State Code | Outage Code | Sync/Condense | State | Operating? | Prev Stat Already | Prev Stat Already | S.C.? | Trans to SC? | Starting Failure? |
|------|------------------|-----------------|---|--|---------------|-------|------------|----------------------|----------------------|-------|--------------|-------------------|
| HWDT | 12:01 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | TRUE | | |
| HWDT | 12:16 | 12:25 | 21 (2)-FO-2 : Forced Outage - Immediately Deferrable | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:26 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| HWDT | 2011/01/05 7:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:45 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:47 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/01/10 9:34 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:42 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:43 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 20:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:26 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/01/27 8:17 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:16 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/01/31 7:35 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:02 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/01/31 | 2011/02/01 | | (49950) Fuel Management Controls and Instrumentation | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 11:43 | 15:03 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:02 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:44 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:12 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:20 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:39 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:20 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/02/22 7:49 | 2011/02/22 | 25-PO : Planned Outage | (64210) Supervisory Control & Data Acquisition (SCADA) | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:05 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/02/23 7:33 | 16:34 | 24-MO : Maintenance Outage | (49900) Controls and Instrumentation | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:34 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:38 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/02/25 9:08 | 13:16 | 25-PO : Planned Outage | (49900) Controls and Instrumentation | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:16 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/03/01 8:21 | 2011/03/01 9:03 | 25-PO : Planned Outage | (49900) Controls and Instrumentation | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/03/01 9:03 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:43 | 12:56 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:56 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/03/07 9:23 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 15:39 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/03/08 8:23 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 15:43 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/03/23 7:54 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/03/23 9:49 | 13:17 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:17 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/04/14 8:55 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/04/14 9:39 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:30 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:05 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:51 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:25 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 19:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/04/27 8:34 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:50 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/05/09 9:13 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 23:05 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:38 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:12 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/05/24 9:19 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 19:47 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/05/25 12:12 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 12:19 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:17 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:42 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:35 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:44 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:46 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:58 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:02 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:13 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:25 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:14 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:17 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:25 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:30 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/06/22 1:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/06/22 1:40 | 2011/06/22 2:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/06/22 2:59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |

| | | | | | | | | | | | | |
|------|-----------------|---|-------|--------------------|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 2011/06/22 6:35 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:23 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:32 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/08/22 5:58 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 22:59 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:36 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:18 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:55 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:01 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:33 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:09 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2011/09/27 8:03 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:23 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:02 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 22:28 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/09/29 7:35 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 22:43 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/01 1:38 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:12 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:08 | 21 (1)-FO-1 : Forced Outage - Sudden | 49100 | Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:17 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:10 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:31 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | TRUE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:20 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:01 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:15 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:58 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:59 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 22:33 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/21 9:11 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:41 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/22 7:53 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:28 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/25 8:19 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/25 9:38 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:41 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:17 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:15 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 19:06 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/27 7:35 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:00 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:35 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/28 7:50 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 21:50 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/29 9:14 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 20:54 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/30 8:53 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:48 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/10/31 7:13 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 22:01 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/11/03 0:30 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/11/03 7:18 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2011/11/07 7:30 | 24-MO : Maintenance Outage | 49100 | Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:08 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2011/11/14 7:30 | 25-PO : Planned Outage | 49100 | Combustion Turbine | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:10 | 13:48 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:43 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:49 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:49 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:24 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:49 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:01 | 14:17 21 (1)-FO-1 : Forced Outage - Sudden | 49100 | Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:17 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:32 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 22:28 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:42 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:14 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/01/11 8:42 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:22 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:48 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:26 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:57 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:23 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | TRUE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:39 | 21 (1)-FO-1 : Forced Outage - Sudden | 49100 | Compressor | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:39 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:34 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/01/16 6:03 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/01/19 9:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:09 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:57 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 12:45 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:30 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:21 | 14:36 21 (1)-FO-1 : Forced Outage - Sudden | 49100 | Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 21:12 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/02/11 8:46 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:45 | 12-0 (FD) : Operating under Forced Derated | 49100 | Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | 49100 | Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |

| | | | | | | | | | | | | |
|------|-----------------|-------|--|--------------------------------------|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 13:12 | 20:53 | 21 (4)-FO-4: Forced Outage - Starting Failure | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 20:53 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| | 2012/02/22 | | | | | | | | | | | |
| HWDT | 11:24 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:34 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:54 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:56 | 13:32 | 21 (4)-FO-4: Forced Outage - Starting Failure | (49812) Generator Lubrication System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 13:32 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:36 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:13 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:23 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/03/15 7:05 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/03/15 8:15 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:03 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/03/18 4:44 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 14:58 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:36 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/04/19 9:47 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:33 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:46 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:17 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:56 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:02 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:46 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:04 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:23 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:53 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:07 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:41 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/04/27 4:34 | 17:18 | 21 (1)-FO-1: Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:18 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/05/02 8:46 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:11 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:37 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:42 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/05/03 7:52 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:45 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:34 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:14 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:34 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:36 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| HWDT | 2012/05/16 9:09 | 19:00 | 25-PO: Planned Outage | (49100) Combustion Turbine | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:00 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/05/17 1:36 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2012/05/17 2:25 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:28 | 17:30 | 25-PO: Planned Outage | (49100) Combustion Turbine | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:30 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/05/19 8:54 | 17:22 | 25-PO: Planned Outage | (49100) Combustion Turbine | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:37 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:22 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 12:00 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:17 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:18 | 17:12 | 25-PO: Planned Outage | (49100) Combustion Turbine | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:12 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:00 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:42 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:42 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:15 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:22 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:47 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:17 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:38 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:55 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:42 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:47 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:17 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:24 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:44 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:57 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:14 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:07 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:22 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:39 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:18 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:19 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:24 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:27 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 17:30 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:05 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:20 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:56 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:34 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:58 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:33 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:01 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:44 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:07 | 11:47 | 21 (1)-FO-1: Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:47 | | 15-ABNO (FD): Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:55 | | 12-O (FD): Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |

| | | | | | | | | | | | | |
|------|------------|-------|---|------------------------------------|-------|-------|-------|-------|-------|-------|---|---|
| HWDT | | 13:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 13:55 | 21 (1)-FO-1: Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 14:39 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 15:05 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 19:11 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 20:49 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 21:17 | 21 (1)-FO-1: Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/06/05 | 3:18 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/06/05 | 3:32 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/06/05 | 3:37 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/06/05 | 4:07 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/06/05 | 4:10 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/06/05 | 7:11 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 14:24 | 25-PO : Planned Outage | (49243) Clutch | FALSE | 25 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 16:47 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 18:54 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 19:06 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 23:01 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 16:07 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 21:24 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/06/29 | 9:00 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/06/29 | 9:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/06/29 | 9:47 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 10:04 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 10:01 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 11:43 | 21 (1)-FO-1: Forced Outage - Sudden | (49811) Generator Bearings | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 16:50 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 20:28 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 13:24 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 14:08 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 21:48 | 21 (1)-FO-1: Forced Outage - Sudden | (49325) Building Fire Protection | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 17:54 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | | 12:09 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 12:41 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | | 21:45 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 13:31 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 14:56 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/08/30 | 9:43 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | FALSE | TRUE | FALSE | 1 | 0 |
| HWDT | | 20:06 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 10:29 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 11:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 11:49 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 12:41 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/09/11 | 8:45 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 18:46 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/09/17 | 8:54 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | | 18:18 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 10:04 | 21 (1)-FO-1: Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 12:58 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 13:57 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 16:29 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 16:47 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 23:39 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 16:56 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 17:08 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 18:17 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 19:10 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 18:11 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 20:31 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/10/31 | 8:46 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/10/31 | 9:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2012/10/31 | 9:48 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 10:03 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 17:14 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 18:25 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 15:01 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 15:17 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 12:27 | 21 (1)-FO-1: Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 13:35 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 15:06 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | | 15:54 | 21 (1)-FO-1: Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 17:22 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2012/11/27 | 6:18 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | | 17:54 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 21:49 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 23:18 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 14:35 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 15:49 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | | 16:00 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 17:33 | 11-O : Operating | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 18:25 | 14-ABNO : Available but not operating | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2013/01/11 | 7:12 | 11-O : Operating | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 11:32 | 14-ABNO : Available but not operating | FALSE | 14 | FALSE | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2013/01/16 | 0:44 | 14-ABNO : Available but not operating | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | | 14:27 | 11-O : Operating | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 15:17 | 14-ABNO : Available but not operating | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | | 16:35 | 11-O : Operating | TRUE | 11 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | | 21:04 | 14-ABNO : Available but not operating | FALSE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2013/01/17 | 9:08 | 11-O : Operating | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | | 14:26 | 14-ABNO : Available but not operating | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |

| | | | | | | | | | | | | |
|------|-----------------|------------------|--|--|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 16:10 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:36 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:50 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:54 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:44 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:31 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 21:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:04 | 22:33 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | TRUE | 21 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 22:33 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:49 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:13 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:05 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2013/01/23 7:26 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2013/01/23 7:32 | 2013/01/23 9:21 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2013/01/23 9:21 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2013/01/23 9:48 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:24 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:49 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:26 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:16 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:09 | 12:24 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 12:24 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2013/04/17 9:11 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:24 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2013/05/17 6:26 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2013/05/18 9:05 | 2013/05/25 16:14 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:14 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:01 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:37 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:58 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2013/07/04 9:01 | 10:48 | 24-MO : Maintenance Outage | (5200) Transmission Limitations | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:48 | | 14-ABNO : Available but not operating | (49100) Combustion Turbine | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:45 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:07 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:19 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:39 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:40 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:47 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:12 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:36 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:52 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:09 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:39 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:14 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:34 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:53 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2013/10/04 0:00 | 12:34 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:34 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:49 | 13:30 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:30 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:04 | 2013/12/19 8:32 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2013/12/19 8:32 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:41 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:42 | 23:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/01/01 0:01 | 19:39 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:39 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/01/09 9:36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49810) Generator Rotor | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:09 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/01/11 9:04 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:17 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:04 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:35 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:59 | 21:52 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 21:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/01/12 9:38 | 13:47 | 24-MO : Maintenance Outage | (49980) Auxiliaries Controls and Instrumentation | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:00 | 18:58 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:48 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:07 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:15 | | 11-O : Operating | | FALSE | 11 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:21 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 22:31 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/01/22 8:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:25 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:26 | 13:57 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:57 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:01 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:12 | 15:06 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:06 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:09 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:19 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:20 | 15:52 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:52 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:55 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

| | | | | | | | | | | | | | |
|------|------------------|-----------------|---|----------------------------|-------|-------|-------|-------|-------|-------|-------|---|---|
| HWDT | 16:01 | | 11-O : Operating | | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:02 | 16:50 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/01/23 7:03 | 2014/01/23 8:55 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/01/23 8:55 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 11:33 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:23 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:06 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:40 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:04 | | 11-O : Operating | | FALSE | 11 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:10 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/04 6:35 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/04 7:08 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:20 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:24 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:54 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:51 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:08 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:46 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/07 9:17 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:36 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:28 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:53 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:11 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/10 4:05 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/13 8:36 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:33 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:27 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:47 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:20 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:54 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:55 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/02/18 2:35 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:17 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:54 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:51 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/01 9:39 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:50 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:44 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:32 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:39 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:10 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/04 5:21 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:30 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 12 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:05 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:36 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/05 9:02 | 13:00 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:48 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/06 4:45 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:14 | 2014/03/07 8:10 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:42 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/10 4:39 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/10 9:47 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/11 6:37 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:12 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/16 7:15 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/16 11:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:07 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:17 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/19 5:34 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/03/19 9:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:22 | 10:43 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | TRUE | 21 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 10:43 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:18 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:50 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:31 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:19 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:49 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:01 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/04/09 7:06 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:51 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:32 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:07 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:50 | 21:52 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 15:28 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | FALSE | 0 | 0 |

| | | | | | | | | | | | | |
|------|-----------------|-----------------|---|--|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 20:58 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 21:30 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| HWDT | 21:34 | 23:14 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:44 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | TRUE | FALSE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/05/07 7:41 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/05/07 9:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:30 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/05/08 7:41 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/05/08 9:55 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/05/12 5:53 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/05/12 7:46 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/05/12 8:33 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/06/01 6:46 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:14 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:15 | 13:18 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49270) Starting System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 12:53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:46 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:01 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:02 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:33 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:10 | 2014/06/21 8:24 | 25-PO : Planned Outage | (49312) Heat Shields | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/06/21 8:24 | 11:00 | 25-PO : Planned Outage | (49312) Heat Shields | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:00 | 18:45 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49312) Heat Shields | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:45 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:17 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:05 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:45 | 19:16 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49312) Heat Shields | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:16 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:07 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:33 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:52 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:26 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:04 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:59 | 19:10 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:32 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/07/05 7:52 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:09 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:28 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:37 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:34 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:13 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/07/25 3:47 | 11:54 | 21 (1)-FO-1 : Forced Outage - Sudden | (49890) Electrical Distribution System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:54 | | 11-O : Operating | | TRUE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:39 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:53 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:42 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:58 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:03 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/09/26 6:58 | 15:53 | 24-MO : Maintenance Outage | (49314) Fuel Supply System to Unit | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:53 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| HWDT | 15:08 | 15:27 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2014/10/02 7:41 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/10/02 8:57 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:24 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:24 | 2014/10/18 7:16 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49270) Starting System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 2014/10/18 7:16 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 13:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:42 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:19 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 12:53 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:22 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:24 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:45 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:28 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/11/17 7:29 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/11/17 8:11 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:07 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:54 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:09 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:06 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:45 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:22 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:59 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:25 | 10:52 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:41 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 23:57 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/12/09 4:42 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2014/12/09 8:57 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:09 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |

| | | | | | | | | | | | | |
|------|------------------|-----------------|--|------------------------------------|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 14:11 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:09 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:11 | 15:10 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 14:03 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:31 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:48 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:16 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:26 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:12 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:10 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2014/12/31 6:19 | 2014/12/31 7:10 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49270) Starting System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 2014/12/31 7:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:36 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/01 6:11 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/01/01 8:18 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 19:15 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/03 6:15 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:35 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/06 6:41 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:38 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:32 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:08 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/08 9:43 | 10:59 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:59 | 16:55 | 13-O (SD) : Operating under Scheduled Derated | (49294) Exhaust Hood/Doors | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:50 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/08 13:39 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49294) Exhaust Hood/Doors | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:15 | 16:55 | 13-O (SD) : Operating under Scheduled Derated | (49294) Exhaust Hood/Doors | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:55 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 20:57 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/09 6:23 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:01 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:49 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:15 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/12 8:07 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:33 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:04 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/14 6:49 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:45 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:05 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:14 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:14 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:38 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/22 9:29 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:54 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/01/23 9:45 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:52 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:12 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:17 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/02/04 6:55 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/02/04 8:09 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/02/05 6:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/02/05 9:08 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:21 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:47 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/02/09 6:31 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:02 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:53 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/02/10 6:55 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:35 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/02/11 8:32 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:28 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/02/12 6:47 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:54 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:19 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:08 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:38 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:42 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:23 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:02 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:55 | 16:50 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:50 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:15 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/02/25 6:36 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/02/25 8:39 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 22:57 | 2015/02/27 0:16 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/02/27 0:16 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 2015/02/27 1:13 | 15:18 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:18 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/02/28 5:47 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/02/28 6:48 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/02/28 9:42 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 10:28 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 23:14 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/03/01 6:25 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |

| | | | | | | | | | | | | |
|------|------------------|---|--|------------------------------------|-------|-------|-------|-------|-------|-------|---|---|
| HWDT | 12:18 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 16:35 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 18:23 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 15:08 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 15:08 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 23:11 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/04 6:11 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/03/04 7:52 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/04 9:27 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 17:35 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 10:21 | 11 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 11:25 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 11:32 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/06 4:10 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 13:58 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/07 8:50 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 19:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/08 7:38 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/03/08 13:33 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 17:00 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 20:51 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/10 7:49 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/03/10 8:46 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 18:07 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 20:53 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/12 6:04 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 11:57 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 17:01 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 21:26 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/13 3:25 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 12:17 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 16:49 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 20:38 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/14 6:38 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/03/14 9:27 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/16 9:21 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 13:20 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 13:51 | 25-PO : Planned Outage | (49800) Generator Outage | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 16:29 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 16:34 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/03/25 | 2015/03/25 | (49850) Synchronous Condenser Equipment | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 15:12 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 15:58 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 16:03 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/04/02 6:36 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/04/02 8:13 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/04/16 7:24 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 12:49 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 16:29 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 18:19 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/04/21 7:11 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/04/21 8:41 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/04/22 7:31 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/04/22 8:45 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/04/28 7:58 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/04/28 8:46 | 21 (1)-FO-1 : Forced Outage - Sudden | (49290) Exhaust Hoses | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 15:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 | |
| HWDT | 16:41 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 18:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 20:59 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 21:45 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/05/29 8:24 | 2015/07/28 | (49850) Fuel Management Controls and Instrumentation | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 18:42 | 25-PO : Planned Outage | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 19:13 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/07/29 | 2015/07/30 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 15:30 | 17:17 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49314) Fuel Supply System to Unit | FALSE | 16 | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/07/30 | 17:17 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | 0 | 0 | |
| HWDT | 18:00 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 18:30 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 15:16 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 16:02 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 17:00 | 12-0 (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 18:09 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 19:20 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 22:27 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 13:00 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 13:52 | 14-ABNO : Available but not operating | (49100) Combustion Turbine | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 15:56 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 18:03 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | TRUE | FALSE | 0 | 0 | |
| HWDT | 23:01 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 11:43 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 13:01 | 20:35 | 21 (1)-FO-1 : Forced Outage - Sudden | (49811) Generator Bearings | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 20:35 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 20:43 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 2015/08/12 8:42 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 2015/08/12 8:53 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |
| HWDT | 11:08 | 12-0 (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 | |
| HWDT | 13:31 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 | |

| | | | | | | | | | | | | |
|------|------------------|------------------|--|--|-------|----|-------|-------|-------|-------|---|---|
| HWDT | 20:06 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 22:31 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/09/13 9:57 | 2015/09/13 12:12 | 24-MO - Maintenance Outage | (5201) Powerhouse substation (non-Generating Unit Equipment) | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:12 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/09/15 9:56 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:15 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/09/27 8:18 | 2015/09/27 9:24 | 21 (4)-FO-4 : Forced Outage - Starting Failure | (49243) Clutch | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 1 |
| HWDT | 2015/09/27 9:24 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:51 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/10/05 | 2015/10/09 11:38 | 25-PO : Planned Outage | (5201) Powerhouse substation (non-Generating Unit Equipment) | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:24 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:38 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:08 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:24 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:06 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 15:08 | | 21 (1)-FO-1 : Forced Outage - Sudden | (49294) Exhaust Hood/Doors | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 20:00 | 11:00 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:00 | 2015/10/23 18:27 | 25-PO : Planned Outage | (5201) Powerhouse substation (non-Generating Unit Equipment) | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/10/23 7:52 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 18:27 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:36 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/01 18:24 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 16:29 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/02 18:58 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:47 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/03 11:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49243) Clutch | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:32 | | 12-O (FD) : Operating under Forced Derated | (49243) Clutch | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 23:01 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49243) Clutch | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:27 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/04 13:38 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 17:12 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/04 18:23 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:00 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/05 18:50 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/11 7:26 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/11 12:01 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:50 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/17 18:26 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:00 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/18 21:57 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/19 8:54 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/19 10:24 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/20 7:23 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/20 9:54 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 16:29 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/20 17:39 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 11:23 | 17:31 | 24-MO - Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:31 | | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/11/23 17:36 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | TRUE | 16 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/11/24 5:00 | 15:00 | 24-MO : Maintenance Outage | (49800) Generator | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:00 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 10:30 | 14:45 | 24-MO - Maintenance Outage | (49319) Cooling Water System | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:29 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 11:44 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 13:57 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 19:04 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 18:23 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 21:04 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/12/01 7:28 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 2015/12/01 8:18 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/12/02 11:35 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:18 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 14:30 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 17:15 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| HWDT | 2015/12/03 9:15 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 13:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| HWDT | 16:39 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 18:16 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| HWDT | 12:07 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 12:46 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| HWDT | 15:11 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

| | | | | |
|------|-----------------|---------------------------------------|--|-------|
| HWDT | 15:55 | 11-O : Operating | | FALSE |
| HWDT | 16:39 | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 2015/12/10 7:13 | 11-O : Operating | | FALSE |
| HWDT | 2015/12/10 8:21 | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 16:35 | 11-O : Operating | | FALSE |
| HWDT | 18:20 | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 16:35 | 11-O : Operating | | FALSE |
| HWDT | 18:39 | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 16:12 | 11-O : Operating | | FALSE |
| HWDT | 18:05 | 14-ABNO : Available but not operating | | FALSE |
| HWDT | 16:15 | 11-O : Operating | | FALSE |
| HWDT | 17:50 | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 10:40 | 11-O : Operating | | FALSE |
| HWDT | 14:49 | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 2015/12/29 8:17 | 11-O : Operating | | FALSE |
| HWDT | 21:15 | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 16:35 | 11-O : Operating | | FALSE |
| HWDT | 20:55 | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 2015/12/31 6:48 | 11-O : Operating | | FALSE |
| HWDT | 11:58 | 14-ABNO : Available but not operating | | TRUE |
| HWDT | 18:07 | 11-O : Operating | | FALSE |
| HWDT | 20:45 | 14-ABNO : Available but not operating | | TRUE |

[illegible]

| Unit | Start Date | Finish Date | State Code | Outage Code | Synch | Condense | State | Operating? | Synch Cond? | Prev Stat Already | Prev Stat Operating? | S.C.? | Trans to SC? | Starting Failure? |
|------|-----------------|-------------|---|--|-------|----------|-------|------------|-------------|----------------------|-------------------------|-------|--------------|-------------------|
| SVLT | 10:34 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 10:34 | 15 | FALSE | FALSE | TRUE | TRUE | | | |
| SVLT | 10:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | TRUE | FALSE | | 0 | 0 |
| SVLT | 11:11 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 11:49 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 2011/01/20 9:51 | 11:12 | 21 (1)-FO-1 : Forced Outage - Sudden | (49253) Intercoolers | FALSE | | 21 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 11:13 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 11:30 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 15:02 | 15:16 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | | 21 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 15:16 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 14:40 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:41 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 2011/02/15 7:05 | 14:49 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | | 24 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:49 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/02/17 8:12 | 15:15 | 25-PO : Planned Outage | (99999) Other | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 15:15 | | 14-ABNO : Available but not operating | (49100) Combustion Turbine | TRUE | | 14 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 13:49 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:38 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 2011/03/07 | 2011/03/07 | | (49311) Internal Cooling and Seal Air System and Seals | FALSE | | 21 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 16:23 | 17:46 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 17:46 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 21 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 19:00 | 20:07 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 20:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 24 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/03/15 9:18 | 14:14 | 24-MO : Maintenance Outage | (49800) Generator | FALSE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 14:14 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/03/16 | 2011/03/16 | | (49980) Auxiliaries Controls and Instrumentation | FALSE | | 24 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/03/16 8:23 | 16:21 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 16:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (99999) Other | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/03/18 9:48 | 14:39 | 25-PO : Planned Outage | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:46 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49280) Battery and Charge System | TRUE | | 24 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/03/23 7:05 | 11:20 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | TRUE | | 24 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 11:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 24 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/03/24 6:50 | 15:28 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 15:28 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 11:49 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 12:41 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 14:19 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 0 | 0 |
| SVLT | 15:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 2011/04/20 8:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 13:11 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | TRUE | FALSE | | 0 | 0 |
| SVLT | 14:34 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 15:09 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 10:08 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 11:02 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 13:19 | 16:57 | 25-PO : Planned Outage | (49321) External Cooling Air System | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 16:57 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/06/14 9:27 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/06/14 9:40 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 2011/06/16 8:59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | TRUE | FALSE | FALSE | | 0 | 0 |
| SVLT | 12:58 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 10:01 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 13:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 0 | 0 |
| SVLT | 13:14 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:11 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 14:20 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:51 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/07/27 7:47 | 16:41 | 25-PO : Planned Outage | (49293) Exhaust Stack and Silencer | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 16:41 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/07/29 9:27 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 10:13 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | TRUE | FALSE | | 0 | 0 |
| SVLT | 2011/08/15 9:29 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 16:29 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 14:21 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | | 12 | TRUE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 15:09 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | TRUE | FALSE | | 0 | 0 |
| SVLT | 2011/08/26 8:02 | 11:03 | 24-MO : Maintenance Outage | (49325) Building Fire Protection | FALSE | | 24 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 11:03 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/09/09 7:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 10:51 | 15:18 | 25-PO : Planned Outage | (49321) External Cooling Air System | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 15:18 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/09/14 5:56 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/09/14 8:49 | 18:48 | 25-PO : Planned Outage | (5200) Transmission Limitations | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 18:48 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 19:14 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/09/15 5:37 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/09/15 6:27 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/09/15 7:10 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 10:06 | 18:55 | 25-PO : Planned Outage | (5200) Transmission Limitations | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 18:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 19:07 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/09/19 7:32 | 19:39 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49890) Electrical Distribution System | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 19:39 | | 25-PO : Planned Outage | (49100) Combustion Turbine | TRUE | | 25 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/09/20 7:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | | 15 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 2011/09/20 9:55 | 16:21 | 25-PO : Planned Outage | (49890) Electrical Distribution System | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 16:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |
| SVLT | 2011/09/22 8:22 | 14:38 | 25-PO : Planned Outage | (49325) Building Fire Protection | FALSE | | 25 | FALSE | FALSE | FALSE | FALSE | | 0 | 0 |
| SVLT | 14:38 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | | 15 | FALSE | TRUE | FALSE | FALSE | | 1 | 0 |

Number of transitions to S.C. 60
Number of starting failures 0

Starting Failure Code 21 (4)-PO-4 : Forced Outage - Starting Failure

| | | | | | | | | | | | | |
|------|---------------------|---------------------|---|--|-------|----|-------|-------|-------|-------|---|---|
| SVLT | 2011/10/04 10:25 | 2011/10/04 10:53 | 21 (1)-FO-1 : Forced Outage - Sudden | (49980) Auxiliaries Controls and Instrumentation | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:53 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:33 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 14:17 | 15:04 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 13:22 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:50 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:37 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:13 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:59 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:17 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:43 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:06 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2011/12/20 7:26 | 17:45 | 21 (1)-FO-1 : Forced Outage - Sudden | (49890) Electrical Distribution System | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:45 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 14:49 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:41 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:46 | 23:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49820) Generator Stator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2012/01/01 0:01 | 23:59 | 21 (1)-FO-1 : Forced Outage - Sudden | (49820) Generator Stator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2013/01/01 0:01 | 10:00 | 21 (1)-FO-1 : Forced Outage - Sudden | (49820) Generator Stator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:00 | 16:54 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:54 | 10:00 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:00 | 12:18 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:18 | 2013/06/01 8:51 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2013/06/01 8:51 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:33 | 12:09 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:09 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:40 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 14:41 | 15:49 | 24-MO : Maintenance Outage | (49313) Supercharging Fan | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:49 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:02 | 12:00 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:01 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:36 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:37 | 11:32 | 24-MO : Maintenance Outage | (49314) Fuel Supply System to Unit | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:32 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:02 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 14:03 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 12:00 | | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:42 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:32 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 17:19 | 14:28 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:28 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 13:18 | 15:55 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:55 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 10:11 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:43 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2013/07/19 7:11 | 2013/07/20 2:57 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2013/07/20 2:57 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2013/07/25 9:25 | 14:45 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:45 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 14:41 | 15:41 | 24-MO : Maintenance Outage | (49317) Lubrication System | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:41 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:21 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:01 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:07 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:42 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:38 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:37 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2013/10/24 9:36 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:01 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:57 | 21:23 | 21 (1)-FO-1 : Forced Outage - Sudden | (49100) Combustion Turbine | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:23 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2013/11/14 9:15 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:24 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:10 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:52 | 20:21 | 25-PO : Planned Outage | (49812) Generator Lubrication System | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:21 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:30 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:20 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 16:44 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 22:35 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 22:20 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:29 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:47 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:32 | 21:33 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 21:33 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/01/04 2:14 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/04 9:05 | 2014/01/04 9:57 | 21 (1)-FO-1 : Forced Outage - Sudden | (5203) Transmission equipment beyond the transmission line | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/01/04 9:57 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:10 | 14:28 | 21 (1)-FO-1 : Forced Outage - Sudden | (49810) Generator Rotor | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 14:28 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/01/04 15:33 | 2014/01/04 15:56 | 21 (1)-FO-1 : Forced Outage - Sudden | (5203) Transmission equipment beyond the transmission line | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:56 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 19:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/01/05 0:03 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |

[illegible]

| | | | | | | | | | | | |
|------|-----------------------|--|--|-------|----|-------|-------|-------|-------|---|---|
| SVLT | 10:40 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:06 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:24 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:26 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:56 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 20:55 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:06 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 21:17 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:19 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:44 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:33 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 14:39 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:30 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 16:56 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:33 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/05/07 8:23 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/05/07 9:55 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/05/16 10:53 | 2014/05/16 14:44 | (49311) Internal Cooling and Seal Air System and Seals | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:44 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/05/28 8:58 | 13:50 25-PO : Planned Outage | (49325) Building Fire Protection | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:50 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/06/06 9:52 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:07 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/06/06 14:00 | 2014/06/09 11:00 | (49980) Auxiliaries Controls and Instrumentation | TRUE | 21 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 11:00 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:30 | 12-O (FD) : Operating under Forced Derated | (49293) Exhaust Stack and Silencer | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:48 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/06/11 8:47 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:36 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:44 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:48 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:38 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:24 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:55 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:13 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/08/06 9:20 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/08/06 9:42 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/08/12 8:08 | 18:14 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 12 | FALSE | FALSE | FALSE | FALSE | 1 | 0 |
| SVLT | 18:14 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 13:12 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:30 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/09/18 8:09 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:15 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:00 | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/02 11:18 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/10/04 8:26 | 10:00 25-PO : Planned Outage | (49100) Combustion Turbine | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:00 | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/21 11:24 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:25 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:38 | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/22 12:41 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:42 | 14:53 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:54 | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/22 21:12 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 21:13 | 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/23 8:12 | 13-O (SD) : Operating under Scheduled Derated | (49100) Combustion Turbine | FALSE | 13 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2014/10/23 15:46 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49100) Combustion Turbine | FALSE | 16 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:51 | 15:23 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:23 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 15:24 | 18:04 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | TRUE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:04 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:51 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 18:52 | 10:00 25-PO : Planned Outage | (99999) Other | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:00 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:24 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:25 2014/11/20 9:21 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:48 | 20:30 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:01 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:14 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:44 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 14:12 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:19 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:55 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:56 | 17:00 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:00 | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:00 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2014/11/30 6:41 | 14:56 24-MO : Maintenance Outage | (49100) Combustion Turbine | TRUE | 24 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 14:56 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 17:06 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 17:10 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:40 | 19:34 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 19:34 | 15-ABNO (FD) : Available but not operating - Forced Derated | (49314) Fuel Supply System to Unit | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2014/12/09 4:13 | 12-O (FD) : Operating under Forced Derated | (49314) Fuel Supply System to Unit | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |

[illegible]

| | | | | | | | | | | | | |
|------|------------------|------------------|--|--|-------|----|-------|-------|-------|-------|---|---|
| SVLT | 17:59 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 20:16 | | 11-O : Operating | | TRUE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:51 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/03/05 20:14 | 2015/03/05 21:31 | 21 (1)-FO-1 : Forced Outage - Sudden | (49650) Synchronous Condenser Equipment | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:31 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2015/03/06 4:45 | | 11-O : Operating | | TRUE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/03/06 8:08 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/03/06 8:52 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:09 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/03/07 4:03 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/03/07 8:08 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/03/12 6:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/03/12 8:56 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:09 | 12:29 | 21 (1)-FO-1 : Forced Outage - Sudden | (49314) Fuel Supply System to Unit | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 1 | 0 |
| SVLT | 12:29 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| SVLT | 10:55 | 10:34 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:34 | 15:28 | 21 (1)-FO-1 : Forced Outage - Sudden | (49811) Generator Bearings | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:28 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:10 | 2015/05/28 9:41 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/05/28 9:41 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/05/28 9:59 | 2015/05/29 7:50 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/05/29 7:50 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/05/29 8:50 | 17:36 | 24-MO : Maintenance Outage | (99999) Other | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:36 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 11:15 | 15:35 | 24-MO : Maintenance Outage | (49800) Generator | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:35 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 10:05 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:29 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49800) Generator | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/06/17 7:20 | 2015/06/17 16:50 | 25-PO : Planned Outage | (5201) Powerhouse substation (non-Generating Unit Equipment) | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:50 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49800) Generator | TRUE | 15 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 17:33 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:54 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 19:56 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/06/23 9:31 | 17:00 | 24-MO : Maintenance Outage | (49100) Combustion Turbine | TRUE | 24 | FALSE | TRUE | TRUE | FALSE | 1 | 0 |
| SVLT | 17:00 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 10:27 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/07/20 10:28 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/07/20 22:15 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | TRUE | 16 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2015/07/21 9:51 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/07/21 18:25 | | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | TRUE | 16 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2015/07/22 7:19 | 2015/07/22 17:23 | 16-ABNO (SD) : Available but not operating - Scheduled Derated | (49101) Combustion Turbine @ Exhaust Emission | FALSE | 16 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:23 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| SVLT | 2015/07/28 8:58 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 2015/07/28 9:55 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:18 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:19 | 11:28 | 21 (1)-FO-1 : Forced Outage - Sudden | (49811) Generator Bearings | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:42 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:50 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:28 | | 12-O (FD) : Operating under Forced Derated | (49811) Generator Bearings | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:25 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49811) Generator Bearings | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/08/12 8:42 | 20:07 | 24-MO : Maintenance Outage | (49325) Building Fire Protection | FALSE | 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:07 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 20:08 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 21:00 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | FALSE | 15 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:12 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 12:04 | | 15-ABNO (FD) : Available but not operating - Forced Derated | (49100) Combustion Turbine | TRUE | 15 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 12:54 | | 12-O (FD) : Operating under Forced Derated | (49100) Combustion Turbine | FALSE | 12 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 13:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 2015/08/31 9:00 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:12 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:42 | 16:43 | 25-PO : Planned Outage | (49890) Electrical Distribution System | FALSE | 25 | FALSE | FALSE | FALSE | FALSE | 1 | 0 |
| SVLT | 16:43 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 16:58 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:29 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:50 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:40 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:15 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 18:35 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:39 | 11:08 | 24-MO : Maintenance Outage | (49900) Controls and Instrumentation | FALSE | 24 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 11:08 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 11:45 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 13:10 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 15:39 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 15:50 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 18:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:01 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:10 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 10:22 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 10:29 | | 14-ABNO : Available but not operating | | FALSE | 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| SVLT | 17:31 | | 11-O : Operating | | FALSE | 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| SVLT | 17:58 | | 14-ABNO : Available but not operating | | TRUE | 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| SVLT | 23:11 | 17:30 | 21 (1)-FO-1 : Forced Outage - Sudden | (49900) Controls and Instrumentation | FALSE | 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |

| | | | | |
|------|-----------------|---------------------------------------|-------------------------------------|-------|
| SVLT | 17:30 | 11-O : Operating | | FALSE |
| SVLT | 17:40 | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/11/17 7:40 | 11-O : Operating | | FALSE |
| SVLT | 10:50 | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 12:49 | 11-O : Operating | | FALSE |
| SVLT | 19:25 | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/11/19 7:10 | 11-O : Operating | | FALSE |
| SVLT | 17:48 | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 2015/11/20 7:39 | 11-O : Operating | | FALSE |
| SVLT | 17:13 | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 2015/11/21 8:13 | 14-MO : Maintenance Outage | (49321) External Cooling Air System | FALSE |
| SVLT | 14:47 | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 10:00 | 11-O : Operating | | FALSE |
| SVLT | 14:40 | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 10:42 | 21 (1)-FO-1 : Forced Outage - Sudden | (49800) Generator | FALSE |
| SVLT | 12:04 | 11-O : Operating | | FALSE |
| SVLT | 12:57 | 14-ABNO : Available but not operating | | TRUE |
| SVLT | 16:22 | 11-O : Operating | | FALSE |
| SVLT | 17:39 | 14-ABNO : Available but not operating | | FALSE |
| SVLT | 18:08 | 11-O : Operating | | FALSE |
| SVLT | 18:24 | 14-ABNO : Available but not operating | | TRUE |

| | | | | | | |
|----|-------|-------|-------|-------|---|---|
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | TRUE | FALSE | 0 | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 24 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | FALSE | FALSE | 1 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 21 | FALSE | FALSE | FALSE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | FALSE | TRUE | FALSE | 0 | 0 |
| 11 | TRUE | FALSE | FALSE | FALSE | 0 | 0 |
| 14 | FALSE | TRUE | TRUE | FALSE | 0 | 0 |

Hardwoods GT - Statistics - 2011 to 2015

| State | Y-T-D | |
|--------------------------|----------|-------------|
| Code | Hours | Adj . Hours |
| 11 | 508.93 | |
| 12 | 438.18 | 151.34 |
| 13 | 40.52 | 13.7 |
| 14 | 10871.53 | 0 |
| 15 | 23982 | 3049.26 |
| 16 | 720.35 | 232.55 |
| 21 | 3074 | |
| 22 | 0 | |
| 23 | 0 | |
| 24 | 1957.45 | |
| 25 | 2231.03 | |
| 30 | 0 | |
| TOTAL | 43824.0 | 3446.9 |
| Number of Forced Outages | | 50 |
| Number of Unit Starts | | 325 |

Calculations

| | |
|--------------------|-------------|
| State 11+12+13 | 987.63 |
| State 14+15+16 | 35573.88 |
| State 21+22+23 | 3074 |
| Number of FO | 50 |
| Number of Starts | 325 |
| No. of Start Fail. | 10 |
| No. trans. to SC | 81 |
| Attempted Starts | 416 |
| r | 61.48 |
| D | 2.432586207 |
| T | 85.51413462 |
| Demand Factor | 0.063682434 |
| UFOP | 16.54% |

NLH HWD/SVL Units - External Causes Excluded

| | |
|--------------------|-------------|
| State 11+12+13 | 1,393.70 |
| State 14+15+16 | 50,982.94 |
| State 21+22+23 | 16,672.03 |
| Number of FO | 88.00 |
| Number of Starts | 514 |
| No. of Start Fail. | 10 |
| No. trans. to SC | 330 |
| Attempted Starts | 665 |
| r | 189.4548864 |
| D | 2.12778626 |
| T | 76.67 |
| Demand Factor | 0.037522239 |
| UFOP | 30.98% |

2011 to 2015 Gas Turbine UFOP Calculations - External Causes Included

Stephenville GT - Statistics - 2011 to 2015

| State | Y-T-D | |
|--------------------------|----------|-------------|
| Code | Hours | Adj . Hours |
| 11 | 160.23 | |
| 12 | 517.72 | 234.57 |
| 13 | 17.62 | 11.27 |
| 14 | 7516.02 | |
| 15 | 17543.40 | 7836.61 |
| 16 | 100.18 | 56.43 |
| 21 | 13598.03 | |
| 22 | 0.00 | |
| 23 | 0.00 | |
| 24 | 1671.20 | |
| 25 | 2699.60 | |
| 30 | 0.00 | |
| TOTAL | 43824.00 | 8138.88 |
| Number of Forced Outages | | 38 |
| Number of Unit Starts | | 189 |

Calculations

| | |
|--------------------|-------------|
| State 11+12+13 | 406.07 |
| State 14+15+16 | 15409.06 |
| State 21+22+23 | 13598.03 |
| Number of FO | 38 |
| Number of Starts | 189 |
| No. of Start Fail. | 0 |
| No. trans. to SC | 60 |
| Attempted Starts | 249 |
| r | 357.8428947 |
| D | 1.630803213 |
| T | 61.8837751 |
| Demand Factor | 0.029983213 |
| UFOP | 50.10% |

2011 to 2015 Gas Turbine UFOP Calculations - External Causes Excluded

Hardwoods GT - Statistics - 2011 to 2015

| State Code | Y-T-D Hours | Adj. Hours | <u>Calculations</u> | | <u>NLH HWD/SVL Units - External Causes Excluded</u> | |
|--------------------------|-------------|------------|---------------------|-------------|---|-----------|
| 11 | 508.93 | | State 11+12+13 | 987.63 | State 11+12+13 | 1,683.20 |
| 12 | 438.18 | 151.34 | State 14+15+16 | 35573.88 | State 14+15+16 | 60,733.48 |
| 13 | 40.52 | 13.7 | State 21+22+23 | 3074 | State 21+22+23 | 16,646.02 |
| 14 | 10871.53 | 0 | Number of FO | 50 | Number of FO | 84.00 |
| 15 | 23982 | 3049.26 | | | | |
| 16 | 720.35 | 232.55 | Number of Starts | 325 | Number of Starts | 514 |
| 21 | 3074 | | No. of Start Fail. | 10 | No. of Start Fail. | 10 |
| 22 | 0 | | No. trans. to SC | 81 | No. trans. to SC | 141 |
| 23 | 0 | | Attempted Starts | 416 | Attempted Starts | 665 |
| 24 | 1929.42 | | | | | |
| 25 | 2120.75 | | r | 61.48 | r | 198.1669 |
| 30 | 0 | | D | 2.432586207 | D | 2.569771 |
| | | | T | 85.51413462 | T | 91.33 |
| TOTAL | 43685.68 | 3446.85 | Demand Factor | 0.063682434 | Demand Factor | 0.0394824 |
| Number of Forced Outages | | 50 | UFOP | 16.54% | UFOP | 28.08% |
| Number of Unit Starts | | 325 | | | | |

2011 to 2015 Gas Turbine UFOP Calculations - External Causes Excluded

Stephenville GT - Statistics - 2011 to 2015

| State Code | Y-T-D Hours | Adj. Hours | <u>Calculations</u> | |
|--------------------------|-------------|------------|---------------------|-------------|
| 11 | 160.23 | | State 11+12+13 | 695.57 |
| 12 | 517.72 | 234.57 | State 14+15+16 | 25159.60 |
| 13 | 17.62 | 11.27 | State 21+22+23 | 13572.02 |
| 14 | 7516.02 | | Number of FO | 34 |
| 15 | 17543.40 | 7836.61 | | |
| 16 | 100.18 | 56.43 | Number of Starts | 189 |
| 21 | 13572.02 | | No. of Start Fail. | 0 |
| 22 | 0.00 | | No. trans. to SC | 60 |
| 23 | 0.00 | | Attempted Starts | 249 |
| 24 | 1117.95 | | | |
| 25 | 2419.45 | | r | 399.1770588 |
| 30 | 0.00 | | D | 2.793453815 |
| | | | T | 101.0425703 |
| TOTAL | 42964.59 | 8138.88 | Demand Factor | 0.033484297 |
| Number of Forced Outages | | 34 | UFOP | 39.52% |
| Number of Unit Starts | | 189 | | |