

Requests for Information

- 1 **Q. Further to the responses to PUB-NP-002 and PUB-NP-003, provide details in**
2 **relation to the status of the Stephenville and Hardwoods gas turbines and actions**
3 **being taken and anticipated timelines as discussed at the November 2013 meeting of**
4 **the Inter-Utility System Planning and Reliability Committee.**
5
- 6 A. The Inter Utility System Planning and Reliability Committee discussed the status of the
7 50 MW Stephenville and 50 MW Hardwoods gas turbines at their November 1st, 2013
8 meeting.
9
- 10 At that time, the Stephenville gas turbine was reported by Newfoundland and Labrador
11 Hydro (“Hydro”) as in-service as a synchronous condenser for system voltage support.
12 The unit was reported as capable of 40 MW of generation and was expected to be capable
13 of 50 MW by the end of November.
14
- 15 The Hardwoods gas turbine was reported by Hydro as being out of service on a planned
16 outage to replace the generator. The outage commenced the first week of October and
17 the unit was expected to return to service in mid-December.