

- 1 **Q. Please provide information showing how many times Newfoundland Power**
2 **exercised its voltage reduction capabilities in 2013. Of those times, how many were**
3 **for the purposes of affecting Newfoundland Power’s bill from Newfoundland and**
4 **Labrador Hydro, how many were due to system emergency conditions, and how**
5 **many times were for some other identified reason?**
6
- 7 A. In 2013, Newfoundland Power exercised its voltage reduction capabilities on 11
8 occasions. Of these 11 occasions, 8 were to manage demand costs from Newfoundland
9 and Labrador Hydro. The remaining 3 occasions were at the request of Newfoundland
10 and Labrador Hydro to support the operation of the Island Interconnected System.