

- 1 **Q. State what fuel is used, and what is the normal supply/storage capabilities, for the**  
2 **portable 6.5 MW generator.**  
3
- 4 A. The 6.5 MW Mobile Gas Turbine (“MGT”) uses No. 2 diesel fuel. The normal  
5 supply/storage capabilities include a 900 litre day tank and a 22,700 litre portable double  
6 walled tank. In cases where the MGT is expected to operate for an extended period,  
7 arrangements are made through our fuel supplier to have a fuel tanker on site.  
8
- 9 When the unit is parked and on standby at the Grand Bay substation in Port aux Basques,  
10 it is tied into the existing 22,700 litre storage tank located on site.