

- 1 **Q. Do inspectors record distribution pole GPS locations during the 7-year distribution**  
2 **feeder inspections? Do the inspectors take digital photographs of deficiencies**  
3 **identified during distribution feeder inspections?**  
4
- 5 A. Inspectors do not record pole GPS locations on all poles during the 7-year distribution  
6 feeder inspections. Inspectors will record the GPS location of a deficiency when it is  
7 identified.  
8
- 9 Inspectors will take digital photographs of deficiencies and attach them to the repair work  
10 order electronically if it will add value to the job planning or repair process. This is at the  
11 discretion of the inspector and is dependent on the nature and severity of the deficiency.<sup>1</sup>

---

<sup>1</sup> A digital photograph of a rusty transformer showing severity of rust would add value to the job planning and repair process. A photograph of porcelain cutout identified as part of a replacement program may not add value.