

- 1 **Q. What was Newfoundland Power’s peak demand during the 2013/2104 winter? What**
2 **was the Avalon Peninsula peak demand during Newfoundland 2013/2014 winter?**
3
4 A. Newfoundland Power’s actual peak demand during the 2013/2014 winter was
5 1,398,465 kW. The actual peak demand on the Avalon Peninsula during the 2013/2014
6 winter was 863,868 kW.