

- 1 **Q. Has Newfoundland Power replaced circuit breakers since 2004 because of fault duty**
2 **limitations? Will any of Newfoundland Power's circuit breakers need to be replaced**
3 **after the integration of Muskrat Falls and the Labrador-Island Link?**
4
- 5 A. Newfoundland Power has replaced 12 circuit breakers since 2004 because of fault duty
6 limitations. The majority of the replacements were due to the installation of additional
7 power transformers in substations.
8
- 9 A preliminary review shows that 1 Newfoundland Power circuit breaker at Oxen Pond
10 Terminal Station will need to be replaced in 2017 prior to the integration of Muskrat Falls
11 and the Labrador-Island Link. A more detailed analysis is required prior to the
12 Company's 2017 Capital Budget submission to confirm this requirement.