

- 1 **Q. Provide the average SAIDI and average SAIFI of Newfoundland Power’s fifteen**
 2 **worst performing feeders each year from 1998 to 2013.**
 3
 4 A. Newfoundland Power assesses its worst performing feeders on the basis of reliability
 5 over the most recent five year period. The average SAIDI and SAIFI of Newfoundland
 6 Power’s fifteen worst performing feeders each year from 1998 to 2013 based on the most
 7 recent 5 year data is detailed in Table 1.
 8
 9

Table 1
Worst Performing Feeders
Five Year Average

	<u>SAIDI</u>	<u>SAIFI</u>
1998	17.42	6.11
1999	17.35	6.86
2000	14.68	6.27
2001	12.00	5.92
2002	6.97	4.16
2003	7.75	4.26
2004	7.53	3.74
2005	7.48	3.58
2006	6.98	3.39
2007	6.07	3.12
2008	5.97	2.97
2009	4.62	3.86
2010	5.29	2.83
2011	5.20	2.69
2012	5.32	4.01
2013	5.15	2.62

1 SAIDI and SAIFI for the worst performing feeders from 1998 to 2013 are shown
2 graphically below:

