

February 2, 2015

The Board of Commissioners of Public Utilities  
Prince Charles Building  
120 Torbay Road, P.O. Box 21040  
St. John's, Newfoundland & Labrador  
A1A 5B2

**Attention: Ms. Cheryl Blundon**  
**Director Corporate Services & Board Secretary**

Dear Ms. Blundon:

**Re: Newfoundland and Labrador Hydro - the Board's Investigation and Hearing into  
Supply Issues and Power Outages on the Island Interconnected System – Nostradamus  
Load Forecasting Report - Revisions**

Enclosed please find the original plus 12 copies of revisions to Hydro's report entitled *Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro Monthly Report: December 2014*, which was filed with the Board on January 30, 2015. The revisions are as follows:

Table 1, page 6, (Rev 1) – Revision made to correct typos;  
Figure 1, page 7 (Rev 1) – Revision made reflect the above revision; and  
Figure 2, page 9 (Rev 1) – Revision made to reflect the above revision.

Revisions are as indicated by shading, where possible.

Yours truly,

**NEWFOUNDLAND AND LABRADOR HYDRO**

  
Tracey L. Pennell  
Legal Counsel

TLP/jc

cc: Gerard Hayes – Newfoundland Power  
Paul Coxworthy – Stewart McKelvey Stirling Scales  
Sheryl Nisenbaum – Praxair Canada Inc.  
ecc: Roberta Frampton Benefiel – Grand Riverkeeper Labrador

Thomas Johnson – Consumer Advocate  
Thomas O' Reilly – Cox & Palmer  
Danny Dumaresque

**Accuracy of Nostradamus Load Forecasting at  
Newfoundland and Labrador Hydro  
Monthly Report: December 2014**

Newfoundland and Labrador Hydro

January 30, 2015

Revised February 2, 2015



**Table of Contents**

1. NOSTRADAMUS LOAD FORECASTING ..... 1

    1.1 Nostradamus ..... 1

    1.2 Short Term Load Forecasting ..... 1

        1.2.1 *Utility Load* ..... 1

        1.2.2 *Industrial Load* ..... 2

        1.2.3 *Supply and Demand Status Reporting* ..... 2

    1.3 Load Forecasting Improvements..... 3

    1.4 Potential Sources of Variance ..... 4

2. DECEMBER 2014 FORECAST ACCURACY..... 5

    2.1 December 8, 2014 ..... 9

    2.2 December 12, 2014 ..... 12

1    **1.    NOSTRADAMUS LOAD FORECASTING**

2    **1.1    Nostradamus**

3    Newfoundland and Labrador Hydro (Hydro) uses software called Nostradamus, by  
4    Ventyx, for short term load forecasting with a time frame of seven days. “The  
5    Nostradamus Neural Network Forecasting system is a flexible neural network based  
6    forecasting tool developed specifically for utility demand forecasting. Unlike  
7    conventional computing processes, which are programmed, neural networks use  
8    sophisticated mathematical techniques to train a network of inputs and outputs. Neural  
9    networks recognize and learn the joint relationships (linear or non-linear) between the  
10   ranges of variables considered. Once the network learns these intricate relationships,  
11   this knowledge can then easily be extended to produce accurate forecasts.”  
12   (Nostradamus User Guide, Release 8.2, Ventyx, an ABB Company, May 2014).

13   The Nostradamus model is trained using a sequence of continuous historic periods of  
14   hourly weather and demand data, then forecasts system demand using predictions of  
15   those same weather parameters for the next seven days.

16   **1.2    Short Term Load Forecasting**

17   Hydro uses its short term load forecast to manage the power system and ensure  
18   adequate generating resources are available to meet customer demand.

19   **1.2.1   Utility Load**

20   Hydro contracts AMEC Foster Wheeler to provide the weather parameters in the form  
21   of hourly weather forecasts for a seven day period. At the same time as the weather  
22   forecast data is provided, AMEC also provides observed data at the same locations for  
23   the previous 24 hours (calendar day). The forecast and actual data are automatically  
24   retrieved from AMEC and input to the Nostradamus database.

25   Nostradamus can use a variety of weather parameters for forecasting as long as a  
26   historical record is available for training. Hydro uses the following weather parameters:  
27   air temperature, wind speed, and cloud cover. Nostradamus can use each variable  
28   more than once, for example both the current and forecast air temperatures are used in  
29   forecasting load. Wind chill is not used explicitly as the neural network function of  
30   Nostradamus will form its own relationships between load, wind and temperature,  
31   which should be superior to the one formula used by Environment Canada to derive  
32   wind chill.

1 Weather data for four locations are used in Nostradamus: St. John's, Gander, Deer Lake,  
2 and Port aux Basques. Data from January 1, 2012 to October 31, 2014 are being used  
3 for training and verification purposes. The training and verification periods are selected  
4 to provide a sufficiently long period to ensure that a range of weather parameters are  
5 included, e.g., high and low temperatures, but short enough that the historic load is still  
6 representative of loads that can be expected in the future.

7 In addition to the weather and demand data, a parameter that indicates daylight hours  
8 each day is input to Nostradamus.

9 Demand data for the Avalon Peninsula alone and for the Island Interconnected System  
10 as a whole are input to Nostradamus automatically each hour. Only total utility  
11 (conforming) load, Newfoundland Power's and Hydro's, is input in the Nostradamus  
12 model. Industrial load, which is not a function of weather is forecast outside the  
13 Nostradamus program and added to the forecasts from Nostradamus to derive the total  
14 load forecast.

15 During the process of training the Nostradamus model, it creates separate submodels  
16 for weekdays, weekends and holidays to account for the variation in customer use of  
17 electricity. Nostradamus has separate holiday groups for statutory holidays and also for  
18 days that are known to have unusual loads, for instance the days between Christmas  
19 and New Years and the school Easter break.

### 20 **1.2.2 Industrial Load**

21 Industrial load (non-conforming) tends to be almost constant, as industrial processes are  
22 independent of weather. Under the current procedure, the power-on-order for each  
23 industrial customer, plus the expected owned generation from Corner Brook Pulp and  
24 Paper (CBP&P), is used as the industrial load forecasts unless System Operations  
25 engineers modify the forecast based on some knowledge of customer loads, for instance  
26 a decrease due to reduced production at CBP&P or a ramp up in load expected at Vale.  
27 Engineers can change the expected load in one or more cells of a seven by twenty-four  
28 grid, or can change the default value to be used indefinitely.

### 29 **1.2.3 Supply and Demand Status Reporting**

30 The forecast peak reported to the Board of Commissioners of Public Utilities (the Board)  
31 on the Daily Supply and Demand Status Report each day is the forecast peak as of 7:20  
32 am. The weather forecast for the next seven days and the observed weather data for  
33 the previous day are input at approximately 5:00 am. Nostradamus is then run every  
34 hour of the day and the most recent forecast is available for reference by System  
35 Operations engineers and the Energy Control Centre operators for monitoring and

1 managing available spinning reserves. The with-in day forecast updates are used by  
2 operators to decide if additional spinning reserve is required in advance of forecast  
3 system peaks.

#### 4 **1.3 Load Forecasting Improvements**

5 Hydro implemented the following changes to the load forecasting process in 2014:

- 6 • Additional training for staff;
- 7 • Updating to the most recent Nostradamus software version;
- 8 • Revised training and verification periods and additional quality control of the  
9 weather data, including the data from January 2014 which will improve the  
10 capability of the model to forecast loads at low temperatures;
- 11 • Adding weather parameters for cloud cover and daylight hours;
- 12 • Modifying actual demand data used in Nostradamus training to remove unusual  
13 system conditions such as significant outages;
- 14 • Changing forecasting processes so that Nostradamus forecasts only utility load  
15 with industrial forecasts done separately;
- 16 • Changing forecasting process to allow adjustments to the generated forecast to  
17 account for unusual system conditions (e.g., to account for an abnormal system  
18 configuration that may result in more or less losses); and
- 19 • Creation of new plots and tables showing the load forecast, spinning reserve,  
20 and available reserve, available on demand to System Operations staff for  
21 managing the system.

22 The changes to the Nostradamus model have eliminated the erratic load shapes that  
23 were present in the forecasts at loads in excess of 1600 MW in January 2014 and  
24 improved the reliability of the peak forecast. In addition, improved model performance  
25 has allowed an increase to hourly updates of the forecast throughout the day;  
26 previously the forecast was updated five times per day.

27 Additional improvements to the forecasting process are planned for 2015, as follows:

- 28 • A further update to the software once it is released by the vendor;
- 29 • A move to twice daily weather forecasting and receipt of observed data which  
30 will improve forecasting of the afternoon peak and the following day; and
- 31 • Monthly accuracy reporting on the weather forecasts from AMEC, which will  
32 improve the understanding of any Nostradamus forecast variance.

1 **1.4 Potential Sources of Variance**

2 Improvements made to the Nostradamus forecasting model and Hydro's processes for  
3 load forecasting have improved the reliability of the load forecasts and it is anticipated  
4 that planned revisions will further improve the accuracy.

5 As with any forecasting, there will be ongoing discrepancies between the forecast and  
6 the actual values. Typical sources of variance in the load forecasting are as follows:

- 7 • Differences in the industrial load forecast from unexpected changes in customer  
8 loads;
- 9 • Inaccuracies in the weather forecast, particularly temperature, wind speed or  
10 cloud cover; and
- 11 • Customer behaviour is not uniform and therefore not completely predictable.

1   **2.    DECEMBER 2014 FORECAST ACCURACY**

2   Table 1 presents the daily forecast peak, the actual peak observed and the available  
3   system capacity, as included in Hydro’s Daily Supply and Demand Status Reports  
4   submitted to the Board for each day in December 2014. The data are also presented in  
5   Figure 1.

6   There were no days in December when System Operations engineers felt it necessary to  
7   make any adjustments to the Nostradamus forecast to account for weather outside the  
8   model’s ability or for unusual system conditions or events.



**Table 1 December 2014 Load Forecasting Data (Rev 1)**


<b>Date</b>	<b>Forecast Peak, MW</b>	<b>Actual Peak, MW</b>	<b>Available Island Supply, MW</b>	<b>Forecast Reserve, MW</b>
1-Dec-14	1225	1217	1500	350
2-Dec-14	1325	1387	1660	410
3-Dec-14	1410	1409	1645	310
4-Dec-14	1250	1174	1750	575
5-Dec-14	1350	1386	1775	500
6-Dec-14	1350	1368	1785	510
7-Dec-14	1275	1275	1680	480
8-Dec-14	1500	1638	1880	460
9-Dec-14	1525	1528	1845	400
10-Dec-14	1350	1379	1870	595
11-Dec-14	1300	1361	1910	685
12-Dec-14	1050	1149	1880	900
13-Dec-14	1075	1094	1880	880
14-Dec-14	1050	1086	1850	870
15-Dec-14	1225	1209	1845	695
16-Dec-14	1325	1417	1840	590
17-Dec-14	1360	1417	1800	515
18-Dec-14	1300	1317	1805	580
19-Dec-14	1260	1287	1850	665
20-Dec-14	1275	1373	1665	465
21-Dec-14	1300	1391	1805	580
22-Dec-14	1450	1455	1855	480
23-Dec-14	1375	1435	1845	545
24-Dec-14	1400	1383	1845	540
25-Dec-14	1325	1339	1865	635
26-Dec-14	1250	1199	1860	705
27-Dec-14	1325	1329	1700	470
28-Dec-14	1325	1344	1870	640
29-Dec-14	1325	1413	1860	630
30-Dec-14	1525	1621	1915	490
31-Dec-14	1600	1664	1850	350

Notes:

Forecast peak, available capacity and forecast reserve are rounded to the nearest 5 MW. Forecast peak and available capacity presented is as reported to the Board. The forecast is updated hourly throughout the day for use in maintaining adequate generation reserves.

Forecast Reserve = Available Island Supply - (Forecast Peak – CBP&P Interruptible load (when applicable) - impact of voltage reduction)

- 1 The observed peaks during December 2014 were between 1086 MW on December 14<sup>th</sup>
- 2 and 1664 MW on December 31<sup>st</sup>. The peaks were above 1600 MW, which would be
- 3 considered a high demand, on three days: December 8<sup>th</sup> (1638 MW), December 30<sup>th</sup>
- 4 (1621 MW), and December 31<sup>st</sup> (1664 MW). It was at loads in excess of 1600 MW in
- 5 January 2014 that the Nostradamus model provided erratic results.
  
- 6 The available capacity during the month was between 1500 MW on December 1<sup>st</sup> and
- 7 1915 MW on December 30<sup>th</sup>. Reserves were sufficient throughout the period.



- 8 Table 2 presents error statistics for the peak forecasts during the month of December.
- 9 Figure 2 is a plot of the forecast and actual peaks, as shown in Figure 1, but with the
- 10 addition of a bar chart showing the forecast errors, the difference between the two data
- 11 series. In both the tables and the figures, a positive error is an overestimate; a negative
- 12 error is an underestimate.

**Table 2 Analysis of Forecast Error**


Date	Actual	Forecast	Error	Absolute			Actual/ Forecast
				Absolute Error	Percent Error	Percent Error	
1-Dec-14	1217	1225	8	8	0.7%	0.7%	0.7%
2-Dec-14	1387	1325	-62	62	-4.5%	4.5%	-4.7%
3-Dec-14	1409	1410	1	1	0.1%	0.1%	0.1%
4-Dec-14	1174	1250	76	76	6.5%	6.5%	6.1%
5-Dec-14	1386	1350	-36	36	-2.6%	2.6%	-2.7%
6-Dec-14	1368	1350	-18	18	-1.3%	1.3%	-1.3%
7-Dec-14	1275	1275	0	0	0.0%	0.0%	0.0%
8-Dec-14	1638	1500	-138	138	-8.4%	8.4%	-9.2%
9-Dec-14	1528	1525	-3	3	-0.2%	0.2%	-0.2%
10-Dec-14	1379	1350	-29	29	-2.1%	2.1%	-2.1%
11-Dec-14	1361	1300	-61	61	-4.5%	4.5%	-4.7%
12-Dec-14	1149	1050	-99	99	-8.6%	8.6%	-9.4%
13-Dec-14	1094	1075	-19	19	-1.7%	1.7%	-1.8%
14-Dec-14	1086	1050	-36	36	-3.3%	3.3%	-3.4%
15-Dec-14	1209	1225	16	16	1.3%	1.3%	1.3%
16-Dec-14	1417	1325	-92	92	-6.5%	6.5%	-6.9%
17-Dec-14	1417	1360	-57	57	-4.0%	4.0%	-4.2%
18-Dec-14	1317	1300	-17	17	-1.3%	1.3%	-1.3%
19-Dec-14	1287	1260	-27	27	-2.1%	2.1%	-2.1%
20-Dec-14	1373	1275	-98	98	-7.1%	7.1%	-7.7%
21-Dec-14	1391	1300	-91	91	-6.5%	6.5%	-7.0%
22-Dec-14	1455	1450	-5	5	-0.3%	0.3%	-0.3%
23-Dec-14	1435	1375	-60	60	-4.2%	4.2%	-4.4%
24-Dec-14	1383	1400	17	17	1.2%	1.2%	1.2%
25-Dec-14	1339	1325	-14	14	-1.0%	1.0%	-1.1%
26-Dec-14	1199	1250	51	51	4.3%	4.3%	4.1%
27-Dec-14	1329	1325	-4	4	-0.3%	0.3%	-0.3%
28-Dec-14	1344	1325	-19	19	-1.4%	1.4%	-1.4%
29-Dec-14	1413	1325	-88	88	-6.2%	6.2%	-6.6%
30-Dec-14	1621	1525	-96	96	-5.9%	5.9%	-6.3%
31-Dec-14	1664	1600	-64	64	-3.8%	3.8%	-4.0%
Minimum	1086	1050	-138	0	-8.6%	0.0%	-9.4%
Average	1356	1322	-34	45	-2.4%	3.3%	-2.6%
Maximum	1664	1600	76	138	6.5%	8.6%	6.1%

Notes:

Forecast peak and available capacity are rounded to the nearest 5 MW

Forecast peak presented is as reported to the Board. The forecast is updated hourly throughout the day for use in maintaining adequate generation reserves.

- 1 Through the month of December the forecast peak was between 9% below actual and
- 2 7% over the actual peak. On the best day the forecast peak was the same as the actual
- 3 peak; on the worst day it was 140 MW too low. On average, the forecast peak was
- 4 45 MW different than the actual peak, or 3.3%.



- 5 In the review of forecast accuracy statistics for December 2014 in Table 2, Hydro offers
- 6 further detail on the differences found between forecast and actual peak for the days
- 7 December 8<sup>th</sup>, when the peak was underestimated by 138 MW, or 8.4%, and December
- 8 12<sup>th</sup>, when the peak was underestimate by 99 MW, or 8.6%.

### 9 **2.1 December 8, 2014**

- 10 On December 8<sup>th</sup>, the peak of the 7:20 am forecast was 1500 MW; the actual peak was
- 11 1638 MW. The absolute difference was 138 MW, 8.4% of the actual. Figure 3 includes
- 12 an hourly plot of the load forecast for December 8<sup>th</sup> as well as several charts which
- 13 examine components of the load forecast to assist in determining the sources of the
- 14 differences between actual and forecast loads.

1 Figure 3(a) shows the hourly distribution of the load forecast compared to the actual  
2 load. The forecast predicted a morning peak of 1500 MW. The actual the morning peak  
3 was 1526 MW, which was close to the forecast. However, the forecast predicted a  
4 lower afternoon peak of 1444 MW but the load actually increased in the afternoon and  
5 peaked at 1638 MW at 5:20 pm (the plot shows a peak of 1622 MW as it was created  
6 with data from Nostradamus which is input on the hour only).

7 Figure 3(b) shows the hourly distribution of the utility load forecast only, i.e., the load  
8 forecast with the industrial component removed. The difference between the forecast  
9 and actual utility loads is similar to that of the total load, so a discrepancy in the  
10 industrial forecast does not explain the variance in the peak.


11 Figure 3(c) shows the actual temperature in St. John's compared to the forecast.  
12 Although Nostradamus uses weather data at four sites, the weather in St. John's tends  
13 to have the largest effect because of the concentration of customers in St. John's. The  
14 temperature was forecast to be approximately two degrees higher during the morning  
15 peak than it actually was, but later in the day the temperature forecast was quite good  
16 so a variance in the temperature forecast does not explain the difference in the peak.

17 Figure 3(d) shows the actual cloud cover in St. John's compared to the forecast. For  
18 most of the day, the weather was cloudier than forecast. Later in the afternoon, the  
19 forecast predicted that skies would be clear (0% cloud) but the cloud cover was  
20 recorded at 80%. When the weather is sunny, the solar radiation warms peoples'  
21 homes and people tend to feel the cold less, so the absence of the forecast sunshine  
22 likely contributed to the discrepancy in the forecast.

23 Figure 3(e) shows the actual wind speed in St. John's compared to the forecast. For  
24 most of the day the actual wind speed was lower than predicted so a variance in the  
25 wind speed forecast does not contribute to the difference in the peak.

26 The Nostradamus model runs every hour to use actual loads experienced that day to  
27 improve the estimate for the rest of the day. By the mid-day update, the forecast peak  
28 for December 8<sup>th</sup> was 1590 MW, 32 MW, or 2% below actual. The updates are used by  
29 operators to manage spinning reserve.

Figure 3 Accuracy Analysis - December 8, 2014



1   **2.2   December 12, 2014**

2   On December 12<sup>th</sup> the peak of the 7:20 am forecast was 1050 MW; the actual peak was  
3   1149 MW. The absolute difference was 99 MW, 8.6% of the actual. Variances in the  
4   forecast at lower peaks are generally less of a concern to System Operations because  
5   reserves are likely higher during periods of lower peaks.

6   Figure 4 includes an hourly plot of the load forecast for December 12<sup>th</sup> as well as several  
7   charts which examine components of the load forecast to assist in determining the  
8   sources of the differences between actual and forecast loads.

9   Figure 4(a) shows the hourly distribution of the load forecast compared to the actual  
10   load. The shape of the actual load was very similar to the forecast but was consistently  
11   approximately 90 MW higher.

12   Figure 4(b) shows the hourly distribution of the utility load forecast only, i.e., the load  
13   forecast with the industrial component removed. The difference between the forecast  
14   and actual utility loads is similar to that of the total load, so a variance in the industrial  
15   forecast does not explain the difference in the peak.

16   Figure 4(c) shows the actual temperature in St. John's compared to the forecast. The  
17   temperature was forecast to be somewhat higher than it was so the discrepancy in the  
18   temperature forecast may contribute somewhat to the variance in the peak.

19   Figure 4(d) shows the actual cloud cover in St. John's compared to the forecast. The  
20   cloud cover forecast was quite accurate so did not contribute to the variance in the load  
21   forecast.

22   Figure 4(e) shows the actual wind speed in St. John's compared to the forecast. The  
23   wind speed forecast was quite accurate so did not contribute to the difference in the  
24   load forecast.

25   It is difficult to ascertain why Nostradamus consistently underestimated the load  
26   forecast on December 12, 2014. The weather forecast was quite accurate for the  
27   parameters that Nostradamus uses and the forecast of industrial load was good. Other  
28   factors, not modelled by Nostradamus could have increased the load that day, for  
29   instance wind direction, precipitation, or human behaviour.

30   The Nostradamus model runs every hour to use actual loads experienced that day to  
31   improve the estimate for the rest of the day. By the mid-day update, the forecast peak  
32   for December 12<sup>th</sup> was 1098 MW, 51 MW, or 4.5% below actual. The updates are used  
33   by operators to manage spinning reserve.

Figure 4 Accuracy Analysis - December 12, 2014

