

- 1 **Q: Reference: *Review of Newfoundland and Labrador Hydro Power Supply***
2 ***Adequacy and Reliability Prior to and Post Muskrat Falls Final Report, Page 76.***
3
4 *"In the post-HVdc case, Teshmont assumed that the Maritime Link would*
5 *instantly change from export of power from the IIS to import of 300 MW of power*
6 *to the IIS, but this is likely to be unacceptable to the Nova Scotia power system."*
7
8 **Has this issue of major importance to the Project been discussed with**
9 **Teshmont? And if so, what were the conclusions of such discussions?**
10
11
12 **A.** The notion that power flow over the Maritime Link can be instantaneously reversed
13 to provide the necessary standby capacity to the IIS has now been recognized as
14 incorrect. Please see Hydro's response to PUB-NLH-512 which states on page 2:
15
16 *"As a result, discussions with Nova Scotia have resulted in the concept of*
17 *instantaneous power reversal on the Maritime Link as unacceptable".*
18
19 In addition, please see Page 103, Footnote 204 of the Liberty report.
20
21 Liberty has not had any discussions with Teshmont on any topic.