



APPROVED BY D. DIAMOND	NEWFOUNDLAND AND LABRADOR HYDRO	DWG. No.	304D
DRAWN BY D.R.	PORT HOPE SIMPSON DIESEL PLANT		
REVISION No. 13			
DATE 2016/09/26			

Note: Although Unit 2044 is connected to the Port Hope Simpson diesel system, it is designated as a mobile genset and could be relocated. At any given time, this mobile genset could be deployed to another diesel plant in the event that additional generation is required. Therefore, Unit 2044 is not considered in the firm capacity of the Port Hope Simpson Diesel Plant.