



NOTE:
*UNIT 2087 DE RATED TO 500KW
BECAUSE OF INSUFFICIENT BREAKER
SIZE.

APPROVED BY D. DIAMOND	NEWFOUNDLAND AND LABRADOR HYDRO	DWG. No.	305D
DRAWN BY D.R.	CHARLOTTETOWN		
REVISION No. 1B	DIESEL PLANT		
DATE 2016/04/11			