

1 Q. **Project C-8: Water System Replacements, Bay d’Espoir and Cat Arm**

2 With reference to page C-9, Domestic Water System-CAT, has Hydro considered any
3 alternatives to the replacement of the Domestic Water System for this facility?

4

5

6 A. With nearly zero parts per million of chlorine in the water and restricted water flow
7 rate due to pipe fouling and rusting, Hydro personnel judged the only viable
8 corrective action was to replace the existing system. Therefore, no alternatives
9 were considered.