

-
- 1 Q. **Project C-24: Upgrade Ventilation in Powerhouse #1 and #2, Bay d-Espoir**
- 2 Please provide further information with respect to any cost recovery by the reduced
- 3 need for forced air heaters and power consumption.
- 4
- 5
- 6 A. Hydro estimates the redirection of waste heat will result in forced air heating
- 7 annual energy savings of 762,000 kWh equating to an average annual nominal
- 8 savings of approximately \$60,000 per year over 25 years as this is the useful life of
- 9 the assets.