

1 Q. **Tab 1; Volume II: Hydraulic Generation Refurbishment and Modernization (2018-**
2 **2019)**

3 Page 5, Section 2.1.3 (Replace/Improve Unit Metering, Monitoring, Protection, and
4 Control Assets) Hydro proposes to replace the condition monitoring equipment for
5 Units 1, 2, 3, 4, and 5. Has the condition monitoring equipment been previously
6 replaced on Unit 6 and Unit 7 or is this planned to be completed at a later date?

7

8

9 A. The condition monitoring equipment was previously replaced on Unit 6
10 (2013/2014) and Unit 7 (2015/2016).