

1 Q. **Tab 4; Volume II: Install Plant Heating System (Holyrood Thermal Generating**  
2 **Station)**

3 Is the plant heating system required for the continued operation of the Holyrood  
4 Gas Turbine?

5

6

7 A. The proposed Holyrood Thermal Generating Station Plant Heating System is not  
8 required for the continued operation of the Holyrood Gas Turbine itself, as the Gas  
9 Turbine resides in a separate building with its own heat source and water supply.

10 However, the Holyrood Plant's fire water supply system serves the full site,

11 including the Holyrood Gas Turbine. Heating elements of that shared system, such

12 as the fire pumps, would be addressed as necessary inside the Plant Heating System

13 project.