

1 **IN THE MATTER OF**
2 the *Electrical Power Control Act, 1994*,
3 SNL 1994, Chapter E-5.1 (the “*EPCA*”)
4 and the *Public Utilities Act, RSNL 1990*,
5 Chapter P-47 (the “*Act*”), as amended, and
6 regulations thereunder; and
7
8
9 **IN THE MATTER OF** Newfoundland and
10 Labrador Hydro’s Reliability and Supply
11 Adequacy Study.

**PUBLIC UTILITIES BOARD
REQUESTS FOR INFORMATION**

PUB-NLH-080 to PUB-NLH-179

Issued: June 30, 2020

- 1 **Newfoundland and Labrador Hydro - EFLA Consulting Engineers Report - *Structural***
2 ***Capacity Assessment of the Labrador Island Transmission Link, April 30, 2020* (“EFLA”**
3 **Report)**
4
- 5 **PUB-NLH-080** With respect to LIL design modeling performed as part of the analysis
6 underlying the April 30, 2020 EFLA report, please describe the nature, extent,
7 methods, and documents and data reviewed by EFLA to verify the original
8 SNC-Lavalin design load models in any way. If verification did not occur,
9 explain whether there is and how there is an adequate basis for assuming that
10 those load models were appropriately designed and executed.
11
- 12 **PUB-NLH-081** Please list and explain the basis for all April 30, 2020 EFLA report assumptions
13 that differed from those made by SNC-Lavalin with respect to LIL design. For
14 any specific assumptions addressed in responses to other requests for
15 information at a level sufficient to satisfy this request, please note the relevant
16 response number.
17
- 18 **PUB-NLH-082** With respect to comments by Hydro at the June 4, 2020 Technical Conference
19 addressing as-designed versus as-built LIL characteristics and structural
20 capabilities, please describe the efforts made by Hydro and the detailed
21 documentation that support a conclusion that as-built structural capacities of all
22 LIL line sections and components are the same as “as-designed.”
23
- 24 **PUB-NLH-083** With respect to comments by Hydro at the June 4, 2020 Technical Conference,
25 please state whether it has been confirmed that all LIL line sections and
26 components have as-built structural capacities at least equal to their as-designed
27 capacities with respect to wind and ice loadings.
28
- 29 **PUB-NLH-084** With respect to comments by Hydro at the June 4, 2020 Technical Conference,
30 please describe the types and extent of documentation or other evidence now
31 existing that demonstrates for each location the performance of inspections
32 made, the nature of the inspections, and application to each element of tower
33 structure, conductors, hardware, insulators, guys, anchors, and foundations in
34 determining compliance with the design specifications and drawings used for
35 the study.
36
- 37 **PUB-NLH-085** Please state all identified deviations from the LIL designs and specifications
38 that were corrected (such as re-tightening bolts); and not corrected (such as the
39 removal of a conductor strand).
40
- 41 **PUB-NLH-086** Please provide documentation listing differences in tower locations and
42 construction, conductors, hardware, insulators, guys, anchors, and foundations
43 between “as-designed” and “as-built,” and verify that each of these differences
44 have been considered in the EFLA study.

- 1 **PUB-NLH-087** Please explain the details of how ongoing LIL reliability studies Hydro cited at
2 the June 4 technical session and to be filed with the Board by November 15,
3 2020 will amass, localize, categorize, analyze, and report on the impacts of local
4 climatological conditions in assessing LIL return periods.
5
- 6 **PUB-NLH-088** With respect to use of CSA Standards in performing analyses addressed in the
7 April 30, 2020 EFLA report, please confirm that EFLA made no use of
8 climatological condition values other than those standard values provided in the
9 standards. If not confirmed, provide a complete list of where and how localized,
10 actual climactic data was used and the sources for such data.
11
- 12 **PUB-NLH-089** With regard to Hydro’s ongoing LIL reliability studies (referred to at the June
13 4 technical conference) and to be filed with the Board by November 15, 2020,
14 please confirm that Hydro is performing another assessment considering glaze
15 ice data that is based on local climatological data; *i.e.*, different from the glaze
16 ice data underlying the results presented in the April 30, 2020 EFLA report, and
17 provide a description of the efforts, data sources, and use that such an
18 assessment will employ. If not so confirmed please explain why not.
19
- 20 **PUB-NLH-090** Further to PUB-NLH-089 provide the currently expected date of availability of
21 the assessment results and Hydro’s understanding of the major risks that this
22 date will not be met, and Hydro’s confidence level that it will be met.
23
- 24 **PUB-NLH-091** Please describe in detail the purpose, methods, data collection and assessment
25 activities, and intended use of local topographical conditions in the ongoing LIL
26 reliability studies Hydro referenced at the June 4 technical conference and
27 which is to be filed by November 15, 2020.
28
- 29 **PUB-NLH-092** Regarding the April 30, 2020 EFLA report, page 26, statement about excluding
30 load cases related to security level and safety level from the EFLA study,
31 please:
32 a. Confirm that security and safety requirements are critical for reliability
33 (cascading prevention) or safety (maintenance safety).
34 b. Describe the reasons for excluding security and safety related load cases
35 from the EFLA study.
36 c. Describe the scope, extent, and date for completion of any planned study
37 of load cases pertaining to security (cascading) and safety. If none are
38 planned explain why not.
39 d. State if, and if so, when Hydro or EFLA intends to conduct studies related
40 to the conditions that would cause cascading, and safety hazards during
41 maintenance operations.
42 e. State whether the scheduled November 15, 2020 reliability study report is
43 intended to address the results of load cases related to security and safety
44 level. If not intended for inclusion in the November 15, 2020 report,
45 explain.

- 1 **PUB-NLH-093** Please see Footnote 12 of the April 30, 2020 EFLA report, noting that “tension
2 towers were designed for extreme unbalanced ice with full load on one side and
3 no conductor on the other side, for one conductor at a time.” Please provide the
4 data and analysis supporting this statement, and describe and explain why or
5 why not tension towers are designed to remain intact when subjected to impact
6 forces from sudden breaks of one conductor with full ice load.
7
- 8 **PUB-NLH-094** With reference to pages 26 and 27 and Footnote 11 of the April 30, 2020 EFLA
9 report, please:
10 a. Explain the justification for excluding unbalanced ice loads.
11 b. Explain the justification for assuming that wind directions are transversal,
12 45 degrees, or longitudinal to spans, thus excluding other possible worse
13 case wind directions and unbalanced ice formations.
14 c. State whether global wind directions and unbalanced ice loads will be
15 addressed in the November 15, 2020 reliability report. If not, explain.
16
- 17 **PUB-NLH-095** Regarding footnote 13 of the April 30, 2020 EFLA report, please state whether
18 detailed load analyses of the ends of overlapping sections will be completed
19 and included in the November study report. If not, explain why not.
20
- 21 **PUB-NLH-096** With respect to detailed study and analysis of expected LIL restoration, please
22 state whether and if so when, Hydro or Nalco plans a detailed study and analysis
23 of expected LIL restoration times under combinations of extreme conditions,
24 such as the following, considering activities required of all groups involved,
25 including work and time required details of each activity or group of activities
26 (including at least equipment and human resource marshalling, transit and work
27 set-up time, and restoration completion and verification):
28 • Midnight outage to full restoration of monopole bipole service
29 • 10 feet of snow cover
30 • High winds impairing helicopter access to affected line segments
31 • Most remote line location
32 • One downed support structure
33 • Multiple downed support structures at the same location
34 • Concurrent downed support structures at different locations
35
- 36 **PUB-NLH-097** Further to PUB-NLH-096 provide Hydro’s views on whether the assumptions
37 listed are reasonable to postulate as worst-case circumstances. If not provide
38 Hydro’s view as to such worst-case circumstances. If no such study is planned
39 in the near term, explain why not.
40
- 41 **PUB-NLH-098** With respect to Hydro’s cover letter for the April 30, 2020 EFLA report,
42 describing “unsurprising” differences between the results of expert opinion in
43 the EFLA report and that previously provided, please summarize the principal
44 areas of divergence in the opinions being referred to, and describe the primary
45 contributing factors in the areas summarized.

- 1 **PUB-NLH-099** Further to PUB-NLH-098 with respect to Hydro’s cover letter for the April 30,
2 2020 EFLA report, referring to a Halder & Associates study, please explain in
3 as much detail as is available the scope of the study and provide any
4 documentation that describes the scope.
5
- 6 **PUB-NLH-100** Further to PUB-NLH-099 explain what specific results from the EFLA study
7 will be used and how in the Halder study.
8
- 9 **PUB-NLH-101** With respect to the April 30, 2020 EFLA report’s Study Summary citation, page
10 5, that the “goal was to use loading specified in the CSA without a special study
11 of local conditions” and “it was not part of this study to review or verify PLS-
12 CADD and PLS-Tower models made by the designers,” please identify all the
13 unstudied local conditions that the CSA considers appropriate for consideration
14 in the design of facilities like the LIL.
15
- 16 **PUB-NLH-102** Further to PUB-NLH-101 describe efforts to review and verify any such models
17 used to provide data or analysis for EFLA’s use in this study.
18
- 19 **PUB-NLH-103** With respect to the phrase “the design exceeded some of the basic requirements
20 in the standard” cited on page 5 of the April 30, 2020 EFLA report, please:
21 a. Explain in detail what is meant by this statement.
22 b. Define specifically what those requirements are and where they are cited
23 or explained in the standard.
24 c. Explain qualitatively and for all cases if, where, and how requirements
25 other than these were applied.
26 d. Provide a table listing all quantified values comprising these basic
27 requirements and provide in that table a one-to-one comparison of all
28 values other than those comprising these basic requirements used in
29 assessing LIL structural capacities as part of the EFLA analysis.
30 e. Identify where in the study report return periods or other quantified
31 measures of LIL structural capacities with respect to wind and ice
32 loadings are presented. If not so presented, provide them measured against
33 all values (basic requirements and others) analyzed as part of the EFLA
34 work, at the greatest level of detail (tower, conductor, and any others
35 employed) analyzed.
36
- 37 **PUB-NLH-104** With respect to the statements set forth in the three bullets beginning near the
38 bottom of page 5 of the April 30, 2020 EFLA report, please:
39 a. Define methodologically and quantitatively what specifically is meant by
40 the “approach” indicated under the first bullet, associated with design of
41 the LIL.
42 b. Provide the specific ice values used under the “same approach cited” and
43 provide their source.
44 c. Define specifically, provide the values, and cite the source for what are
45 termed “CSA recommendations” and explain the basis for concluding that
46 the CSA has opined that such values are “recommended.”

- 1 d. Provide the best available quantitative measures of how EFLA defined
 2 “realistic” and “probable” recognizing, for example that the latter can
 3 mean 51 percent.
 4 e. Identify and provide the values set forth in all sources of information
 5 considered by EFLA in analyzing ice and wind conditions specific to
 6 particular tower and conductor locations.
 7 f. Cite the locations in the EFLA report that show return periods or other
 8 structural capacity measures under such localized conditions, and, if
 9 EFLA has performed analysis using such conditions, but not included
 10 them in the report, provide them.
 11 g. Provide the exceedance utilization level EFLA does consider “critical”
 12 and explain in detail if and whether any level less than qualifying as
 13 critical is material to assessing tower and conductor structural capacity.
 14 h. Define “should not” as used in the second bullet and provide and support
 15 EFLA’s” judgment about the likelihood (expressed as quantitatively as
 16 possible) of breakage or outage.
 17 i. Provide and quantify what EFLA considers “normal design practice,”
 18 indicated under the third bullet, with respect to electrode conductor
 19 suspension hardware.
 20 j. Define as quantitatively as possible “marginal increase” with respect to
 21 failure of such hardware, and identify as particularly and quantitatively as
 22 possible the amount of increase EFLA considers as present.
 23

24 **PUB-NLH-105** With respect to the last statement on page 6 of the April 30, 2020 EFLA report,
 25 please describe with specificity what consideration remains to be given to the
 26 “above-mentioned exceptions,” and describe in detail EFLA’s view on the
 27 means, analyses, criteria, and other aspects warranting such consideration.
 28

29 **PUB-NLH-106** With respect to the April 30, 2020 EFLA report’s page 11 reference to “the
 30 operational experience and special studies” used in “original design of the
 31 LITL,” please:
 32 a. Confirm that such original design conforms in all material respects to the
 33 “as-designed” LIL basis examined by EFLA.
 34 b. Describe the documents that comprise the studies cited.
 35 c. Identify all ice and wind conditions identified by those studies and used
 36 in such original design.
 37

38 **PUB-NLH-107** With respect to benchmarking “against the 50, 150 and 500-years return period
 39 loadings provided in the CSA 60826-10 standard”, page 11 of the April 30,
 40 2020 EFLA Report, please:
 41 a. Provide EFLA’s opinion and explanation of what consideration applying
 42 good utility practice (or alternative definition of the standard EFLA
 43 considers appropriate in design of overhead lines serving purposes like
 44 those of the LIL and define any such alternative standard applied) should
 45 be given to localized wind and ice conditions in assessing return periods.

- 1 b. With respect to the use of 50, 150, and 500 year return periods, provide
2 and explain EFLA’s opinion on which should apply to the LIL, given its
3 purposes and intended operation, and explain the reasons for its selection.
4
- 5 **PUB-NLH-108** Regarding references to the EFLA study’s non-addressing of “construction
6 quality and effects of component fatigue” and review of “detailed engineering
7 work undertaken in design of the LITL transmission line” (page 12), please
8 describe the timing, nature, and results of any studies, analyses or other work
9 performed by or for Hydro/Nalcor with respect to excessive aeolian vibration
10 or galloping conductors on the LIL.
11
- 12 **PUB-NLH-109** With respect to the statement on page 12 of the April 30, 2020 EFLA report that
13 EFLA’s analysis was not “intended to review, verify, or audit the detailed
14 engineering work undertaken in design of the LITL transmission line; please
15 describe in detail what examination EFLA did undertake of engineering work
16 and describe the results of such examination as was undertaken.
17
- 18 **PUB-NLH-110** With respect to the statement on page 12 of the April 30 EFLA report, describe
19 each principal category, conclusion, or analysis influencing initial design that
20 EFLA did examine, assess, reconfirm, or otherwise test and each principal
21 category of judgment, conclusion, or analysis influencing initial design on
22 which EFLA relied and which were material to its conclusions about return
23 periods.
24
- 25 **PUB-NLH-111** Page 23 of the April 30, 2020 EFLA report observed that Hydro provided “as-
26 built” line profiles for the study. Please describe how Hydro developed the as-
27 built profiles and how the as-built profiles were used in the EFLA study.
28
- 29 **PUB-NLH-112** With respect to the April 30, 2020 EFLA report’s page 23, statement about
30 modifications to the tower analyses made to the PLS-CADD and PLS-Tower
31 models used for the original design, please provide further description of the
32 reasons for these modifications and the nature and magnitude of their effects on
33 study results, with respect to:
- 34 • Using the PLS-Cadd option “IEC 60824.2017F, rather than using “wind
35 on face” as used in the design.
 - 36 • Reducing the stiffness of a few elements in seven suspension towers by a
37 factor of 10.
 - 38 • Improvements made to modeling the earth wire peak in tower 1219.
39
- 40 **PUB-NLH-113** With respect to the April 30, 2020 EFLA report’s page 24, statement that
41 “Allowable conductor tension limits were verified in all sections using the same
42 settings from the “as-designed” in using the ruling span concept analysis in the
43 PLS-CADD” please:
- 44 a. Confirm that incorrect ruling spans (average span length between tension
45 towers) used can cause either excessive sag or excessive tension, and if
46 cannot be confirmed explain why not.

- 1 b. Describe how actual “as-built” ruling spans for each line section were
 2 verified to be the same as the “as-design” ruling spans.
 3 c. State whether any “as-built” ruling span lengths were different from “as-
 4 design” ruling span lengths, and were any changes considered in the
 5 study.
 6 d. Describe whether and how the reported removal of a strand in the “as-
 7 built” conductor was considered for determining tension limits for that
 8 LIL line section.
 9

10 **PUB-NLH-114** Regarding footnotes 11 through 14 of the April 30, 2020 EFLA report, please
 11 explain in more detail why the following assumptions and simplifications
 12 indicated on pages 26 and 27 were made for the study and whether and how
 13 each assumption or simplification might allow conditions for higher risk of LIL
 14 component failure:

- 15 a. Use of assumptions from design unless conflicting with CSA standard
 16 (and indicate where the LIL design assumptions differed from the CSA
 17 standard).
 18 b. Ice load on tower members assumed the same as radial ice on conductor
 19 (and indicated whether this is worst case, and if not, why this assumption
 20 was made).
 21 c. Load cases contain only uniform ice formation (and indicate whether this
 22 is worst case, and if not, why this assumption was made).
 23

24 **PUB-NLH-115** With respect to the April 30, 2020 EFLA report’s page 27 listing of the
 25 following sources of data used to establish the design load conditions included
 26 CSA Standards:

- 27 • A study of glaze ice undertaken by Cold Regions Research and
 28 Engineering Laboratory.
- 29 • Studies made by Landsvirkjun Power which evaluated rime (or in-cloud)
 30 ice loadings
- 31 • Hydro’s nearly 50-year operating history along the transmission line route
- 32 • Measurements in test spans at LRM that measure rime icing
- 33 • Studies completed by Meteorology Research, Inc., Teshmont, and RSW
- 34 • Climatic Monitoring Program from 1973-1987 concerning transport
 35 power to Newfoundland from the proposed Gull Island Project
 36 measurements and monitoring programs

37 Please:

- 38 a. Indicate how data from each of these data sources were used to influence
 39 or modify the glaze ice and wind data indicated in Table 14 of the EFLA
 40 report.
 41 b. Address how these sources are intended to be used in the ongoing analysis
 42 for the reliability report scheduled to be filed by November 15, 2020.
 43

44 **PUB-NLH-116** With respect to these sources of data cited on page 27 of the April 30, 2020
 45 EFLA report, please identify any others considered, how they were considered,

1 and what adjustments to wind and glaze ice data they produced for the EFLA
2 analysis.

- 3
4 **PUB-NLH-117** With respect to use of localized wind and ice loadings, please:
- 5 a. Provide and explain EFLA's opinion and explanation thereof about what
6 types of sources are appropriate for consideration in design of a facility
7 serving the purposes of and having the physical characteristics (describing
8 those characteristics that are material) of the LIL.
 - 9 b. Provide and explain EFLA's understanding of what specific sources are
10 available to do so for the corridor traversed by the LIL.
 - 11 c. Provide and explain EFLA's understanding of how initial design did
12 account for and employ such consideration and where it produced
13 uniquely determined (versus CSA-provided) values.

- 14
15 **PUB-NLH-118** With respect to the bullets beginning at the bottom of page 28 of the April 30,
16 2020 EFLA report and continuing through the top of page 29, please explain in
17 detail the responsibility, bases, and calculations and values used for:
- 18 a. Determining whether glaze or rime ice was controlling for each loading
19 zone.
 - 20 b. Assessing the contribution of wind conditions in making that
21 determination.
 - 22 c. The Category B and Category C determinations.
 - 23 d. Determining from local conditions that wind speeds for 8 LIL zones in
24 Table 14 were increased.
 - 25 e. Determining to increase wind speed for zones 7a, 7b, and 7c were
26 increased by 1.64 compared to the CSA standard.
 - 27 f. Increases in wind speed in zones 5 and 9 (was not 1.64, but what was it),
28 and based on what data.
 - 29 g. Not considering topography in other zones.

- 30
31 **PUB-NLH-119** With respect to air density factor addressed at page 29 of the April 30, 2020
32 EFLA report, please:
- 33 a. Explain why the values of air correction factors used by the designers
34 were different than CSA air correction factors.
 - 35 b. State which the EFLA analysis used: CSA, LIL design basis, or other
36 (explain if other).
 - 37 c. How choosing the other would affect return period measures.

- 38
39 **PUB-NLH-120** With respect to the April 30, 2020 EFLA report's page 28 discussion of
40 assuming all icing to be radial, please:
- 41 a. Provide the basis for making this assumption.
 - 42 b. Describe circumstances that have material potential for producing non-
43 radial accumulation.
 - 44 c. Explain whether non-radial accumulation has the potential for magnifying
45 the impact of the accumulation.

- 1 **PUB-NLH-121** With respect to the statement on page 31 of the April 30, 2020 EFLA report
 2 that, “It was not part of this study to assess the suitability of the terrain category
 3 selection or local wind effects used in the design assumption for the LITL”
 4 please:
 5 a. Describe why the terrain categories selected by the designers were not
 6 verified in the EFLA study.
 7 b. Provide a depiction of the categories and a list of their mileages for the
 8 DESIGN loading.
 9 c. Provide Hydro’s comparison of that categorization and those mileages
 10 with expected terrain conditions assuming anticipated vegetation
 11 management methods.
 12

- 13 **PUB-NLH-122** With respect to the April 30, 2020 EFLA report statement at page 31 that, “the
 14 effects of acceleration due to funneling between hills or due to sloping grounds
 15 are not covered and may require specific studies to assess such influences”
 16 please:
 17 a. Please describe any specific funneling studies prepared as part of LIL
 18 design, the EFLA study, or otherwise.
 19 b. If no such studies have occurred, please explain the reasons and assess the
 20 impact of their absence on the confidence that can be placed in the results
 21 of the EFLA analysis.
 22

23 **Newfoundland and Labrador Hydro – Near-Term Reliability Report, May 15, 2020**

24 ***Demand Forecast***

- 25
 26
 27 **PUB-NLH-123** Please provide a comparison of forecast values for IIS customer coincident
 28 demand in MW and IIS forecast energy requirement in GWh, for all scenarios
 29 and all years covered by the forecast, for the following reports and studies:
 30 a. Near-Term Reliability Report – May 2020.
 31 b. Reliability and Resource Adequacy Study 2019 Update.
 32 c. Near-Term Generation Adequacy Report, May 15, 2019.
 33 d. 2018 Reliability and Resource Adequacy Study.
 34

- 35 **PUB-NLH-124** With respect to IIS customer coincident demand, please:
 36 a. Confirm or provide the corrected values if not confirmed that the actual
 37 IIS utility demand (1,549 MW) in winter 2018-2019 exceeds both the P50
 38 (1,478 MW) and P90 (1,539 MW) forecasts for that year, as presented in
 39 the November 2019 RRAS update.
 40 b. Explain the causes of the high actual demand in terms of how the key
 41 drivers of the forecast compared to the actual values that year.
 42 c. Provide an explanation and analysis of how the May 15, 2020 report
 43 forecasts considered and differ from 2019-2020 winter period actual
 44 demands.

- 1 **PUB-NLH-125** Page 13 of the Near-Term Reliability Report, May 15, 2020 states that,
 2 “Hydro’s forecast annual peak demand requirements for the Newfoundland
 3 Power system are approximately 40-50 MW higher than the peak demand
 4 forecast provided by Newfoundland Power.” Please provide an analysis of the
 5 causes of the difference between Hydro’s forecasts in its May 2020 report and
 6 the lower ones of Newfoundland Power.
 7
- 8 **PUB-NLH-126** Please provide a P90 forecast for the coming winter.
 9
- 10 **PUB-NLH-127** With respect to present, extended, and potential resumed application of
 11 COVID-19 circumstances, restrictions, and guidance, please:
 12 a. Confirm that their application during the winter season can have
 13 implications that may cause a material impact on peak loads for this
 14 season. If not so confirmed explain why not.
 15 b. Describe whether Hydro has collected during the existence of current
 16 COVID-19 circumstances, restrictions, and guidance demand and usage
 17 data available and suitable for use in examining changing use and demand
 18 patterns.
 19 c. Provide the results of any study or analysis that Hydro has performed to
 20 address usage and demand impacts of COVID-19 circumstances,
 21 restrictions, and guidance. Also provide the scope, activities, questions to
 22 be answered, and schedule of any such study no underway or
 23 contemplated.
 24 d. Summarize Hydro’s knowledge, understanding, and perspectives and
 25 views about industry writings, studies, or analyses of the impact of
 26 COVID-19 circumstances, restrictions, and guidance on customer usage
 27 and demand.
 28
- 29 **PUB-NLH-128** With respect to possible joint discussions, information gathering and sharing,
 30 and dialogue with Newfoundland Power, please:
 31 a. State and explain Hydro’s views on whether such joint initiatives may
 32 have significant potential for gaining useful understanding about usage
 33 and demand impacts of COVID-19 circumstances, restrictions, and
 34 guidance.
 35 b. If they may, describe if, and if so how, such joint efforts might be expected
 36 to provide useful information (and the earliest realistic dates for doing so)
 37 for consideration in the Board’s Reliability and Resources Adequacy
 38 Study review.
 39
- 40 *Measures of Load Loss*
 41
- 42 **PUB-NLH-129** Regarding the results shown in Table 6, page 17 of the Near-Term Reliability
 43 Report, May 15, 2020, on a calendar year basis, please provide Hydro’s views
 44 on the usefulness of presenting the results on the basis of a 12-month period
 45 that keeps the months of November through April together, given that one of

- 1 the assumptions required to be employed would have the LIL in service shortly
 2 thereafter.
 3
- 4 **PUB-NLH-130** Please provide LOLE results corresponding to the scenarios and periods in
 5 Tables 6 through 11, Near-Term Reliability Report, May 15, 2020. (Note:
 6 Monthly numbers can be calculated by taking the sums over all days in each
 7 month of the Average Unserved Energy Hours in the peak hours of the day. If
 8 another approach is in Hydro's view more appropriate, please (in addition to
 9 responding as noted in this request) describe it and provide the results of
 10 employing it.
 11
- 12 **PUB-NLH-131** With respect to the scenarios in Section 6.0: Results, Near-Term Reliability
 13 Report, May 15, 2020, please:
 14 a. Provide the dates on which each of the Muskrat Falls units was assumed
 15 to be available in those scenarios.
 16 b. Clarify whether the LIL was assumed to be completely unavailable in
 17 winter 2020-2021 in any of the scenarios reported.
 18 c. If there were such scenarios, identify them.
 19 d. If there was no scenario reported in Section 6.0 in which the LIL was
 20 assumed to be completely unavailable in winter 2020-2021, provide
 21 results for a variation of scenario S1 in which LIL availability is zero.
 22
- 23 **PUB-NLH-132** Please explain why or why not near-term reliability should be evaluated against
 24 the $LOLE \leq 0.1$ days/year criterion.
 25
- 26 *Maritime Link Imports*
 27
- 28 **PUB-NLH-133** Please describe efforts and results of efforts and who has made them to secure
 29 firm power purchase agreements for any period with a duration of one month
 30 or longer.
 31
- 32 **PUB-NLH-134** Please describe efforts to secure firm power purchase agreements for any period
 33 with a duration of one month or longer during any part of the November-April
 34 2019-2020 period over the Maritime Link.
 35
- 36 **PUB-NLH-135** Please describe the reasons (focusing on both firmness and economy) why no
 37 firm power purchase agreement with a duration of one month or longer over the
 38 Maritime Link was secured in winter 2019-2020.
 39
- 40 **PUB-NLH-136** Please outline the efforts (and results) Hydro has undertaken or that have been
 41 undertaken for Hydro to secure a firm power purchase agreement for any
 42 portion of the November-April 2020-2021 period over the Maritime Link.
 43
- 44 **PUB-NLH-137** Please describe market and regional supply/demand conditions as they affect
 45 the likelihood for securing a firm power purchase agreement for any period in
 46 winter 2020-2021 over the Maritime Link.

1 **PUB-NLH-138** Please describe Hydro's and Nalcor's understanding of the
 2 coincidence/difference between expected peak loads of the IIS and Nova Scotia
 3 Power systems and of the relationship between Nova Scotia Power's supply
 4 resources and demand (and those of other relevant market participants) at its
 5 expected winter peak period for the coming and the following winter and relate
 6 that understanding to confidence levels with respect to the availability of supply
 7 over the Maritime Link during peak conditions.
 8

9 ***Hydro Electric Energy Storage***

10
 11 **PUB-NLH-139** Refer to the Section 5.0, System Energy Capability, Near-Term Reliability
 12 Report, May 15, 2020, statement that, "Hydro is establishing minimum storage
 13 limits to April 30, 2021 in consideration of potential delays in the availability
 14 of the LIL to deliver energy to the IIS." Please describe: the modeling process
 15 and how it accounts for and produces differences based on assumptions about
 16 LIL availability and what difference those assumptions make.
 17

18 **PUB-NLH-140** With respect to developing information, performing analyses, and making
 19 decisions about water limits and their effects on day-to-day use of Hydro's
 20 hydro units, please:
 21 a. Describe in detail the roles played by Hydro, Nalcor Energy Marketing,
 22 and other Nalcor personnel and contracted resources.
 23 b. Identify the groups and the lead personnel from each of those
 24 organizations involved.
 25 c. Identify key decisions that affect such day-to-day use.
 26 d. Identify the organizations and the lead persons with direct accountability
 27 and responsibility for making such decisions.
 28

29 **PUB-NLH-141** Please describe with detail the measures that ensure Hydro's ability to
 30 maximize use of its hydro resources to ensure reliability, given Nalcor Energy
 31 Marketing's role in managing Hydro's hydro resources.
 32

33 **Other Near-Term Issues**

34
 35 **PUB-NLH-142** How many test failures occurred in the Factory Acceptance Test (FAT) that
 36 finished on May 1, 2020?
 37

38 **PUB-NLH-143** With regard to the FAT setup and circumstances, please:
 39 a. Describe the ac networks to which the LIL was connected during the FAT;
 40 addressing the different system configurations used at the connection
 41 points of the MF converter and at the Soldiers Pond converter.
 42 b. Provide the minimum the short circuit level for each setup tested.
 43

44 **PUB-NLH-144** Please provide the following details of the software deficiencies and the setup
 45 that resulted in the failure of the FAT:
 46 a. The network configuration during the test.

- 1 b. Whether the same test had been passed with other network configurations.
 2 c. If so, list the configurations that passed.
 3 d. A detailed description of tests that resulted in the failure.
 4 e. A description of the software function that caused the failure.
 5 f. Whether this software function had previously been known to result in
 6 test failure, and if so, the actions taken to avoid this failure prior to the
 7 FAT.
 8 g. If this was a new/unknown fault, please explain why this software
 9 fault/"bug" had not been identified during the pre-FAT testing and what
 10 action(s) will be taken to correct the deficiency.
- 11
- 12 **PUB-NLH-145** Regarding FAT of the updated interim software ("second FAT"), scheduled to
 13 commence on the 6th June, please:
 14 a. State whether, it started on the scheduled date, and if not, when it
 15 commenced.
 16 b. Please describe in detail the testing of the software that had been
 17 performed before second FAT commencement.
 18 c. Provide the number of known "bugs", if any, remaining in software prior
 19 to second FAT commencement. If any exist, please provide a full
 20 description of each bug, including its potential impact/consequences of
 21 operation and explain why each remaining bug had not been corrected.
 22 d. Confirm or explain if not that there were no known issues with the
 23 software prior to second FAT commencement.
 24 e. State whether the second FAT will include as a minimum all the tests
 25 performed in the first FAT, and if not, why not.
 26 f. Identify all additional tests, if any, included in second FAT to ensure that
 27 the previously faulty software is fully fit for its intended purpose.
 28
- 29 **PUB-NLH-146** Please describe the bipole control available in the interim LIL software version.
 30 In particular:
 31 a. Whether the controls can automatically balance the current in the two
 32 poles when in bipole operation.
 33 b. In the event of a trip of one of the poles, whether the controls will
 34 automatically transfer the power from the lost pole to the remaining pole,
 35 subject to the power not exceeding 450MW.
 36 c. What other features are provided in the interim bipole control.
 37
- 38 **PUB-NLH-147** With respect to the sea electrodes and the electrode lines, please:
 39 a. Confirm that they have not yet been tested with significant power. If they
 40 have been fully tested, please described the test and provide the results.
 41 b. If they have not been tested, describe how these two components will be
 42 tested/commissioned.
 43
- 44 **PUB-NLH-148** With respect to bipole commissioning, please confirm or if not explain, when
 45 the scheme has been commissioned up to 225MW whether it will be subjected
 46 to trial operation with continuous power transmission at levels between 90MW

1 and 225MW for 30 days and that any malperformance will require the
2 recommencement of the trial operation period, after the rectification of the
3 cause of the trip.

4
5 **PUB-NLH-149** With respect to trial operation period without synchronous condensers
6 available, please state:

- 7 a. Whether it may be permitted.
8 i. Whether it will take place, and if not, will Nalcor be permitted to
9 use the LIL at power up to 225MW.
10 b. Whether any tentative or firmer decisions have been regarding such
11 operation.
12 c. What principal conditions and other limits will guide the decision whether
13 to permit operation.
14

15 **PUB-NLH-150** Please state whether Nalcor personnel will be operating the LIL during the trial
16 operation period, and if so, what training will have been provided to the
17 operators before they take control of the LIL, and if not, when will the operators
18 receive the necessary training. If not, how many operators will be provided by
19 GE.
20

21 **PUB-NLH-151** In the event of a trip during the LIL's trial operation period, please:
22 a. Confirm or explain if not that GE and Nalcor personnel will examine the
23 records and determine the cause of the trip.
24 b. Describe actions to resolve any LIL trial-operations-period trips found to
25 be caused by a software bug (*e.g.*, whether the software will be
26 changed/corrected prior to re-starting).
27

28 **PUB-NLH-152** Please state and if so describe whether any corrections/changes to the LIL
29 software will be tested on the real Time Digital Simulator in Stafford prior to
30 implementation of the change at site.
31

32 **PUB-NLH-153** Following successful completion of the LIL's trial operation period, please
33 describe:

- 34 a. Whether and if so how commissioning at higher power will proceed, with
35 up to 450MW being transmitted.
36 b. Whether and if so how operation at higher power than 225MW will
37 depend on the availability of synchronous condensers.
38 c. Whether and if so how and for how long a trial operation period will be
39 required before continuous operation at 450MW is permitted.
40 d. Please explain the reason for the maximum limit for operation of the LIL
41 with the interim software, noting that the report "Stage 4D LIL Bipole:
42 Transition to High Power Operation" found that operation up to 900MW
43 was possible when exporting 500MW on the ML, and at up to 550MW
44 without the ML in service.

- 1 **PUB-NLH-154** Assuming the LIL has been fully commissioned with the final software, and is
 2 operated at up to 900MW, please:
 3 a. Confirm or explain if not that a trip of the bipole can result in Under
 4 Frequency Load Shedding (UFLS) of up to 913MW.
 5 b. Estimate the time to re-connect all lost loads assuming no ML and no LIL
 6 (or reconnect all available generation).
 7 c. Estimate the time to re-connect all lost loads assuming no ML and one
 8 LIL pole, with and without frequency control.
 9 d. Estimate the time to re-connect all lost loads assuming ML at up to
 10 150MW and no LIL.
 11 e. Estimate the time to re-connect all lost loads assuming ML at up to
 12 150MW and one LIL pole.
 13

14 **PUB-NLH-155** With respect to operation of Synchronous Condenser No. 3 operation to date,
 15 please confirm or explain if not known that it was run at rated speed for two or
 16 three days with vibrations noted during that period.
 17

- 18 **PUB-NLH-156** With respect to running of the synchronous condensers for a continuous period
 19 of many months assuming continuation of past observed level of vibrations,
 20 please:
 21 a. Describe Hydro's understanding (informed by Nalcor if required) of
 22 rights and obligations of General Electric with respect to permitting and
 23 taking responsibility for any consequences of doing so and the risks that
 24 the exercise of such rights may present to permitting such synchronous
 25 condenser operation.
 26 b. The positions of Nalcor and Hydro with respect to the need, wisdom,
 27 desirability, and consequences of doing so.
 28

29 *Generation*

- 30
 31 **PUB-NLH-157** With respect to the root cause of the rotor rim key cracking for the Upper
 32 Salmon Plant/Unit, please:
 33 a. Describe the status of efforts to determine the root cause(s).
 34 b. Identify the root cause(s) if known.
 35 c. Describe corrective actions planned or in place, other than frequent
 36 monitoring.
 37

38 **Reliability and Resource Adequacy Study Update, November 15, 2019**

- 39
 40 **PUB-NLH-158** Please provide the following documents:
 41 a. Operational Study - Stage 4C: Labrador Transfer Analysis (TP-R-034).
 42 b. Labrador Interconnected System - Expansion Study (TP-R-019).
 43 c. Application of Emergency Transmission Planning Criteria for a Labrador
 44 Island Link Bipole Outage (TP-TN-069).
 45 d. NLSO Operating instruction TOP-P-022 - TL248 Planned and Forced
 46 Outage.

- 1 e. NLSO Operating instruction TOP-P-068 - Granite Canal Tap Shunt
- 2 Reactor.
- 3 f. NLSO Operating instruction TOP-P-076 - NL Transmission System
- 4 Operating Limits.
- 5 g. TP-S-001 NLSO Standard – Facilities Rating Guide.
- 6 h. TP-S-003 NLSO Standard – Annual Planning Assessment.
- 7 i. TP-S-007 NLSO Standard – Transmission Planning Criteria.
- 8 j. NLSO Standard – Transmission Facilities Rating Guide (TP-S-001).
- 9 k. 2019 CDM Potential Study.

10

11 **PUB-NLH-159** Please provide the versions of the following documents (underlying the
12 November 2018 RRAS) for the 2019 update, or the most closely corresponding
13 information if structure or format have changed:

- 14 a. Modelling Assumptions.
- 15 b. PLEXOS Loss Calculation.
- 16 c. Wind Data Update.
- 17 d. LIL Firm Capacity.
- 18 e. Reliability Model 2.09.
- 19 f. Reliability Model 2.13.
- 20 g. Expansion Model 2.09.
- 21 h. Island LOLE Calculator.
- 22 i. Province LOLE Calculator.
- 23 j. LOLE Calculator – Benchmarking.

24

25 **PUB-NLH-160** Reference Reliability and Resource Adequacy Study – 2019 Update *Volume III*:
26 Long-Term Resource Plan, page 30, Section 7.1.1. Please provide the analysis
27 deriving the selection of the 16 percent planning reserve margin for the Island.

28

29 **PUB-NLH-161** With regard to operational studies, please provide:

- 30 a) A list of all completed, ongoing, and future operational studies pertinent
- 31 to the Reliability and Resource Adequacy Study and the LIL Include how
- 32 information in these studies will be used in the assessment of long-term
- 33 reliability of the Newfoundland and Labrador Integrated System.
- 34 b) A status update regarding all operational studies that have not yet been
- 35 filed with the Board, are underway, or are yet to be started.

36

37 **PUB-NLH-162** Given that Newfoundland is now interconnected with Nova Scotia through the
38 Maritime Link, and will be interconnected with Quebec through the LIL, please
39 describe what NERC or NPCC requirements currently or will apply to Hydro,
40 and outline Hydro's current or planned efforts to comply with these
41 requirements.

42

43 *TGS Study Reports*

44

45 **PUB-NLH-163** Regarding the TGS Technical Notes' identification of the need for up to
46 120MW of generation on the Avalon Peninsula, please:

- 1 a. State when Hydro will complete the analysis of options and make the
2 results available.
- 3 b. Describe the next steps (nature, issues to be addressed, expected questions
4 to be answered) in assessing optimum means for determining and meeting
5 such needs, and address specifically any role of the Holyrood units in
6 those next steps.
- 7 c. State when Hydro expects to have completed such efforts and make
8 results available.
- 9
- 10 **PUB-NLH-164** With respect to the TGS analysis of the impacts of trips of ac lines connecting
11 the ML and the LIL, please:
- 12 a. Confirm that this analysis has identified potential thermal overloads
13 resulting from single contingencies (“N-1”) and from further events
14 following them (“N-1-1”) and that operational protocols will be
15 developed by Hydro to manage the relevant overload conditions and that
16 circumstances may require the inclusion of limits on ML exports.
- 17 b. Based on what Hydro knows to date, provide a brief summary of the
18 potential nature and scope of those protocols and limits, in order to
19 provide an overall perspective on how significant they might be from a
20 customer perspective.
- 21 c. Describe the likely worst-case customer impacts of these operational
22 protocols on consumers in the IIS.
- 23
- 24 **PUB-NLH-165** Further to PUB-NLH-164 provide Hydro’s current estimate of the date when
25 these operational protocols will be available and an assessment of the risks to
26 and likelihood of meeting that date.
- 27
- 28 **PUB-NLH-166** With respect to full-power LIL operation at short circuit levels (SCL) less than
29 2,833MVA, please state whether such operation require General Electric’s
30 approval, and, if so, provide the status of discussions with GE and any tentative,
31 preliminary, or final agreements, decisions, or criteria regarding any such
32 operation and its approval.
- 33
- 34 **PUB-NLH-167** Further to PUB-NLH-166, state whether General Electric has agreed to or
35 offered for discussion a limit for operation at SCL levels below 2,833 MVA,
36 and if so identify such levels. If no limit has been set, state whether GE has
37 confirmed that they will allow operation up to 900MW without any SCs and
38 with the SCL below 2,833 MVA.
- 39
- 40 **PUB-NLH-168** With respect to the potential for a three-phase fault in the area near Soldiers
41 Pond to cause a commutation failure during fault recovery have commutation
42 failures happened in some cases after the clearance of faults near the Soldiers
43 Pond converter station.
- 44
- 45 **PUB-NLH-169** Further to PUB-NLH-168 confirm that additional studies are being performed
46 using the more appropriate PSCAD software to investigate this matter. If so

- 1 when will the results of any study will be available, the risks to that date, and
2 Hydro's estimation of the likelihood of availability at that date.
3
- 4 **PUB-NLH-170** With respect to the study of temporary HVDC overhead line faults, please state
5 whether Hydro intends to study them and if so when the results of any study
6 will be available, the risks to that date, and Hydro's estimation of the likelihood
7 of availability at that date.
8
- 9 **PUB-NLH-171** With respect to the threat of system instability following a three-phase fault on
10 line TL267 at load flows above 650MW, please state whether Hydro now plans
11 to address this threat through tuning of the SC stabilizers to control transmission
12 line oscillation on the Bay d'Espoir to Avalon corridor. If so, please describe
13 the principal activities required to do so and when Hydro expects to complete
14 the work required, the risks to that date, and Hydro's estimation of the
15 likelihood of availability at that date.
16
- 17 **PUB-NLH-172** With respect to restrictions General Electric has placed on LIL operation, please
18 confirm or if not explain that Hydro has stated to Liberty that it, as opposed to
19 Nalcor, has no role in such matters, which Hydro described as "commercial" in
20 nature.
21
- 22 **PUB-NLH-173** Further to PUB-NLH-172, please provide a robust description of what Hydro
23 defines as commercial issues with respect to LIL operation, as opposed to those
24 issues where Hydro does have a role. Secure from Nalcor agreement to provide
25 its views on LIL operational restrictions that's General Electric has imposed
26 and advise when it has been received.
27
- 28 **PUB-NLH-174** Confirm that Hydro has stated to Liberty that Hydro has no role in commercial
29 matters with General Electric and with respect to responsibility for potential
30 damage to LIL or other equipment connected to the ac network.
31
- 32 **PUB-NLH-175** With respect to manual activities TGS had to perform to supplement the ML
33 model available for conducting an analysis, which resulted from the tripping of
34 lines connecting the ML to the IIS, state whether Hydro asked or will ask for
35 an updated model. If so, state when Hydro expects to receive the model.
36
- 37 **PUB-NLH-176** With respect to the impacts of UFLS resulting from contingencies studied by
38 TGS, please:
39 a. Confirm or explain if not that Hydro's calculation of maximum expected
40 UFLS (at present 963MW) is not yet accompanied by: (i) a mapping of
41 the areas affected, (ii) frequencies that will trigger disconnection by area,
42 or (iii) load shed by area. Please also identify which of the three Hydro
43 will accomplish, describe the activities required to accomplish each and
44 state when Hydro expects to complete the work required for those it
45 intends to accomplish, the risks to that date or dates, and Hydro's
46 estimation of the likelihood of availability at dates estimated.

1 **PUB-NLH-177** With respect to TGS’s identification of a possible voltage collapse in the Bay
2 d’Espoir -Soldiers Pond corridor, caused by a reactive power problem, please
3 state whether Hydro plans to address such collapse as part of resource adequacy
4 study activities. If not explain why not. If so, state when Hydro expects to
5 complete the work required, the risks to that date, and Hydro’s estimation of
6 the likelihood of availability at the date estimated.
7

8 **Generation**
9

10 **PUB-NLH-178** Please describe the status and schedule of studies being performed to
11 accomplish the following regarding Holyrood as a short- and long-term
12 capacity resource.

- 13 a. Faster start of the Holyrood generating station and any plans to reduce the
14 startup times for the generating station.
- 15 b. Evaluation of Holyrood as a viable long-term capacity generating asset.
- 16 c. The risks to study completion dates, and Hydro’s estimation of the
17 likelihood of study results availability at the completion dates estimated.


18
19 **PUB-NLH-179** With respect to supply resource options under consideration, please describe:

- 20 a. The nature, scope, and schedule for analyzing them and providing
21 preliminary or final results for stakeholder examination in this review.
- 22 b. The roles of Hydro, Nalcor, and outside resources in performing such
23 analyses.
- 24 c. Whether the results will provide direct comparisons of Holyrood
25 extension options and all other options identified from least cost,
26 availability date, and other relevant criteria (list them) in order to present
27 a basis for making an optimum selection in fulfilling future resource
28 requirements.

DATED at St. John’s, Newfoundland this 30th day of June 2020.

BOARD OF COMMISSIONERS OF PUBLIC UTILITIES

Per



Cheryl Blundon
Board Secretary