

1 Q. What are Hydro's best estimates of the impacts of Covid-19, rate mitigation and government
2 intervention (i.e., heat pump incentives) on the load forecast? Has Hydro altered its load
3 forecast uncertainty curve to incorporate these events and if so, how has the load forecast
4 uncertainty curve been altered?

5

6

7 A. Please refer to Newfoundland and Labrador Hydro's ("Hydro") response to PUB-NLH-127 with
8 respect to the impacts of COVID-19 on the load forecast.

9 The 2018 Reliability and Resource Adequacy ("RRA") Study presented four load forecasts
10 scenarios for the Island Interconnected System with three different rate possibilities. Please
11 refer to Hydro's response to PUB-NLH-123¹ to view the variation in forecast resultant from use
12 of differing electricity rate.

13 Government interventions (i.e. heat pump incentives, electric vehicle charging network and
14 building electrification) will have varying degrees of impact on the load forecast. Hydro's current
15 long-term planning model construct for projecting energy efficiency savings (i.e. heat pumps)
16 relies on linear regression model estimated efficiency gains measured within the historical load
17 data which is then extrapolated to the forecast period. The amount of efficiency savings
18 projected in future periods is adjusted based on the load forecaster's judgement. Hydro has
19 made allowances for the conservation impacts from increased heat pump installations to reflect
20 lower peak demand savings than energy savings. Hydro will reassess these allowances when
21 results from an ongoing heat pump study by Newfoundland Power are available.

22 Hydro incorporated the loads associated with building electrification plans² by government and
23 a modest uptake of electric vehicles into the long term planning forecast.³ These forecast

¹ Cases I, II, and III in the 2018 RRA Study are all representative of a single baseline provincial economic forecast with varying electricity price forecasts.

² Excludes any potential peak demand impact associated with the potential conversion of boiler loads at Memorial University.

³ Hydro's long term planning forecast reflects electric vehicle load based on studies of potential adoption curves for other Canadian jurisdictions and pre-dates the release of the Dunsky CDM Potential Study. Subsequent iterations of the long term planning forecast reflect electric vehicle sales based on the Dunsky CDM Potential Study.

1 impacts resulted in an approximate 0.5% increase to the customer demand forecast, over the
2 study period. Hydro continues to assess electric vehicle adoption in the province and the
3 potential impacts they could have on system requirements in the context of investments in
4 supporting infrastructure and Conservation and Demand Management program offerings. While
5 some of the factors noted in the question may necessitate modifications to the load forecast
6 uncertainty parameter, the supporting analysis would require availability of actual demand data.
7 Given the recent nature of the potential impacts in question (i.e. heat pumps) there is not
8 currently sufficient information to determine if a change to the load forecast uncertainty
9 parameter is required.⁴ The requirements for such changes in future would be assessed as part
10 of Hydro's comprehensive analysis, proposed to occur every three years.

11 Further, given that the demand requirements used in Hydro's analysis result from the
12 multiplication of the load forecast in an hour with the load forecast uncertainty parameter, any
13 changes in the load forecast will materialize in the load values used in Hydro's analysis without
14 having to modify the load forecast uncertainty parameter. As such, to the degree the impacts of
15 events like COVID-19 or changes in forecast system requirements due to heat pump adoption
16 result in differences in Hydro's base or sensitivity load forecasts, the implications of such events
17 and technologies will be considered in Hydro's analysis.

⁴The load forecast uncertainty parameter incorporates probabilistic modelling of weather variability into the reliability model. The resultant variance in the load forecast, which occurs from using a load forecast uncertainty parameter, results from the multiplication of the load forecast in an hour with that uncertainty parameter. As such, changes in the load forecast will materialize in the load values used in analysis without having to modify the load forecast uncertainty parameter.