

1 Q. With reference to IC-NLH-011, would additional UFLS on the Island permit partial or full
2 resolution of the limitation represented by the Technical Conference #3 presentation slide 47?

3 i) If yes, how much UFLS is required and why was this not pursued?

4 ii) If not, why will this not work?

5

6

7 A. Additional under frequency load shedding on the Island would partially resolve the limitation
8 resulting from the Labrador-Island Link to Maritime Link relationship. Please refer to
9 Newfoundland and Labrador Hydro's response to IC-NLH-014 of this proceeding.