

1 Q. With reference to IC-NLH-011, please provide a list of other solutions considered to mitigated  
2 the limitation represented by the Technical Conference #3 presentation slide 47 (e.g., flywheels,  
3 easily shed pumped storage hydro loads, speed-no-load hydro operation, etc.) and why these  
4 are not included in the options being considered?

5

6

7 A. Please refer to Newfoundland and Labrador Hydro's ("Hydro") response to IC-NLH-014 of this  
8 proceeding for the list of potential technically viable solutions to mitigate the limitations within  
9 the Labrador-Island Link to Maritime Link relationship.

10 Adding more inertia to the system in the form of synchronous condensers or flywheels would  
11 have a minimal impact, as demonstrated in Hydro's response to IC-NLH-020 of this proceeding.