

1 Q. **Reference: *Reliability and Resource Adequacy Study – 2019 Update*, November 15, 2019,**
2 **Volume III: Long-Term Resource Plan, Section 7.2.6 – Assessment of the LIL Bipole Outage**
3 **Scenario.**

4 Please provide the load required to be served on the Avalon Peninsula during the same date-
5 time intervals as provided in the response to NP-NLH-036. Please provide the data in Microsoft
6 Excel format.

7

8

9 A. Please refer to NP-NLH-036, Attachment 1, provided as an Excel file, for the Avalon load for the
10 requested time period. Note that Newfoundland and Labrador Hydro (“Hydro”) does not
11 perform regional load forecasting. For the purposes of modelling, it is assumed that 53% of the
12 island load occurs on the Avalon Peninsula, consistent with load flow analysis completed by
13 Hydro, which is informed by Newfoundland Power’s Infeed Load Forecast.