

1 Q. **Reference: *Reliability and Resource Adequacy Study – 2018, November 16, 2018, Volume I:***
2 **Study Methodology and Proposed Planning Criteria, Attachment 7, pages 21-23, Tables 15 -**
3 **18.**

4 Tables 15 through 18 indicate a failure rate of 0.7656 f/yr. Please confirm that this indicates a
5 bipole outage once every 1.3 years (1/0.7656). If not, please explain.

6

7

8 A. It is confirmed. Please refer to Newfoundland and Labrador Hydro's response to NP-NLH-052.