

- 
- 1 Q. Please provide Hydro’s assessments for the LIL related to the possibility (e.g., low, medium,  
2 or high) for each of the events listed below to be capable of causing the LIL to be non-  
3 operational for an extended period of time:  
4
- 5 a) extreme weather;
  - 6
  - 7 b) line or terminal station equipment failure;
  - 8
  - 9 c) vandalism;
  - 10
  - 11 d) cybersecurity attack; and
  - 12
  - 13 e) other possible but likely less probable events such as an earthquake or airplane hit.
  - 14
  - 15 f) Please detail the effect that different seasonal conditions could have on the  
16 restoration efforts associated with each of these outage scenarios with particular  
17 emphasis on the impact to restoration times.
  - 18
  - 19 g) If no assessments have been undertaken please provide the rationale for not  
20 conducting such assessments.
  - 21
  - 22
- 23 A. Given the importance of the Labrador-Island Link (“LIL”) to the Island Interconnected  
24 System, Nalcor Energy Power Supply (“Nalcor”) engaged an external consultant, EFLA  
25 Consulting Engineers (“EFLA”), to assess the risk of failure of the overhead transmission line  
26 in consideration of a variety of scenarios, and to identify equipment and restoration  
27 methods that can be used to restore service in the event of a failure.

1 The results of the EFLA study are included in the following attachments:

- 2
- 3 • PUB-NLH-054, Attachment 1: “Emergency Response Plan – LITL Transport,  
4 Material, Storage Locations and Communication,” April 12, 2018;
- 5
- 6 • PUB-NLH-054, Attachment 2: “Emergency Response Plan – LITL Emergency  
7 Line Conductor Selection,” March 20, 2018;
- 8
- 9 • PUB-NLH-054, Attachment 3: “Risk Assessment Labrador Island  
10 Transmission Link,” April 13, 2018;<sup>1</sup>
- 11
- 12 • PUB-NLH-054, Attachment 4: “Emergency Response Plan: LITL Event  
13 Preparation and Risk Mitigation Measures,” March 29, 2018;
- 14
- 15 • PUB-NLH-054, Attachment 5: “Emergency Restoration Solutions for LITL  
16 350kV Labrador Island Interconnector ERP,” April 12, 2018;
- 17
- 18 • PUB-NLH-054, Attachment 6: “Crew Complement and Training  
19 Requirements 350 kV Labrador Island Interconnector ERP,” April 12, 2018;  
20 and
- 21
- 22 • PUB-NLH-054, Attachment 7: “Emergency Restoration Plan: LITL – Overland  
23 Transmission Emergency Restoration Plan 350 kV Labrador Island  
24 Interconnector ERP,” April 12, 2018.

25

26 The EFLA report considers transmission lines only and does not address the other  
27 components of the LIL including ac Terminals, HVdc Stations, and communications

---

<sup>1</sup> Some of the risks addressed in the study include freezing rain, extreme winds, flooding, erosion, landslides, frost heave, lightning, forest fires, galloping, Aeolian vibration, vandalism, vegetation growth, impact by ground and airborne vehicles, and risks from design and maintenance practices.

1 equipment. The ac Terminals, HVdc Stations, and communications equipment have been  
2 designed to prevent single-component failures causing customer interruptions as further  
3 described below. In addition Nalcor has completed a critical spares review and procured  
4 critical spares to maintain required availability. In 2020, a business continuity risk review  
5 will be completed on these facilities to determine any remedial actions required to mitigate  
6 any high level risks identified with these facilities.

7  
8 a) Extreme Weather

9 Design of the overhead line portion of the LIL was undertaken using the overhead  
10 line design standards in force, namely CAN/CSA C22.3 No. 1 and CAN/CSA C22.3  
11 No. 60826. A significant amount of historical data, including: historical and modern  
12 studies, on-site test tower data, as well as local experience when available, was  
13 utilized in the determination of the meteorological loading. Eleven different loading  
14 zones were identified over the 1,100 kilometre overhead line as part of the  
15 optimization of the line design with the construction cost and to account for the  
16 unique environmental conditions specific to certain areas. These include various  
17 combinations of wind and ice through heavy glaze ice zones, coastal zones, and  
18 heavy rime ice (in-cloud ice) zones. Through an iterative process, line design was  
19 completed following standard design practices to optimize and reduce line failure  
20 risk and to further balance the loads on the structures. The design of the LIL meets  
21 CSA 150-year<sup>2</sup> ice and wind loading recommendations for glaze ice zones off the  
22 Avalon Peninsula and CSA 500-year<sup>3</sup> ice and wind loading recommendations on the  
23 Avalon Peninsula. For rime ice zones, such as the Long Range Mountains, the line  
24 design exceeds 500-year designs for both rime ice and wind. Although events such  
25 as insulation failure can cause a pole outage, LIL bipole design ensures that in the  
26 event of an outage to one pole, the remaining pole is capable of carrying 2.0 pu<sup>4</sup>  
27 current overload for 10 minutes, ramping down to 1.5 pu current overload

---

<sup>2</sup> 1:150-year design provides an annual probability of structural failure due to meteorological loads of 0.7%

<sup>3</sup> 1:500-year design provides an annual probability of structural failure due to meteorological loads of 0.2%

<sup>4</sup> Per unit ("pu").

1 indefinitely. This ensures that failure of an item that affects one pole will not cause  
2 the LIL to be non-operational for an extended period of time.

3

4 The calculated annual probability of failure of one or more towers on the overhead  
5 transmission line due to extreme weather is considered to be 0.7% for the section  
6 designed to a return period of 1:150 years and is 0.2% for the section that is  
7 designed to a return period of 1:500 years. In comparison, typical transmission lines  
8 within the system are designed for a 1:50-year event, with a 2% annual probability  
9 of failure under an extreme weather event. Distribution lines have a higher  
10 probability of failure. While an extreme weather event can happen at any time of  
11 year, failures causing transmission outages typically occur during the winter  
12 season. Given the length of the line, this could occur from October to May. Access  
13 to the site can be reached by access road sections, helicopters, snowmobile, or  
14 heavy equipment should road access be difficult due to extreme snow. Assuming a  
15 loss of a full section of the transmission line (up to 20 structures between anti-  
16 cascade structures) the emergency response plan is targeting restoration of  
17 monopole operation via emergency structures over a two-week timeframe. The  
18 emergency response plan is designed to take limited access into account.

19

20 The ac and dc terminal stations were designed for a 50-year lifespan; however,  
21 extreme weather events similar to the loading on the LIL overhead line in that area  
22 were also taken into account in the design of the stations to reduce the probability  
23 of failure of the terminal station equipment for an extended period of time.

24 Depending on the location of a failure in the terminal station, the unlikely failure  
25 due to extreme weather could take either a pole or breaker-and-a-third ac  
26 diameter<sup>5</sup> out of service, with multiple failures being less probable. Failure of  
27 terminal station equipment for one pole will be mitigated by the monopole  
28 overload protection. The design of the breaker-and-a-third layout ensures that

---

<sup>5</sup> An ac diameter includes the equipment between the two bus connections. For a breaker-and-a-third diameter, this includes four circuit breakers and three line connections within the length of the diameter.

1 failure of an ac diameter would maintain operational flexibility by minimizing the  
2 number of common elements (lines, transformers, converters, synchronous  
3 condensers, and capacitor banks) forced out of service by the failure. Therefore,  
4 there is a low probability of an extreme weather event causing a LIL outage in the  
5 terminal stations for an extended period of time. Other than loss of productivity  
6 while working in winter weather conditions, which is no different than workers are  
7 exposed to today, similar restoration times would be required at any time of year,  
8 with typically longer restoration times in extreme cold weather.

9

10 b) Line or Terminal Station Equipment Failure

11 Equipment failure on the transmission line, such as a string of failed insulators, will  
12 typically remove one pole from service and will not lead to an extended customer  
13 outage. Critical spares stock levels will ensure that equipment is available to  
14 complete timely repairs and restore full service for bipole operation. Other than  
15 high winds restricting the ability to climb towers or low cloud conditions in  
16 mountain zones restricting helicopter access, seasonal conditions will not have a  
17 material effect on restoration times. The emergency response plan will be designed  
18 to take limited access into account.

19

20 The terminal stations at Muskrat Falls and Soldiers Pond have been designed using  
21 a breaker-and-a-third scheme as stated in Newfoundland and Labrador Hydro's  
22 response to part a. During normal operation, a single failed piece of equipment can  
23 be removed from service without affecting other equipment. In the event of a  
24 breaker failure (i.e., stuck breaker), two elements are removed from service.  
25 Elements are strategically connected so that no two transmission lines,  
26 transformers, generators, or filter feeders are removed from service.

1 Adequate spare equipment will be available for both the terminal stations and  
2 submarine cable transition compounds<sup>6</sup> to ensure timely replacement of any failed  
3 equipment. Each converter station has a spare converter transformer to allow  
4 quick replacement of a failed unit. In addition, there is a spare filter bank for each  
5 converter station. Therefore, there is a low probability that equipment failure will  
6 cause a LIL outage for an extended period of time.

7

8 c) Vandalism

9 Vandalism on the transmission line is discussed in PUB-NLH-054, Attachment 3.  
10 Vandalism on transmission lines in Newfoundland and Labrador is typically limited  
11 to individuals shooting insulators. Typically, failures of this type do not cause an  
12 outage unless multiple insulators in a string are damaged. In this instance,  
13 insulators can be easily replaced, and therefore this activity has a very low  
14 probability of causing a LIL outage on the transmission line for an extended period  
15 of time.

16

17 HVdc Stations, ac Terminal Stations, and submarine cable transition compounds are  
18 equipped with security gates and fencing that completely surround the stations to  
19 prevent public access. Closed-circuit television cameras have been installed in  
20 strategic locations throughout these facilities and can be monitored from various  
21 locations. Routine maintenance and inspections are also important in identifying  
22 any vandalism activities. Regular inspections can identify damaged equipment and  
23 initiate the process for repairs before an outage has occurred. Based on this  
24 activity, there is a low probability of vandalism causing a LIL outage for an extended  
25 period of time.

---

<sup>6</sup> The transition compounds are the intersect point where the submarine cables at the Strait of Bell Isle transition to the overhead line. There is a transition compound on either side of the Strait of Belle Isle.

1 d) Cybersecurity Attack

2 Nalcor's cybersecurity risk protocols and mitigations are currently being  
3 implemented for these assets. A detailed risk assessment has not yet been  
4 completed for communications infrastructure, ac Terminals, and HVdc Stations.  
5 Cybersecurity attack will be included in that analysis.

6  
7 e) There are other possible but likely less probable events that can cause the LIL to be  
8 non-operational for an extended period of time. Although earthquakes are possible  
9 and have occurred in the past, according to Natural Resources Canada they pose a  
10 very low risk to Newfoundland and Labrador.<sup>7</sup>

11  
12 Transmission line design has incorporated the required aircraft notification markers  
13 to minimize the potential of contact with aircraft, and the line has not been routed  
14 within aerodrome airspace. In the unlikely event of an aircraft contact, the zone of  
15 failure will be limited to one or two towers and therefore restoration efforts should  
16 not cause an extended LIL outage.

17  
18 The submarine cables across the Strait of Belle Isle are installed inside directionally  
19 drilled boreholes from land to the ocean floor, emerging at a depth of  
20 approximately 70 m. A natural sea berm restricts icebergs greater than 60 m from  
21 entering the Strait of Belle Isle. Once on the ocean floor, the cables were laid in  
22 the naturally occurring contours (valleys) on the seabed to further protect them. In  
23 addition, the cables were then covered in a rock berm in all areas not protected by  
24 the directional drilled boreholes to further protect from dropped ship anchors and  
25 fishing gear. Nalcor also negotiated a fishing exclusion zone to remove fishing  
26 activity from the cable location. As such, fishing activity would be inadvertent and  
27 in violation of the exclusion zone and not anticipated to be a regular occurrence. A  
28 total of three submarine cables have been installed to provide redundancy. In the

---

<sup>7</sup> "2015 Seismic Hazard Map Geological Survey of Canada," Natural Resources Canada, November 3, 2017,  
<<http://www.seismescanada.rncan.gc.ca/hazard-alea/simphaz-en.php#NL>>

- 1 event of damage to the submarine cable requiring significant repair, the LIL can be  
2 operated normally with one cable out of service while repairs are carried out using  
3 the spare cable stored in Corner Brook.
- 4
- 5 f) The effect that seasonal conditions can have on restoration efforts is included  
6 within responses to parts a to c.
- 7
- 8 g) A detailed business continuity risk assessment has not yet been completed for  
9 communications infrastructure, ac Terminals, and HVdc Stations. As noted above,  
10 this will be addressed in 2020.

**PUB-NLH-054 Attachments 1 through 7 contain sensitive information pertaining to the security of Newfoundland and Labrador Hydro assets and are not provided.**