Page 1 of 1


1	Q.	Please provide Hydro's Emergency Preparedness and Restoration Plans (or equivalent) that
2		specifically address potential HVDC system outages.
3		
4		
5	Α.	Please refer to PUB-NLH-055, Attachment 1 for the "Overhead Transmission Lines (OHTL)
6		Interim Emergency Restoration Plan" for the Labrador-Island Link ("LIL"). Nalcor engaged
7		EFLA Consulting Engineers, an engineering and consulting company based in Iceland and
8		Norway, to conduct a detailed analysis of the LIL. The report generated from this activity is
9		provided in Newfoundland and Labrador Hydro's response to PUB-NLH-054. EFLA
10		Consulting Engineers specializes in the design, management, and implementation of
11		diverse engineering power and utility projects. Nalcor is utilizing this document to prepare
12		an Emergency Restoration Plan for the LIL. The targeted completion date for the final
13		Emergency Restoration Plan is the fourth quarter of 2019. Please refer to Newfoundland
14		and Labrador Hydro's response to PUB-NLH-054 for further details.

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 1 of 14



Overhead Transmission Lines (OHTL)

Interim Emergency Resoration Plan



PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 2 of 14

	and the second start of the
Revision	Pag
Revision	
	Revision

Table of Contents

1. General Overview	3
1.2 General Line Metrics	4
2. General Overview of Repair/Restoration Approach	4
2.1 Manufacturer Defects / Deficiencies	5
2.2 Emergency Repair on the CF to MF Line	5
2.3 Emergency Repair on the MF to SOP Line	6
3. LITL Call Out Tree	7
4. SOLDIERS POND MANAGEMENT & LOGISTICAL SUPPORT	8
5. SOLDIERS POND CONTACT LIST	9
6. EMERGENCY CONTACT NUMBERS	10
7. NOTIFICATION OF CEOC EXECUTIVE ON CALL PROCEDURE	
8. LCP SITE REPRESENTATIVE CONTACT INFORMATION	
9. LCP OPERATIONAL SUPPORT WORK FLOW	13

REFERENCE DOCUMENTS

- Contractor Emergency Response Plans (Supplied by Contractor)
- LCP Project Wide Emergency Response Plan LCP-PT-MD-0000-HS-PL-0004-01
- Soldiers Pond Interim Emergency Response Plan
- Drug and Alcohol Standard LCP-PT-MD-0000-LR-SD-0001-01
- Health and Safety Management Plan LCP-PT-MD-0000-HS-PL-0001-01
- Occupational Safety and Health Act and Regulations
- Emergency Call Out Procedure


PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 3 of 14

	OHTL EMERGENCY RESTORATION PLAN		
4.0 j 4 i	Nalcor Doc. No.	Revision	Page
			3

1 THE LABRADOR ISLAND TRANSMISSION LINK (LITL)

1.1 General

The Labrador Island Transmission Link (LITL) is a 900 MW, 350kV HVdc transmission system between Muskrat Falls in Labrador and Soldiers Pond on the Island portion of the Province. The LITL transmits power from the 824 MW Muskrat Falls hydroelectric plant to service load on the Island Interconnected System, particularly on the Avalon Peninsula. The LTA portion of the line will also provide an interconnection between the Upper Churchill Falls plant and the Island Interconnected System.



Labrador Transmission Assets (Green)

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 4 of 14

*	OHTL EMERGENCY RESTORATION PLAN		
	Nalcor Doc. No.	Revision	Page
		and a second	1

1.2 General Line Metrics.

The LITL overhead HVdc transmission line will traverse approximately 1100km from Muskrat Falls to Soldiers Pond. This includes approximately 388 km in Labrador and approximately 680km on the island of Newfoundland. The elevation of the LITL will vary from 0m (Sea Level) to approximately 630m in the Long Range Mountains (LRM) and 500m in the Highlands of St. John on the Great Northern Peninsula. The Labrador section of the LITL is to carry two electrode conductors from the Muskrat Falls Converter Station to the grounding station at L'Anse au Diable on southern Labrador. Most of the electrode line in Labrador (370km) will be built on the ±350 kV HVdc steel transmission towers above the pole conductors and below the tower's single OPGW. The remainder of the electrode line in Labrador will be supported by wood poles.

The Labrodor Transmission Assets (LTA) consists in the ac transmission line system form Churchill Falls to Muskrat Falls, specifically:

Churchill Falls switchyard extension;

Muskrat Falls switchyard;

• Transmission lines from Muskrat Falls to Churchill Falls: double-circuit 315 kV ac, 3 phase lines, double bundle conductor, Single circuit galvanized lattice steel guyed suspension and rigid angle towers; 247 km long

 735 kV Transmission Line at Churchill Falls interconnecting the existing and the new CF switchyards

2. General Overiew of Emergency Repair / Restoration Approach

Nalcor Energey Power Supply has classified failures into 5 levels ranging from levels 1-5. Level 1,2, & 3 failures are expected to be midigated by internal resources within the organization. Levels 4 & 5 will require external support and contracts. A fault will be detected by fault location devices located in Soldiers Pond and Muskrat Falls. These detectors will detect a fault usually within a few kilometers of the affected tower(s). The GPS tools set would then be used to determine the exact location and determine what method of access we would use to inspect the line. Location would also determine what other challenges would exist such as; environment, topography, road access, helicopter landing zones, external emergency services, etc. Helicopter surveys would then be utilized to confirm such information and nature of the fault. Weather services would be used through a contract with AMEC to provide current conditions on site as well as

Nalcor Doc. No.	Revision	Page

future forcasts. In the Interim Power Supply will engage third parties to facilitate emergency respair until internal resources are in place and operational.

Emergency repair will fall under the following classifications:

- 1 Manufacturer or construction defects / deficienes on the entire line
- 2 Emergency repair on the section of the line from Churchill Falls to Muskrat Falls
- 3 Emergency repair on the section of the line from Muskrat Falls to Soldiers Pond

2.1 Manufacturer defects / definiences

In the event of an outage or discovered damage that has resulted from defects or deficieinces that are manufacturer or construction related the company will seek repair through the warranty process. The contracts warranty is for a period 3 years following final completion (December 2017 for HVac and mid August 2018 for HVdc). There is an extended warranty for an additional 3 years on any foundation issues. This repair will be carried out by a third party contract such as Valard Contruction Ltd. All repair plans will be the responsibility of this third party contractor with approval from the company.

2.2 Emergency repair on the section of the line from CF to MF

Should a repair be required on the portion of the line from Churchill Falls to Muskrat Falls that is not covered under warranty Power Supply will have to perform the repair. Power Supply has the option to dispatch crews from Churchill Falls which could be supported from Muskrat Falls, as well support can be requested from Newfoundland and Labrador Hydro. Should the scope of the repair be outside the resources of local repair teams Power Supply has a contract with Allteck to facilitate such events.


PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 6 of 14

	OHTL EMERGENCY RESTORATION PLAN		
<u>.</u>	Nalcor Doc. No.	Revision	Page
		Autor and a second s	C I

2.3 Emergency repair on the section of the line from MF to SOP

A repair that is required on the portion of the line from Muskrat Falls to Soldiers, and is not covered under warranty, can be facilitated by crews and resources from Power Supply, Muskrat Falls or Soldiers Pond Line Crews with support from Churchill Falls. As well Newfoundland & Labrador Hydro maybe leveraged to supply resources and personal to help facilitate the repair depending on the location and level of the incident. If the repair / restoration process is outside or beyond the resources of Power Supply or NL Hydro a contract is in place with Allteck to perfom the required repair / restoration on behalf of Power Supply.

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 7 of 14



PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 8 of 14

	OHTL EMERGENCY RESTORATION PLAN		
	Nalcor Doc. No.	Revision	Page
and a start of the second	(a) A region (and a structure of the		0

4. SOLDIERS POND MANAGEMENT & LOGISTICAL SUPPORT

Position	Name	Work Ext.	Home #	Cell #
Soldier's Pond On Call				(709) 733-2907
Regional Manager	Perry Taylor	(709) 733-5576		(709) 631-8645
General Manager	Chad Wiseman	(709) 733-5530		(709) 727-5804
Site SH&E Advisor	Vacant	and the second		
Emergency Response Coordinator	Jim Barnes	(709) 733-5749		(709) 697-5576
Safety Lead	Brad Spurrell	(709) 737-1430		(709) 725-3835
Work Execution Manager - Lines	Bob woodman	(709) 733-5782	-1E4	(709) 691-8915
Work Execution & Operations Manager	Evan Oliver	(709) 737-1225		(709) 727-6532
Technical Supervisor - Operations	Andrew Smith	(709) 733-6533	يور أ ماليا	(709) 682-0328
Technical Supervisor – Maint. Controls	Ray Bursey	(709) 733-5487		(709) 325-0379
Technical Supervisor - Operations	Tobie Comtois	(709) 733-5798		(709) 693-4759
Technical Supervisor – Maint. Elec/Mec	Clyde O'Leary	(709) 733-5483		(709) 691-6755

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 9 of 14

	0	HTL EMERGENCY RESTORATIO	N PLAN		
1.1	Mar Mary	Nalcor Doc. No.	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Revision	Page
					9

5. SOLDIERS POND CONTACT LIST

Name	Number	Alternate #	Position
Soldiers Pond On Call	(709) 733-2907	ALL ALL AND A	
Chad Wiseman	(709) 727-5804		General Manager, Transmission
Perry Taylor	(709) 631-8645		Regional Manager
Bob Woodman	(709) 691-8915		Work Execution Manager - Lines
Evan Oliver	(709) 727-6532		Work Execution & Operations Manager
Andrew Smith	(709) 682-0328		Technical Supervisor - Operations
Tobie Comtois	(709) 733-5798		Technical Supervisor - Operations
Ray Bursey	(709) 325-0379		Technical Supervisor - Maintenance (Controls)
Clyde O'Leary	(709) 691-6755		Technical Supervisor - Maintenance (Electrical/Mechanical)
Mike Morey	(709) 690-2300		Technical Operator - Electrical
Travis Stacey	(709) 330-0771		Technical Operator - Electrical
Trevor Tobin	(709) 280-1783		Technical Operator - Electrical
Paddy Bonia	(709) 280-0496		Technical Operator - Electrical
Ryan Arnold	(709) 746-8595		Technical Operator - Electrical
Brandon Toope	(709) 727-0874		Technical Operator - Electrical
Sandy Goodyear	(709) 536-8209		Technical Operator - Mechanical
Robin Laws	(709) 763-6776		Technical Operator - Mechanical
Mike Yetman	(709) 699-8020		Technical Operator - Mechanical
Duane Quinlan	(709) 727-5598		Technical Operator - Mechanical
Steve Batt	(709) 727-6070		Technical Operator - Mechanical
Andrew Neil	(709) 770-5273		Technical Operator - Mechanical
Otto Atkins	(709) 987-9701		Control Tech
Zak Watts	(780) 402-0912		Control Tech
Greg Harris	(709) 735-0143		Control Tech
Leah Melvin	(709) 769-7065		Control Tech
Lance Benoit	(709) 631-9726		HVDC Consultant
Lyle Neumann	(709) 897-5615		HVDC Consultant
Robert Youngberg	(587) 990-2181		HVDC Consultant
Kevin Edmondson	(204) 648-3898	The second s	HVDC Consultant

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 10 of 14

OHTL EMERGENCY RESTORATION PLAN		
Nalcor Doc. No.	Revision	Page
		10

6. Emergency Response Numbers

NAME	NUMBER
RCMP – province wide	911
Remote Medivac – JRCC Halifax	1-800-565-1582
Province Wide Medical Emergency	911
Forest Fire Report / Information	1-866-709-3473
Poison Control Center – St. John's	1-866-727-1110
Fire and Emergency Services, NL	709 729-3703
Fire Departments Province Wide	911
Power Supply on Call - SOP	709 733-2907
Power Supply on Call - MF	709 733-2906
Energy Control Center (ECC)	709 737-1957 / 1958
C3 Emergency Response Team	709 727-4989
Valard Construction	780 436-9876
AllTeck	604 857-6638 / 6647 / 6653

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 11 of 14

OHTL EMERGENCY RES	IORATION PLAN		
Nalcor Doc. N	0.	Revision	Page
			11

7. NOTIFICATION OF CEOC EXECUTIVE ON CALL PROCEDURE

Procedure for Initiating an Alert or Emergency	Step 1 — Complete all requirements of the Soldier's Pond Emergency Response Manual
Notification to Mobilize	Step2 — Call ECC at 754-3123 and provide:
CEOC	Name of Facility
	Nature of Emergency or Alert
	Assistance required from ECOC
and the second secon	Your Name and Contact Number
	Casualties or Injuries
	Date and Time of Incident
a se a simi	Current Status of the Situation
tellere privilegisse girte	Agencies Notified (RCMP, 911, Medical OH&S, Etc.)
and the second start of the	Step 3 - Request Executive On Call be notified
	Step 4 — Depending on the type of Alert or Emergency, you may be contacted by the Executive On Call or operations liaison once he or she arrives at the ECOC

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 12 of 14

OHTL EMERGENCY RESTORATION PLAN		
Nalcor Doc. No.	Revision	Page
	and the second second second second	40

8. LCP SITE REPRESENTATIVE CONTACT INFORMATION

Churchill Falls Terminal Station (CHFTS2):

• LCP Site Rep.: Donald Samson, Area Construction Manager: c. (709) 730-3836

- LCP Site Rep.: Dennis Byrne, Area Construction Coordinator: t. (709) 733-5725 c. (709) 735-0157
 - o Thomas Murphy, QA Electrical Inspector: c. (709) 735-0029
 - o Adam Chubbs, Completions & System Energization Lead: t. (709) 733-5275 c. (709) 597-3020
 - o Fire & Security, Main Gate: (709) 925-8280

Muskrat Falls Terminal Station (MFATS2):

- LCP Site Rep.: Donald Samson, Area Construction Manager: c. (709) 730-3836
- LCP Site Rep.: James Noftal, Area Construction Coordinator: t (709) 733-5729 c. (709) 897-5640
 - o Adam Chubbs, Completions & System Energization Lead: t. (709) 733-5275 c. (709) 597-3020 o Safety Site Rep: Joe Lake: c. (709) 899-6390
 - o Kevin Fewer: c. (709) 899-3114
 - o Security, Main Gate: (709) 325-0580

Muskrat Falls Converter Station (MFACSI:

- ICR Site Rep.: Donald Samson, Area Construction Manager: c. (709) 730-3836,
- LCP Site Rep.: James Noftal, Area Construction Coordinator: t (709) 733-5729 c. (709) 897-5640
 - o Adam Chubbs, Completions & System Energization Lead: t. (709) 733-5275 c. (709) 597-3020 o Safety Site Rep: Joe Lake: c. (709) 899-6390
 - o Kevin Fewer: c. (709) 899-3114,
 - o Security, Main Gate: (709) 325-0580

Soldiers Pond Terminal Station (SORTS):

- LCP Site Rep.: Ray Butler, SOP Construction Manager: t. 709 733-5265 c. 709-727-9847
 - o Adam Chubbs, Completions & System Energization Lead: t. (709) 733-5275 c. (709) 597-3020 o Safety Site Rep: Sean Lee: c. (709) 691-2903,
 - o Dave Hunt: c. (709) 730-2501.
 - o Security, Main Gate: (709) 682-0153

Soldiers Pond Converter Station (SOPCS):

- LCP Site Rep.: Ray Butler, SOP Construction Manager: t. 709 733-5265 c. 709-727-9847
 - o Adam Chubbs, Completions & System Energization Lead: t. (709) 733-5275 c. (709) 597-3020
 - o Safety Site Rep: Sean Lee: c. (709) 691-2903,
 - o Dave Hunt: c. (709) 730-2501.
 - o Security, Main Gate: (709) 682-0153

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 13 of 14

	OHTL EMERGENCY RESTORATION PLAI		
and i	Nalcor Doc. No.	Revision	Page
			13

Soldiers Pond Synchronous Condensers(SOPSC):

LCP Site Rep: Ray Butler, SOP Construction Manager: t. 709 733-5265 c. 709-727-9847

o Shaun Marshall, Area Manager - Synchronous Condensers: t. 709-778-6661 c. 709-687-7065

o Safety Site Rep's: Sean Lee: c. (709) 691-2903,

Dave Hunt: c. (709) 730-2501.

o Security, Main Gate: (709) 682-0153

Forteau Point Transition Compound (POPCABLE):

• LCP Site Rep.: Ray Butler, SOP Construction Manager: t. 709 733-5265 c. 709-727-9847

• LCP Site Rep.: Robert Williamson, c. (709) 899-0592

Shoal Cove Transition Compound (SOCCABLE):

- LCP Site Rep.: Ray Butler, SOP Construction Manager: t. 709 733-5265 c. 709-727-9847
- LCP Site Rep.: Vaughan Wooford, c. (709) 631-8222

Telecommunications (All locations):

- LCP Site Rep.: Gilles De Gonzague, System Integration and Telecommunication Area Manager, t. (709) 733-4490 c. 709-682-1858
 - o Joseph O'Dell, Package Lead Systems Integration and Telecoms: t. 709-733-5283 c. 709-899-1846

Additional Contacts:

- In the event that the above primary and secondary contacts are not available, please contact one of the following LCP (Transmission) Managers:
 - o Brian Smith Completions Commissioning Manager: t.(709) 733-5211 c. (709) 689-6852
 - o Tim Hunt, Deputy Project Manager HVDC Specialties: t. (709) 778-6636 c. (709) 330-0743

o Barry Boland, Project Stewardship Transfer Manager - HVDC Specialties: t. (709) 733-6535, c. (709) 725-0740

o Snehal Parmar, Project Manager - Overland Transmission: t. 709 733 4439 c. 709 897-5824 o Shawn Hurley, Project Manager - HVDC Specialties: t. (709) 778-6627 c. (709) 725-7083 • Primary Health and Safety Contact for LCP is:

o Glen O'Neill, HSSER Manager - Transmission: t. 709-733-4489 c. 709-693-1480

PUB-NLH-055, Attachment 1 Reliability and Resource Adequacy Study Page 14 of 14

	OHTL EMERGENCY RESTORATION PLAN		
w to see	Nalcor Doc. No.	Revision	Page
and the second se			14

9. LCP OPERATIONAL SUPPORT WORK FLOW

LCP Operational Support Workflow

Step	Activity Description	(A) Operations Energy Control Centre NLSO	(B) Operations Site Control Room / Field Technician	(C) Project Contact LCP Site Rep.	(D) Main Contractor	(E) Other
1	(A) Receive and acknowledge alarm, and action (B) to investigate cause of alarm.	1-		1		
2	(B) Investigates cause of alarm		2			
3	(B) Determines what action to take.	No Action Required - (A) notified.	-3			
4	(B) Provides assessment to (A).		À	Assistance		
5	(B) Determines whether issue can be resolved with or without LCP support.		5	required		
6	(B) Resolves issue and notifies (A).		6			
7	(B) Contacts (C) as per contact list for assistance.		7+			
8	(C) Contacts (D) to notify of issue and request assistance.		L	8	-	
9	(D) Resolves issue, gets assistance as required from (A) & (B).	9c •····	••••• 9b ••••	*****	··· 9a	
10	(D) Notifies (B) & (C) of the issue status once complete.		+		10	
11	(B) Notifies (A) of issue status.		11			