

- 1 Q. **Reference Avalon Capacity Study, page 26, Table 7-3:**
- 2 Please:
- 3 a. Describe and explain whether 4 GTs solve all the issues analyzed in this study.
- 4
- 5 b. Describe whether resolution would also require reactive support or thermal upgrades.
- 6
- 7 c. Indicate and explain whether the table implies that a generation-only option could
- 8 work for all cases, including a 3PF at BDE.
- 9
- 10

- 11 A. a. It is correct that the addition of four 60 MW gas turbines would resolve all technical
- 12 issues related to transmission constraints identified in the Avalon Capacity Study.¹ Such a
- 13 solution would allow for the application of steady state Transmission Planning Criteria,
- 14 even in the unlikely event of a bipole outage, and would also provide the capability to
- 15 withstand a three-phase fault at Bay d’Espoir without the risk of system instability.
- 16

17 It must be noted that the Newfoundland and Labrador Transmission System is currently not

18 designed to withstand a three-phase fault on the 230 kV bus at Bay d’Espoir. Given the cost

19 implications to reinforce the transmission system and the unlikelihood of such an event

20 occurring [please refer to Newfoundland and Labrador Hydro’s (“Hydro”) response to PUB-

21 NLH-073], Hydro did not consider it prudent to upgrade the transmission system solely to

22 provide the ability to withstand a three-phase fault on or near the 230 kV bus at Bay

23 d’Espoir. In the interconnected scenario, the NLSO² Standard Transmission Planning

24 Criteria³ currently states that the system must maintain stability following any three-phase

25 fault **except** a three-phase fault on, or near, the Bay d’Espoir 230 kV bus.

¹ “Solutions to Serve Island Demand During a LIL Bipole Outage,” TransGrid Solutions, May 23, 2019.

² Newfoundland and Labrador System Operator (“NLSO”).

³ “NLSO Standard Transmission Planning Criteria TP-S-007,” March 7, 2019, s.5.9, at p.15.

<https://www.oasis.oati.com/woa/docs/NLSO/NLSOdocs/TP-S-007_Transmission_Planning_Criteria_UPDATED_03072019.pdf>

1 b. This solution would not require additional thermal upgrades or reactive support. The
2 incremental generation would be operated to offload the transmission corridor between
3 the Bay d’Espoir Terminal Station and the Soldiers Pond Terminal Station such that there
4 would be no violations to Transmission Planning Criteria.

5

6 c. It is correct that a generation-only option would eliminate all violations to Transmission
7 Planning Criteria, including a three-phase fault at Bay d’Espoir, as described in Part a by
8 alleviating the system condition described in Hydro’s response to PUB-NLH-065.