

1 Q. **Newfoundland and Labrador Hydro – Near-Term Reliability Report, May 15, 2020**

2 **Other Near-Term Issues**

3 Please state and if so describe whether any corrections/changes to the LIL software will be  
4 tested on the real Time Digital Simulator in Stafford prior to implementation of the change at  
5 site.

6

7

8 A. All corrections/changes to the Labrador-Island Link software will be tested using the real time  
9 digital simulator at the General Electric site in Stafford before being considered for deployment  
10 to site.