

1 Q. **Reference: Reliability and Resource Adequacy Study 2022 Update, Volume III, page 5.**
2 Further to PUB-NLH-258, provide the comparable actual values for winter 2021 and winter
3 2022.

4

5

6 A. The actual Island Interconnected System customer coincident demand for winter 2021 and
7 winter 2022 is provided in Table 1.

Table 1: Island Interconnected System Coincident Customer Peak Demand (MW)¹

	Actual Peak Demand	Weather-Adjusted Peak Demand ²
Winter 2021	1,563	1,596
Winter 2022p ³	1,441	1,483

¹ Island Interconnected System customer demands are exclusive of transmission losses and station service requirements.

² Weather-adjusted utility peak demand estimates are at average historical peak weather conditions.

³ The Island Interconnected System customer coincident demand for winter 2022 is preliminary and is for the period ending January 11, 2023.