

1 Q. **Reference: Newfoundland and Labrador Hydro - Long-Term Load Forecast Report**

2 Please refer to the LTLFR at page 21.

3 a) Please provide the current list of requests for power in Labrador, as referenced in lines
4 2-3.

5 b) Please identify the two major industrial customers in line 9. If not a specific set of
6 customers, please explain how this assumption (explained at lines 9 through 13) was
7 developed.

8

9

10 A. a) As of March 31, 2021, as part of Newfoundland and Labrador Hydro's ("Hydro") process
11 with respect to the Labrador Network Additions Policy, Hydro had received significant
12 customer service requests in Labrador East and Labrador West. On November 10, 2022, the
13 Government of Newfoundland and Labrador issued an Order in Council OC2022-266
14 exempting Hydro from the legislative obligation to supply firm electrical service in
15 Newfoundland and Labrador to applicants from cryptocurrency industries, which
16 significantly reduced the requests. At the time of the load forecast development, there were
17 two firm requests for service in Labrador West with a combined request of 850 MW. In
18 Labrador East, there were three firm requests for service with a combined request of
19 23.4 MW.

20 b) The two Industrial customers currently being served in Labrador West are the Iron Ore
21 Company of Canada and Tacora Resources Inc.