

1 Q. **Reference: Volume II, Wood Pole Line Management Program - Various, Tab 11, page 9, Table 7**

2

3 Does conductor inspection and maintenance form part of Hydro's practices for Wood Pole Line
4 Management? If yes, why isn't conductor included as a line component in Table 7? If not, why
5 not?

6

7

8 A. Yes. Conductor inspection and maintenance forms part of Newfoundland and Labrador Hydro's
9 ("Hydro") practices for Wood Pole Line Management. To date, Hydro has not encountered a
10 material amount of conductor deterioration on its transmission lines. Conductor refurbishment
11 therefore makes up a small portion of the overall program; it is included under the
12 "Miscellaneous" line of Table 7.