

1 Q. Paragraph 8 of the revised application states that: “Alternatives involving the interconnection of  
2 multiple isolated systems are expected to further facilitate the integration of renewable energy  
3 in the future, as such systems are better suited to absorb fluctuations in supply that are  
4 commonly experienced from renewable generation, allowing for a greater penetration of  
5 renewable energy on the system.”

6 In addition, Hydro’s revised application appears to rely on the finding in the Integrated Response  
7 Plan provided by Midgard Consulting Inc. (the “Midgard Report”) that the fully interconnected  
8 system configuration facilitates greater penetration of incremental renewable energy sources  
9 sooner (see, for example, pages 5 and 8 of Schedule 2).

10 a) Please provide the existing renewable energy penetration maximums per each of the  
11 eight isolated diesel power plants in NCC territory (in terms of percentage and in units  
12 of energy – recent three-year average), and the value of increased renewable energy  
13 penetration in the proposed regional diesel plant, displacing the existing four power  
14 plants (again in percentage and units of energy – three-year average).

15 b) Please provide details regarding how the revised application (including the revised  
16 project schedule) will affect when renewable energy projects are expected to be  
17 researched, developed, and executed in the area.


18

19

20 A. a) It is not possible to determine the exact technical or economic renewable energy  
21 penetration limits for any isolated diesel powered community without understanding the  
22 scale of the project being considered and the amount of federal funding available for the  
23 specific project. Independent power producers interested in selling power to Newfoundland  
24 and Labrador Hydro (“Hydro”) would need to complete their own Hybrid Power Dispatch  
25 and Economic Study. This study would investigate a number of different renewable energy  
26 generation and energy storage technologies to determine which is the most economic to  
27 develop based on technical constraints and the amount of outside funding available for the  
28 project.

1 From a technical perspective, the maximum amount of renewable energy that can be  
2 installed in any isolated diesel powered community depends on the scale of the renewable  
3 energy generation facility and technology used. From an economic perspective, the amount  
4 of energy penetration that can be achieved depends on the technical limits, project costs,  
5 diesel fuel costs, and amount of outside funding available.

6 The technical maximum renewable energy penetration of a small scale renewable energy  
7 project with no control system will be limited based on the renewable energy facilities  
8 capacity. In turn, the capacity of the facility will be limited based on the difference between  
9 the system's minimum load and the minimum generation limit of the smallest diesel genset.  
10 The amount of energy generated would be dependent on the renewable energy resource  
11 (i.e., sunlight for a solar installation, or wind for a wind turbine installation). For example, in  
12 the theoretical system depicted in Figure 1, the maximum capacity for a small scale  
13 renewable energy project without a control system would be 47 kW which is the minimum  
14 community load (147 kW) minus the minimum diesel unit generation limit (100 kW). The  
15 amount of energy that could be generated would equal the area under the solar generation  
16 curve.



**Figure 1: Daily Load Profile**

- 1 The technical maximum renewable energy penetration of a medium scale renewable energy
- 2 project that has a battery energy storage system sized to manage fluctuations in renewable
- 3 generation, and a dedicated communication link to Hydro’s diesel plant, would be limited
- 4 based on the difference between the diesel units minimum load levels and the community
- 5 load at all points in time, not just the minimum value. The system would not have a capacity
- 6 limit imposed, and in theory could be designed to provide all the remaining energy beyond
- 7 the energy provided by Hydro’s smallest diesel unit when it is operating at the minimum
- 8 diesel generation limit.

1           The maximum renewable energy potential for medium scale renewable energy projects in  
2           the isolated system considered as part of the southern Labrador interconnection project is  
3           included in Hydro’s application.<sup>1</sup>

4           Considering the theoretical system depicted in Figure 1, the maximum amount of renewable  
5           energy penetration would be the area between the community load and minimum diesel  
6           generation curve.

7           The technical maximum renewable energy penetration limit of a large-scale renewable  
8           energy project that has a battery energy storage system and control system designed to  
9           allow for a diesel-off operation would be the full energy requirements of the system. For  
10          example, considering the theoretical system depicted in Figure 1, this would be represented  
11          by the area under the community load curve.

12          **b)** Renewable energy projects are already being researched, developed, and executed all over  
13          the province, including within southern Labrador. Hydro expects these activities to continue  
14          with or without the proposed interconnection; however, if the proposed interconnection is  
15          constructed, there will be increased potential for renewable energy projects in terms of the  
16          number and size of such projects, as well as the area in which they may be feasible. If the  
17          interconnection is constructed as per the revised application, this would increase the  
18          potential for renewable energy projects even further than the initially proposed phased  
19          interconnection. The immediate interconnection of the communities as proposed within  
20          Hydro’s revised application will allow for greater renewable penetration sooner than  
21          Hydro’s initial proposal.

22          Regardless of the alternative, penetration of renewable energy is limited to that which is  
23          feasible on each individual system, until such time that the individual systems are  
24          interconnected, which Hydro expects to be completed in 2027.

---

<sup>1</sup> “Long-Term Supply for Southern Labrador – Revision 1,” Newfoundland and Labrador Hydro, rev. May 31, 2023 (originally filed July 16, 2021), sch. 1, att. 1, app. B, p. 3, table 1.