

1 Q. **Reference: Midgard Consulting March 28, 2023 Report - Southern Labrador Communities –**
2 **Integrated Resource Plan**

3 Further to PUB-NLH-075, would the assignment of a 25% FOR with respect to the mobile
4 generators have impacted any of Midgard’s or Hydro’s recommendations/conclusions? Please
5 explain and provide any associated analysis.

6

7

8 A. As discussed in Newfoundland and Labrador Hydro’s (“Hydro”) response to PUB-NLH-075 of this
9 proceeding, Hydro does not use forced outage rates when determining its capacity
10 requirements for its isolated systems.