

1 Q. **Refurbishment of Tank 2.**

2 Please provide copies of all communications to and from the provincial regulator with respect to
3 the possibility of a further extension beyond June 2023 for the inspection of Tank 2.

4

5

6 A. The provincial regulator, during discussions regarding extending Tank 2, thoroughly scrutinized
7 all calculations provided by TEAM Industrial Services and insisted on a conservative approach to
8 the interpretation of the API 653.¹ Through this review, June 2023 was determined to be the
9 appropriate interval for the next planned inspection and no further discussions were had about
10 possibly extending the inspection interval beyond that date. Please refer to Newfoundland and
11 Labrador Hydro's response to IC-NLH-014.

¹ *Tank Inspection, Repair, Alteration, and Reconstruction*, API Standard 653, 2014.