

1 Q. Table 1, page 3, shows Unit 2044, Hydro's spare mobile diesel genset, as being utilized as a
2 power supply for Charlottetown and Pinsent's Arm in 2023.

3 a) Does Hydro plan to keep Unit 2044 in Charlottetown until a longer-term supply solution is
4 implemented? If not, please provide details.

5 b) Does Hydro plan to acquire another spare mobile diesel genset to replace Unit 2044? Please
6 include the rationale for your response.

7

8

9 A. a) Yes. Newfoundland and Labrador Hydro ("Hydro") plans on keeping Unit 2044 in
10 Charlottetown until a longer-term supply solution is implemented.

11 b) No. Hydro does not plan to acquire another mobile diesel genset to replace Unit 2044.
12 Mobile units are experiencing a worldwide supply shortage. In the event of a mobile unit
13 failure, a rental unit would have to be acquired to replace the failed unit, which would not
14 be secured until needed. Hydro has approached its vendors and there are currently no
15 mobile units for sale.