

1 Q. **Reference: Volume II, 2023 Capital Budget Application, Program 14, Upgrade of Worst-**  
2 **Performing Distribution Feeders (2023–2024), page 8, lines 1 to 4.**

3 How many kilometres of #2 ACSR on FHD-L1 are planned to be replaced?

4

5

6 A. Newfoundland and Labrador Hydro plans to replace approximately 250 meters of #2 ACSR<sup>1</sup> on  
7 Feeder FHD-L1.

---

<sup>1</sup> Aluminum-conductor steel reinforced (“ACSR”).