

1 Q. **Reference: Application, Schedule 6, Proposals Under \$750,000, page 8 of 13 and 11 of 13**

2 Why are the “Replace 48V Battery Banks and Chargers” (page 8) and “Replace Terminal Station
3 Battery Banks and Chargers” (page 11) ***not*** included under the “Replace Terminal Station Battery
4 Banks and Chargers” project?

5

6

7 A. The Replace 48V Battery Banks and Chargers program and the Replace Terminal Station Battery
8 Banks and Chargers program are not combined, as they represent different asset classes and are
9 used on different types of equipment. The 48 V battery banks and chargers are for telecontrol
10 equipment that requires lower voltage, whereas terminal station battery banks and chargers are
11 normally 125 V and are used primarily for protection and control equipment.