

1 Q. **Reference: Capital Expenditures and Carryover Report for the Year Ended December 31, 2022,**
2 **page 21**

3 It is stated

4 Protective relay replacements for Wabush Terminal Station Line 1 and Line 3,
5 due to the manufacturer's recall of some protective relays.

6 Are relays of the type recalled installed elsewhere on Hydro's system?

7

8

9 A. None of the relays to which this recall applies are installed elsewhere on Newfoundland and
10 Labrador Hydro's system.